

NRR-PMDAPEm Resource

From: Goetz, Sujata
Sent: Thursday, August 07, 2014 10:13 AM
To: Timothy.Hope@luminant.com; Ervin-Walker, Tamera (Tamera.Ervin-Walker@luminant.com)
Cc: Singal, Balwant
Subject: FW: Acceptance Review - Comanche Peak Nuclear Power Plant, Units 1 and 2 License Amendment Request to Revise Technical Specification 3.8.1 (TAC Nos. MF 4342, MF 4343)

By letter dated July 1, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14192A338), Luminant Generation Company LLC, submitted a license amendment request for Comanche Peak Nuclear Power Plant, Units 1 and 2, for revision to Technical Specification S 3.8.1, "AC [Alternating Current] Sources – Operating" to extend, on a one time basis, the completion time (CT) of Required Action A.3 for one inoperable offsite circuit, from 72 hours to 14 days. The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the Code of Federal Regulations (10 CFR), an amendment to the license (including the TSs) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-8004.

Sujata Goetz
Project Manager, Office of Nuclear Reactor Regulation
O8C10
(voice) 301-415-8004

Hearing Identifier: NRR_PMDA
Email Number: 1477

Mail Envelope Properties (Sujata.Goetz@nrc.gov20140807101300)

Subject: FW: Acceptance Review - Comanche Peak Nuclear Power Plant, Units 1 and 2
License Amendment Request to Revise Technical Specification 3.8.1 (TAC Nos. MF 4342, MF 4343)
Sent Date: 8/7/2014 10:13:17 AM
Received Date: 8/7/2014 10:13:00 AM
From: Goetz, Sujata

Created By: Sujata.Goetz@nrc.gov

Recipients:

"Singal, Balwant" <Balwant.Singal@nrc.gov>

Tracking Status: None

"Timothy.Hope@luminant.com" <Timothy.Hope@luminant.com>

Tracking Status: None

"Ervin-Walker, Tamera (Tamera.Ervin-Walker@luminant.com)" <Tamera.Ervin-Walker@luminant.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2289	8/7/2014 10:13:00 AM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: