

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 5706

FILE:

FROM: Carolina Power & Light Co. Raleigh, N.C. 27602 N. B. Bessac			DATE OF DOC 7-19-73	DATE REC'D 7-25-73	LTR x	MEMO	RPT	OTHER
TO: John F. O'Leary			ORIG 3 signed	CC 37	OTHER	SENT AEC PDR x SENT LOCAL PDR x		
CLASS	UNCLASS x	PROP INFO	INPUT	NO CYS REC'D 40		DOCKET NO: 50-261		

DESCRIPTION:

Ltr furnishing monthly report of primary and secondary activity measurements and effluent discharge activity levels for June, 1973...

ENCLOSURES:

**ACKNOWLEDGED
DO NOT REMOVE**

PLANT NAME: H. B. Robinson

FOR ACTION/INFORMATION

7-25-73 LB

BUTLER(L) W/ Copies	SCHWENCER(L) W/ Copies	ZIEMANN(L) W/ Copies	REGAN(E) W/ Copies
CLARK(L) W/ Copies	STOLZ(L) W/ Copies	DICKER(E) W/ Copies	W/ Copies
GOLLER(L) W/ Copies	VASSALLO(L) W/ Copies	KNIGHTON(E) W/ Copies	W/ Copies
KNIEL(L) W/ Copies	✓SCHEMEL(L) W/ 7 Copies	YOUNGBLOOD(E) W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

✓ <u>REG FILE</u>	<u>TECH REVIEW</u>	DENTON	<u>LIC ASST</u>	<u>A/T IND</u>
✓AEC PDR	HENDRIE	GRIMES	BROWN (E)	BRAITMAN
✓OGC, ROOM P-506A	SCHROEDER	GAMMILL	DIGGS (L)	SALTZMAN
✓MUNIZING/STAFF	✓MACCARY	KASTNER	GEARIN (L)	
✓CASE	KNIGHT	BALLARD	GOULBOURNE (L)	<u>PLANS</u>
GIAMBUSSO	PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	SHAO		MAIGRET (L)	DUBE
MOORE (L) (BWR)	✓STELLO	<u>ENVIRO</u>	SERVICE (L)	
DEYOUNG(L) (PWR)	HOUSTON	MULLER	SHEPPARD (E)	<u>INFO</u>
✓SKOVHOLT (L)	NOVAK	DICKER	SMITH (L)	C. MILES
P. COLLINS	ROSS	KNIGHTON	✓TEETS (L)	
	IPPOLITO	YOUNGBLOOD	WADE (E)	
<u>REG OPR</u>	✓TEDESCO	REGAN	WILLIAMS (E)	
✓FILE & REGION(3)	LONG	PROJECT LDR	WILSON (L)	
MORRIS	LAINAS			
✓STEELE	BENAROYA	<u>HARLESS</u>		
	VOLLMER			

EXTERNAL DISTRIBUTION

✓1 - LOCAL PDR Hartville, S. C.	(1)(2)(9)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
✓1 - DTIE(ABERNATHY)	1-R.Schoonmaker, OC, GT, D-323	1-GERALD LELLOUCHE
✓1 - NSIC(BUCHANAN)	1-R. CATLIN; E-256-GT	BROOKHAVEN NAT. LAB
1 - ASLB(YORE/SAYRE/ WOODARD/"H" ST.	1-CONSULTANT'S	1-AGMED(WALTER KOESTER
✓16 - CYS ACRS XXXXXXXX SENT TO LIC ASST.	NEWMARK/BLUME/AGBABIAN	RM-C-427-GT
S. TEETS 7-25-73	1-GERALD ULRIKSON...ORNL	✓1-RD..MULLER...F-309 GT

Regulatory

File Cy.



Carolina Power & Light Company

50-261

July 19, 1973

File: NG 5211.1

Serial: NG-73-209

Mr. John F. O'Leary, Director
Directorate of Reactor Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545


Dear Mr. O'Leary:

H. B. ROBINSON UNIT NO. 2
LICENSE DPR-23

MONTHLY REPORT OF PRIMARY AND SECONDARY ACTIVITY
MEASUREMENTS AND EFFLUENT DISCHARGE ACTIVITY LEVELS


In accordance with the requirements of the "Interim Conditions for Operation, H. B. Robinson Unit No. 2," dated September 12, 1972, we hereby submit as an attachment the monthly report of primary and secondary activity measurements and effluent discharge activity levels for June, 1973.

Yours very truly,


N. B. Bessac
Manager
Nuclear Generation

NBB:mvp
Attachment

cc: Messrs. C. D. Barham
B. J. Furr
D. V. Menscer
E. E. Utley
D. B. Waters



57076

A.E.C. INTERIM MONTHLY REPORT

MONTH AND YEAR: June, 1973

DAY	RCS GROSS DEGASSED ACTIVITY, uci/ml	STEAM GENERATOR GROSS ACTIVITY, uci/ml			LIQUID DISCHARGE, mci	
		A	B	C	GROSS ACTIVITY	GROSS IODINE
1	2.52 (10^{-1})	0	0	0	1.034 mci Gaseous	0.004 mci
2	2.46 (10^{-1})	0	0	0		
3						
4	1.37 (10^{-1})	0	0	0	8.783 mci particulate	
5	2.45 (10^{-1})	0	0	0		
6	3.06 (10^{-1})	0	0	0		
7	2.79 (10^{-1})	0	0	0	9.817 mci Total	
8	2.33 (10^{-1})	9.29 (10^{-7})	0	0		
9	2.19 (10^{-1})	0	0	0		
10						
11	2.94 (10^{-1})	0	0	0		
12	2.92 (10^{-1})	0	0	0		
13	2.84 (10^{-1})	0	0	0		
14	3.14 (10^{-1})	0	0	0		
15	2.84 (10^{-1})	1.1 (10^{-6})	0	0		
16	2.69 (10^{-1})	0	0	0		
17						
18	2.71 (10^{-1})	0	0	0		
19	3.02 (10^{-1})	0	0	0		
20	3.49 (10^{-1})	0	0	0		
21	2.39 (10^{-1})	8.99 (10^{-7})	0	0		
22	2.11 (10^{-1})	8.39 (10^{-7})	0	0		
23	2.01 (10^{-1})	1.19 (10^{-6})	0	0		
24						
25	3.62 (10^{-1})	1.71 (10^{-6})	9.19 (10^{-7})	4.74 (10^{-7})		
26	3.52 (10^{-1})	0	0	0		
27	3.21 (10^{-1})	1.71 (10^{-6})	0	0		
28	3.47 (10^{-1})	1.26 (10^{-6})	0	0		
29	2.24 (10^{-1})	2.79 (10^{-7})	1.12 (10^{-6})	7.83 (10^{-7})		
30	2.07 (10^{-1})	0	0	0		
31						

Ø IMPLIES < MDA OF $\sim 7.5 \times 10^{-7}$ uci/ml