

ACKNOWLEDGED

DO NOT REMOVE

FILE: Misc R&D

FROM: Carolina Power & Light Company Raleigh, N. C. 27602 E. E. Utley			DATE OF DOC 8-7-73	DATE REC'D 8-15-73	LTR x	MEMO	RPT	OTHER
TO: J. F. O'Leary			ORIG 3 signed	CC	OTHER	SENT AEC PDR <u>x</u> SENT LOCAL PDR <u>x</u>		
CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D 40		DOCKET NO: 50-261		
	x							

DESCRIPTION:

Ltr trans the following:

ENCLOSURES:

REPORT: Monthly Report of Primary &
Secondary Activity Measurements and Effluent
Discharge Activity Levels for July, 1973

PLANT NAME: H. B. Robinson

(40 cys encl rec'd)

FOR ACTION/INFORMATION 8-15-73 LB


BUTLER(L)	SCHWENCER(L)	ZIEMANN(L)	REGAN(E)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
GOLLER(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL(L)	✓SCHEMEL(L)	YOUNGBLOOD(E)	
W/ Copies	W/ 7 Copies	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

✓REG FILE	TECH REVIEW	DENTON	LIC ASST	A/T IND
✓AEC PDR	HENDRIE	GRIMES	BROWN (E)	BRAITMAN
✓OGC, ROOM P-506A	SCHROEDER	GAMMILL	DIGGS (L)	SALTZMAN
✓MUNTZING/STAFF	✓MACCARY	KASTNER	GEARIN (L)	
CASE	KNIGHT	BALLARD	GOULBOURNE (L)	PLANS
GIAMBUSSO	PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	SHAO		MAIGRET (L)	DUBE
MOORE (L)(BWR)	✓STELLO	ENVIRO	SERVICE (L)	
DEYOUNG(L)(PWR)	HOUSTON	MULLER	SHEPPARD (E)	INFO
✓SKOVHOLT (L)	NOVAK	DICKER	SMITH (L)	C. MILES
P. COLLINS	ROSS	KNIGHTON	✓TEETS (L)	
	IPPOLITO	YOUNGBLOOD	WADE (E)	
REG OPR	✓TEDESCO	REGAN	WILLIAMS (E)	
✓FILE & REGION(3)	LONG	PROJECT LDR	WILSON (L)	
MORRIS	LAINAS			
✓STEELE	BENAROYA	HARLESS		
	VOLLMER			

EXTERNAL DISTRIBUTION

✓1 - LOCAL PDR <u>Hartville, S. C.</u>	(1)(2)(9)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
✓1 - DTIE(ABERNATHY)	1-R.Schoonmaker, OC, GT, D-323	1-GERALD LELLOUCHE
✓1 - NSIC(BUCHANAN)	1-R. CATLIN, E-256-GT	BROOKHAVEN NAT. LAB
1 - ASLB(YORE/SAYRE/ WOODARD/"H" ST.	1-CONSULTANT'S	1-AGMED(WALTER KOESTER
✓16 - CYS ACRS WALKING SENT TO LIC ASST.	NEWMARK/BLUME/AGBABIAN	RM-C-427-GT
S. TEETS 8-15-73	1-GERALD ULRIKSON...ORNL	✓1-RD..MULLER..F-309-GT



Carolina Power & Light Company

August 7, 1973

File: NG 5211.1

Serial: NG-73-263


Mr. John F. O'Leary, Director
Directorate of Reactor Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545

Dear Mr. O'Leary:

50-261


H. B. ROBINSON UNIT NO. 2
LICENSE DPR-23

MONTHLY REPORT OF PRIMARY AND SECONDARY ACTIVITY
MEASUREMENTS AND EFFLUENT DISCHARGE ACTIVITY LEVELS



In accordance with the requirements of the "Interim Conditions for Operation, H. B. Robinson Unit No. 2," dated September 12, 1972, we hereby submit as an attachment the monthly report of primary and secondary activity measurements and effluent discharge activity levels for July, 1973.


Yours very truly,


E. E. Utley
Vice-President
Bulk Power Supply

JH:NBB:mvp

Enclosure

cc: Messrs. C. D. Barham
N. B. Bessac
B. J. Furr
D. V. Menscer
D. B. Waters



A.E.C. INTERIM MONTHLY REPORT

MONTH AND YEAR: JULY, 1973

DAY	RCS GROSS DEGASSED ACTIVITY, uci/ml	STEAM GENERATOR GROSS ACTIVITY, uci/ml			LIQUID DISCHARGE, mci	
		A	B	C	GROSS ACTIVITY	GROSS IODINE
1						
2	7.54 (10^{-2})	9.49 (10^{-7})	0	0		
3	2.26 (10^{-1})	0	0	0		
4	3.28 (10^{-1})	0	0	0		
5	3.19 (10^{-1})	6.46 (10^{-7})	0	0		
6	2.96 (10^{-1})	6.16 (10^{-7})	0	0	4.650 mci	0.213 mci
7	1.64 (10^{-1})	1.39 (10^{-6})	0	0	particulate	
8						
9	3.32 (10^{-1})	2.5 (10^{-6})	0	0		
10	2.94 (10^{-1})	1.56 (10^{-6})	7.07 (10^{-7})	0	6.229 mci	
11	3.20 (10^{-1})	0	0	0	gaseous	
12	2.51 (10^{-1})	0	0	0		
13	3.27 (10^{-1})	0	0	0	10.879 mci	
14	1.63 (10^{-1})	0	0	0	Total	
15						
16	3.01 (10^{-1})	0	0	0		
17	3.05 (10^{-1})	0	0	0		
18	3.64 (10^{-1})	2.62 (10^{-6})	0	0		
19	3.37 (10^{-1})	9.13 (10^{-7})	0	0		
20	3.42 (10^{-1})	4.9 (10^{-7})	0	0		
21	1.71 (10^{-1})	0	0	0		
22						
23	2.45 (10^{-1})	0	0	0		
24	3.26 (10^{-1})	2.26 (10^{-6})	0	0		
25	3.22 (10^{-1})	3.17 (10^{-6})	0	7.52 (10^{-7})		
26	3.41 (10^{-1})	2.17 (10^{-7})	0	0		
27	3.51 (10^{-1})	1.57 (10^{-6})	0	0		
28	2.45 (10^{-1})	1.60 (10^{-6})	0	0		
29						
30	2.16 (10^{-1})	6.01 (10^{-7})	0	0		
31	2.1 (10^{-1})	0	0	0		