

50-261

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

DATE OF DOCUMENT

08/03/77

DATE RECEIVED

08/09/77

NUMBER OF COPIES RECEIVED

1 signed

TO: Mr. Robert W. Reid

FROM: CP&L

Raleigh, N. C. 27602

E. E. Utley

☒ LETTER☐ NOTORIZED

PROP

INPUT FORM

☒ ORIGINAL☒ UNCLASSIFIED☐ COPY

DESCRIPTION Furnishing info regarding plant
modifications to comply with the staff position
on onsite emergency power systems.

ENCLOSURE

1p

DISTRIBUTION OF MATERIAL CONCERNING ONSITE
EMERGENCY POWER SYSTEMS

PLANT NAME: H. B ROBINSON UNIT # 2
jcm 08/10/77

ACKNOWLEDGED
DO NOT REMOVE

SAFETY

FOR ACTION/INFORMATION

BRANCH CHIEF: (7) Reid

PROJECT MANAGER:

LIC. ASST.

INTERNAL DISTRIBUTION

REG FILE

NRC PDR

I & E(2)

OELD

MIPC

HANAUER

BENAROYA

IPPOLITO

EISENHUT

SHAO

BAER

BUTLER

GRIMES

F. ROSA

T. WAMBACH

D. TONDI

D. MCDONALD

D. JAFFE

EXTERNAL DISTRIBUTION

LPDR: HARTSVILLE SC.

16 CYS ACRS CATEGORY B

CONTROL NUMBER

misc
772220082
B



Carolina Power & Light Company

August 3, 1977

REGULATORY DOCKET FILE COPY

FILE: NG-3514 (R)

SERIAL: NG-77-883

Director of Nuclear Reactor Regulation
ATTN: Mr. Robert W. Reid, Chief
Operating Reactors Branch #4
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
ONSITE EMERGENCY POWER SYSTEMS

Dear Mr. Reid:

Your letter of June 3, 1977 requested that CP&L commit to plant modifications to comply with the staff positions on onsite emergency power systems. As a result of your letter, CP&L has requested an engineering consultant to study the existing plant systems and design modifications consistent with the criteria expressed in the staff positions. This design work will be completed in early 1978 and installation will be completed as soon thereafter as equipment and plant availability permit.

Your letter also requested that CP&L request a license amendment to incorporate technical specification changes comparable to those described. Since the proposed changes implement surveillance and operability requirements for the equipment to be installed as a result of the modifications to be designed, they are not yet meaningful. CP&L will submit a request for appropriate technical specification changes at least sixty days prior to the installation of any modifications, accompanied by a description of the modification.

Yours very truly,

E. E. Utley
Senior Vice President
Power Supply

CSB/MFP/gsm