

50-261

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: Mr. Robert W. Reid

FROM: CP&L
Raleigh, N. C. 27602
E. E. UtleyDATE OF DOCUMENT
10/04/77DATE RECEIVED
10/11/77☒ LETTER
☒ ORIGINAL
☐ COPY☒ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

3 signed

DESCRIPTION Notorized 10/04/77...Trans The
Following:

1p

ENCLOSURE

License No. DPR-23 Appl for Amend:
tech specs proposed change concerning revising
the qualifications for the Environmental and
Radiation Control Supervisor...

1p

PLANT NAME: H. B. ROBINSON UNIT # 2
jcm 10/11/77

dist: Mh

37045 encl. rec'd *

SAFETY

FOR ACTION/INFORMATION

ENVIRONMENTAL

ASSIGNED AD:

Golke

ASSIGNED AD:

V. MOORE (LTR)

BRANCH CHIEF:

BRANCH CHIEF:

Regan

PROJECT MANAGER:

PROJECT MANAGER:

Bajwa

LICENSING ASSTANT:

LICENSING ASSISTANT:

Duncan

B. HARLESS

INTERNAL DISTRIBUTION

REG FILES

SYSTEMS SAFETY

PLANT SYSTEMS

SITE SAFETY &

NRC PDR

R. MATTSON

TEDESCO

ENVIRON ANALYSIS

I & E (2)

SCHROEDER

BENAROYA

DENTON & MULLER

OELD

LAINAS

CRUTCHFIELD

GOSSICK & STAFF

ENGINEERING

IPPOLITO

HANAUER

KNIGHT

F. ROSA

ENVIRO TECH.

MIPC

BOSNAK

ERNST

CASE

SIHWELL

OPERATING REACTORS

BALLARD

BOYD

PAWLICKI

STELLO

YOUNGBLOOD

PROJECT MANAGEMENT

REACTOR SAFETY

SHAO

SITE TECH.

SKOVHOLT

ROSS

BAER

GAMMILL (2)

P. COLLINS

NOVAK

BUTLER

HOUSTON

ROSZTGCZY

GRIMES

MELTZ

CHECK

SITE ANALYSIS

HELTEMES

VOLLMER

SK

AT&I

BUNCH

SALTZMAN

J. COLLINS

RUTBERG

KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Hartsville, SC

TIC

NSIC

NAT LAB (3)

REG IV (J. HANCHETT)

16 CYS ACRS SENT CATEGORY

772840055



REGULATORY DOCKET FILE COPY

Carolina Power & Light Company

October 4, 1977

FILE: NG-3514 (R)

SERIAL NO.: NG-77-1138

Office of Nuclear Reactor Regulation
ATTN: Mr. Robert W. Reid, Chief
Operating Reactors Branch No. 4
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

RE: H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23

REQUEST FOR LICENSE AMENDMENT - REVISION OF TECHNICAL SPECIFICATIONS


Dear Mr. Reid:

As requested by your letter of August 18, 1977 and in accordance with the Code of Federal Regulations, Title 10, Parts 2.101 and 50.90, Carolina Power & Light Company (CP&L) hereby requests a revision to the Technical Specifications for its H. B. Robinson Steam Electric Plant, Unit No. 2. This amendment revises the qualifications for the Environmental and Radiation Control supervisor.

The present incumbent does exceed the qualifications of Regulatory Guide 1.8, September 1975 as clarified by your letter of August 18, 1977. A revised Technical Specification page to reflect the new qualifications, with clarification, is attached. The revised portion is shown by the vertical bar in the right hand margin.

Yours very truly,

E. E. Utley
Senior Vice President
Power Supply



CSB/gsm
Attachment

Sworn to and subscribed before me this 4th day of October, 1977.

Franklin Murray
Notary Public

My Commission Expires: October 4, 1981

336 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

772840055

6.3

FACILITY STAFF QUALIFICATIONS

6.3.1 Each member of the facility staff shall meet or exceed ANSI N18.1-1971 with regard to the minimum qualifications for comparable positions

6.3.2 The Environmental and Radiation Control Supervisor shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975. The Guide says that he shall have a bachelor's degree or equivalent in a science or engineering subject. Equivalent in this case is defined as follows:

- (a) 4 years of formal schooling in science or engineering,
- (b) 4 years of applied radiation protection experience at a nuclear facility,
- (c) 4 years of operational or technical experience/training in nuclear power, or
- (d) Any combination of the above totaling 4 years.

This requirement is in addition to the requirement for five years of professional experience in applied radiation protection.