

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207150019 DOC. DATE: 92/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 GROOMS, J.W. Carolina Power & Light Co.
 CHAMBERS, R.H. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1992 for HB Robinson Steam
 Electric Plant, unit 2.W/920709 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-1 LA	3 3	PD2-1 PD	1 1
MOZAFARI, B	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1
<u>REG FILE</u> 01	1 1	RGN2	1 1
EXTERNAL: EG&G BRYCE, J.H	1 1	NRC PDR	1 1
NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MOR
E.B.



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

JUL 09 1992

Robinson File: 15505

Serial: RNP/92-1828

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of June, 1992.

Very truly yours,

R. H. Chambers
General Manager
H. B. Robinson S. E. Plant

AES:sgk

Enclosures

cc: Mr. S. D. Ebnetter
Mr. L. W. Garner

9207150019 920630
PDR ADOCK 05000261
R PDR

IE 24
11

CP&L CO

RUN DATE 07/06/92

RUN TIME 07:57:59

PLANT PERFORMANCE DATA SYSTEM

OPERATING DATA REPORT

ROBINSON UNIT 2

PAGE 1

RPD36-000

DOCKET NO. 050-0261

COMPLETED BY JACKIE GROOMS

TELEPHONE (803)383-4524

OPERATING STATUS

- | | |
|--|---|
| 1. UNIT NAME: ROBINSON UNIT 2 | NOTES There were 252 assemblies
and one (1) skeleton assembly with
100 Fuel Rods in the Spent Fuel
Pool. There are 56 assemblies in
the Dry Fuel Storage, and 157 in
the Reactor Vessel. |
| 2. REPORTING PERIOD: JUNE 92 | |
| 3. LICENSED THERMAL POWER (MWT): 2300 | |
| 4. NAMEPLATE RATING (GROSS MWE): 739.0 | |
| 5. DESIGN ELECTRICAL RATING (NET MWE): 700.0 | |
| 6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0 | |
| 7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0 | |
| 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT,
GIVE REASONS: N/A | |

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): N/A
10. REASONS FOR RESTRICTION IF ANY: NONE

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	720.00	4367.00	187031.00
12. NUMBER OF HOURS REACTOR CRITICAL	193.58	2282.98	130672.24
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	156.95	2244.22	127765.42
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	216654.48	4958544.24	258832474.32
17. GROSS ELEC. ENERGY GEN. (MWH)	66996.00	1661318.00	83919555.00
18. NET ELEC. ENERGY GENERATED (MWH)	55825.00	1571656.00	79256593.00
19. UNIT SERVICE FACTOR	21.80	51.39	68.31
20. UNIT AVAILABILITY FACTOR	21.80	51.39	68.32
21. UNIT CAP. FACTOR (USING MDC NET)	11.35	52.69	63.60
22. UNIT CAP. FACTOR (USING DER NET)	11.08	51.41	60.54
23. UNIT FORCED OUTAGE RATE	.00	.00	14.70
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):	N/A		

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: N/A
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

CP&L CO

RUN DATE 07/06/92

RUN TIME 07:57:58

PLANT PERFORMANCE DATA SYSTEM

APPENDIX B - AVERAGE DAILY POWER LEVEL

ROBINSON UNIT 2

PAGE 1

RPD39-000

DOCKET NO. 050-0261
COMPLETED BY JACKIE GROOMS
TELEPHONE (803) 383-4524

JUNE 1992

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-2	17	-18
2	-2	18	-20
3	-2	19	-20
4	-2	20	-21
5	-4	21	-22
6	-4	22	-22
7	-4	23	-22
8	-3	24	57
9	-5	25	141
10	-7	26	277
11	-5	27	469
12	-7	28	466
13	-9	29	538
14	-12	30	629
15	-18		
16	-18		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 050-0261
UNIT NAME H. B. Robinson
DATE 07-06-92
COMPLETED BY J. W. Grooms
TELEPHONE (803) 383-4524

REPORT MONTH JUNE

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0306*	060192	S	563.05	C	1	---	ZZ	ZZZZZ	Continuation of Cycle #14 Refueling Outage.
0601	062492	S		C	1	---	ZZ	ZZZZZ	Unit brought on line and ramping up to full power after completion of RO #14.
*Continuation from previous month.									

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance of Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵
Exhibit I - Same Source

(9/77)