

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9209210008      DOC. DATE: 92/08/31      NOTARIZED: NO      DOCKET #  
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C      05000261  
 AUTH. NAME      AUTHOR AFFILIATION  
 GROOMS, J.      Carolina Power & Light Co.  
 CHAMBERS, R.H.      Carolina Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1992 for HB Robinson Steam  
 Electric Plant. W/920915 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7  
 TITLE: Monthly Operating Report (per Tech Specs)

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD2-1 LA	3 3	PD2-1 PD	1 1	/
	MOZAFARI, B	1 1			A
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1	D
	NRR/DLPO/LPEB10	1 1	NRR/DOEA/OEAB	1 1	D
	<u>REG FILE</u> 01	1 1	RGN2	1 1	S
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1	
	NSIC	1 1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

*MOR*  
*2/11*



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29550

SEP 15 1992

Robinson File: 15505

Serial: RNPD/92-2396

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of August, 1992.

Very truly yours,

R. H. Chambers  
General Manager  
H. B. Robinson S. E. Plant

AES:sgk

Enclosures

cc: Mr. S. D. Ebnetter  
Mr. L. W. Garner

210007

9209210008 920831  
PDR ADOCK 05000261  
R PDR

CP&L CO  
RUN DATE-  
RUN TIME

PLANT PERFORMANCE DATA SYSTEM  
OPERATING DATA REPORT  
ROBINSON UNIT 2

PAGE 1  
RPD36-000

DOCKET NO. 050-0261  
COMPLETED BY: JACKIE GROOMS  
TELEPHONE (803)383-4524

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: AUGUST 92
3. LICENSED THERMAL POWER (MST): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NEW MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THRU 7) SINCE LAST REPORT,  
GIVE REASONS: N/A

NOTES: THERE ARE 224  
ASSEMBLIES AND ONE  
SKELETON ASSEMBLY WITH  
100 RODS IN THE SPENT  
FUEL POOL. THERE ARE 56  
ASSEMBLIES IN THE DRY  
FUEL STORAGE, 157 IN THE  
REACTOR VESSEL, 7  
ASSEMBLIES IN SPENT FUEL  
CASK IF-303 AND 7  
ASSEMBLIES IN SPENT FUEL  
CASK IF-304.

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): N/A
10. REASONS FOR RESTRICTION, IF ANY: NONE

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH):  
MAR. 6, 1993-MAR. 26, 1993. MAINTENANCE OUTAGE FOR POLAR CRANE REPAIRS.
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: 9/12/92
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION: FORECAST ACHIEVED

INITIAL CRITICALITY

\_\_\_\_ -- \_\_\_\_

INITIAL ELECTRICITY

\_\_\_\_ -- \_\_\_\_

COMMERCIAL OPERATION

\_\_\_\_ -- \_\_\_\_

CP&L CO  
RUN DATE 09/03/92  
RUN TIME 09:06:28

PLANT PERFORMANCE DATA SYSTEM  
APPENDIX B - AVERAGE DAILY POWER LEVEL  
ROBINSON UNIT 2

PAGE 1  
RPD39-000

DOCKET NO. 050-0261  
COMPLETED BY: JACKIE GROOMS  
TELEPHONE (803)383-4524

AUGUST 1992

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	700	17	708
2	700	18	708
3	703	19	708
4	702	20	708
5	703	21	706
6	702	22	298
7	701	23	-12
8	701	24	-20
9	701	25	-17
10	701	26	-10
11	703	27	-10
12	705	28	-10
13	706	29	-4
14	708	30	-4
15	703	31	-4
16	606		

## UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 050-0261

UNIT NAME H. B. ROBINSON

DATE 09-03-92

REPORT MONTH AUGUST

COMPLETED BY J. W. GROOMS

TELEPHONE (803)383-4524

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>2</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
0801	081592	F		B	1	---	N/A	VALVE	CAUSE OF EVENT-RAMP DOWN FROM FULL POWER TO PERFORM MONTHLY TURBINE VALVE TEST, OST-551.
0802	081692	S		B	1	---	N/A	VALVE	CAUSE OF EVENT - RAMP UP TO FULL POWER AFTER COMPLETION OF MONTHLY TURBINE VALVE TEST, OST-551.
0803	082292	F	229.83	A	3	92-017	EA	TRANS	CAUSE OF EVENT: LOSS OF STARTUP TRANSFORMER CAUSED BY A SHORT CIRCUIT IN THE SUDDEN PRESSURE FAULT PROTECTIVE RELAY SENSING CIRCUITRY.  CORRECTIVE ACTION: INVESTIGATE PROBLEM WITH START-UP TRANSFORMER, MAKE NECESSARY REPAIRS, AND RETURN UNIT TO POWER OPERATION.  NOTE: ALL REPAIRS TO THE START-UP TRANSFORMER HAVE BEEN COMPLETED. THE UNIT REMAINS OFF LINE DUE TO A SEPARATE ISSUE REGARDING FOREIGN MATERIAL IN THE SAFETY INJECTION SYSTEM.
						92-018			

1

2

3

4

F: Forced  
S: Scheduled

Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Other (Explain)

Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets for Licensee  
Event Report (LER) File (NUREG-  
0161)

<sup>5</sup> Exhibit 1 - Same Source

(9/77)

92-2396