

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9307160292 DOC. DATE: 93/06/30 NOTARIZED: NO DOCKET #
FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
AUTH. NAME AUTHOR AFFILIATION
GROOMS, J. Carolina Power & Light Co.
FLANAGAN, W.J. Carolina Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1993 for HB Robinson Steam
Electric Plant, unit 2.W/930712 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-1 LA	3 3	PD2-1 PD	1 1
MOZAFARI, B	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DORS/OEAB	1 1	NRR/DRIL/RPEB	1 1
<u>REG FILE</u> 01	1 1	RGN2	1 1
EXTERNAL: EG&G BRYCE, J.H	1 1	NRC PDR	1 1
NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14



Carolina Power & Light Company

ROBINSON NUCLEAR PLANT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29551

JUL 12 1993

Robinson File: 15505

Serial: RNP/93-1621


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of June, 1993.

Very truly yours,


William J. Flanagan, Jr.
Acting Plant General Manager
H. B. Robinson S. E. Plant

SAB:lst

Enclosures

cc: Mr. S. D. Ebnetter
Mr. W. T. Orders

9307160292 930630
PDR ADOCK 05000261
R PDR

Handwritten signature/initials

CP&L CO
RUN DATE 07/07/93
RUN TIME 09:41:59

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE GROOMS
TELEPHONE (803)383-4524

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: JUNE 1993
3. LICENSED THERMAL POWER (MST): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: NONE

NOTES: There are 182 assemblies and one assembly with 100 Rods in the Spent Fuel Pool. There are 56 assemblies in the Dry Fuel Storage and 157 in the Reactor Vessel.

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): NONE
10. REASONS FOR RESTRICTION, IF ANY: NONE

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH): Refueling Outage is scheduled to start 9/11/93 with a duration of 53 days. Unit scheduled online 11/4/93.

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: None

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION: FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

CP&L CO
RUN DATE 07/07/93
RUN TIME 09:41:59

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE GROOMS
TELEPHONE (803)383-4524

JUNE 1993

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	479	17	703
2	705	18	704
3	707	19	703
4	709	20	703
5	708	21	703
6	707	22	701
7	708	23	699
8	710	24	700
9	707	25	699
10	705	26	700
11	703	27	699
12	702	28	698
13	701	29	700
14	702	30	698
15	702		
16	702		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JUNE

DOCKET NO. 050-0261
UNIT NAME H. B. Robinson
DATE 07/07/93
COMPLETED BY J. W. Grooms
TELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ²	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0601	060193	F	---	B	NA	---	SJ	VALVEX	Cause of Event - Rx power held at 60% for "C" Feed Reg Valve Problems.
0602	060193	S	---	B	NA	---	IM	INSTRU	Corrective Action - Repair air leak on valve positioner. Cause of Event - Ramp up to full power. NOTE: Event is a continuation of Event No. 0502 which resulted from reactor power reduction to 60% due to state thermal discharge limits for discharge canal. Reactor power was increased to 100% on 6/1/93 when NPDES temperature limit was increased.

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵ Exhibit 1 - Same Source