

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9311170222 DOC. DATE: 93/10/31 NOTARIZED: NO DOCKET #
FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
AUTH. NAME AUTHOR AFFILIATION
GROOMS, J. Carolina Power & Light Co.
PEARSON, M.P. Carolina Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Oct 1993 for HB Robinson Steam
Electric Plant, Unit 2.W/931111 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	3 3	PD2-1 PD	1 1
	MOZAFARI, B	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DORS/OEAB	1 1	NRR/DRIL/RPEB	1 1
	<u>REG FILE</u> 01	1 1	RGN2	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14



Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29550

November 11, 1993

Robinson File: 15505

Serial: RNP/93-2785


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of October, 1993.

Very truly yours,


Marc P. Pearson
Plant General Manager

SAB:lst
Enclosures
c: Mr. S. D. Ebnetter
Mr. W. T. Orders

9311170222 931031
PDR ADDCK 05000261
R PDR

Highway 151 and SC 23 Hartsville SC

JK24

CP&L CO
RUN DATE 11/02/93
RUN TIME 10:59:03

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE GROOMS
TELEPHONE (803)383-4524

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: OCTOBER 1993
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: NONE

NOTES: There are 238 assemblies and one assembly with 100 Rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): NONE
10. REASONS FOR RESTRICTION, IF ANY: NONE

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH): None
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: November 11, 1993
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION: FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

CP&L CO
RUN DATE 11/02/93
RUN TIME 10:59:03

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE GROOMS
TELEPHONE (803)383-4524

OCTOBER 1993

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-2	17	-3
2	-2	18	-2
3	-2	19	-3
4	-1	20	-2
5	0	21	-2
6	0	22	-2
7	-1	23	-2
8	-2	24	-2
9	-2	25	-4
10	-2	26	-2
11	-2	27	-2
12	-2	28	-2
13	-2	29	-2
14	-2	30	-4
15	-2	31	-7
16	-2		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH OCTOBER

DOCKET NO. 050-0261
UNIT NAME H. B. Robinson
DATE 11/02/93
COMPLETED BY J. W. Grooms
TELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ²	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0901*	100193	S	745	C	1	---	ZZ	ZZZZ	Continuation of Cycle #15 Refueling Outage. This outage will continue into November. * Continued from previous month.

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵ Exhibit 1 - Same Source