

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9402280227 DOC. DATE: 94/01/31 NOTARIZED: NO DOCKET #
FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
AUTH. NAME AUTHOR AFFILIATION
WOODS, J. Carolina Power & Light Co.
PEARSON, M.P. Carolina Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1994 for HB Robinson Unit 2.
W/940218 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFARI, B	1 1
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DORS/OEAB	1 1	NRR/DRIL/RPEB	1 1
	<u>REG FILE</u> 01	1 1	RGN2	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 11



Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29550

Robinson File: 15505
Serial: RNP/94-0304

FEB 18 1994

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of January, 1994.

Very truly yours,

Marc P. Pearson
Plant General Manager

SAB:lst
Enclosures
c: Mr. S. D. Ebnetter
Mr. W. T. Orders

9402280227 940131
PDR ADDCK 05000261
R 200074 PDR

Highway 151 and SC 23 Hartsville SC

CP&L CO.
RUN DATE 2/02/94
RUN TIME 09:00:21

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE WOODS
TELEPHONE (803)383-4524

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: JANUARY, 1994
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: NONE

NOTES: There are 238 assemblies and one assembly with 100 Rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): NONE
10. REASONS FOR RESTRICTION, IF ANY: NONE

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

CP&L CO
RUN DATE 02/02/94
RUN TIME 09:00:20

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE WOODS
TELEPHONE (803)383-4524

JANUARY 1994

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-4	17	-12
2	-4	18	-12
3	-4	19	-12
4	-4	20	-12
5	-4	21	-12
6	-4	22	-12
7	-3	23	-11
8	-4	24	-20
9	-6	25	-22
10	-9	26	-21
11	-9	27	-22
12	-9	28	-23
13	-9	29	-23
14	-10	30	-23
15	-10	31	-23
16	-11		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JANUARY

DOCKET NO. 050-0261
UNIT NAME H. B. Robinson
DATE 02/02/94
COMPLETED BY J. B. Woods
TELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ²	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0201*	020194	F	744	B,H	1		DB	FUELXX	* Continued from previous month. On November 18, 1993, the fuel vendor, Siemens, notified CP&L that 6 fuel assemblies had fuel rods misloaded. The unit proceeded to cold shutdown at 2235 November 18, 1993, for inspection and movement of the fuel.

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵ Exhibit 1 - Same Source