

PRIORITY 1

ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9407120369 DOC. DATE: ~~94/06/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 WOODS, J. Carolina Power & Light Co.
 KRICH, R.M. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for June 1994 for HB Robinson Steam
 Electric Plant Unit 1 (W/940707) ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFARI, B	1 1
INTERNAL:	AEOD/DSP/TPAB	1 1	NRR/DORS/OEAB	1 1
	NRR/DRIL/RPEB	1 1	<u>REG FILE</u> 01	1 1
	RGN2	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR



TS 6.9.1.4

Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29551

Robinson File: 15505
Serial: RNP/94-1337

JUL 07 1994


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specifications Section 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company submits the enclosed report of operation statistics and shutdown experience for the month of June, 1994.

Very truly yours,



R. M. Krich
Manager - Regulatory Affairs

SAB:dwm
Enclosures

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP

9407120369 940630
PDR ADDCK 05000261
R PDR

Highway 151 and SC 23 Hartsville SC

JE24

CP&L CO
RUN DATE 07/05/94
RUN TIME 07:32:50

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE WOODS
TELEPHONE (803)383-4524

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: JUNE, 1994
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: None

NOTES: There are 238 assemblies and one assembly with 100 Rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): None
10. REASONS FOR RESTRICTION, IF ANY: None

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH): None

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: None

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION: FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

Enclosure 2 to Serial: RNP/94-1337
Page 1 of 1

CP&L CO
RUN DATE 07/05/94
RUN TIME 07:32:50

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE WOODS
TELEPHONE (803)383-4524

JUNE 1994

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	704	17	695
2	705	18	694
3	702	19	693
4	693	20	692
5	661	21	691
6	702	22	690
7	703	23	691
8	701	24	693
9	699	25	694
10	700	26	695
11	698	27	697
12	696	28	698
13	697	29	700
14	699	30	700
15	699		
16	698		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JUNEDOCKET NO. 050-0261UNIT NAME H. B. RobinsonDATE 07/05/94COMPLETED BY J. B. WoodsTELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ²	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0601	060494	F	---	B	NA	---	TA	VALVEX	CAUSE OF EVENT: Ramp down from 100% to 70% Power for Monthly Turbine Valve Test, OST-551.
0602	060594	S	---	B	NA	---	TA	VALVEX	CAUSE OF EVENT: Ramp up from 70% to 100% after completion of Monthly Turbine Valve Test, OST-551.

1 F: Forced

S: Scheduled

2 Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3 Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

4 Exhibit G - Instructions

for Preparation of Data

Entry Sheets for Licensee

Event Report (LER) File (NUREG-

0161)

⁵ Exhibit 1 - Same Source

(9/77)

94-1337