

PRIORITY 1

ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9410180266 DOC. DATE: ~~94/09/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
 AUTH. NAME AUTHOR AFFILIATION
 WOODS, J. Carolina Power & Light Co.
 KRICH, R.M. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Sept 1994 for HB Robinson Steam
 Electric Plant unit 2. W/941010 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFART, B	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	NRR/DORS/OEAB	1 1	NRR/PMAS/IRCB-E	1 1
	RGN2	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

ml

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



TS 6.9.1.4

Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29551

Robinson File: 15505
Serial: RNP/94-1790

OCT 10 1994

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specifications Section 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power & Light Company submits the enclosed report of operation statistics and shutdown experience for the month of September, 1994.

Very truly yours,

R. M. Krich
Manager - Regulatory Affairs

SAB:bej

Enclosures

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP

180692

9410180266 940930
PDR ADOCK 05000261
R PDR

Highway 151 and SC 23 Hartsville SC

JE24

CP&L CO
RUN DATE 10/05/94
RUN TIME 11:20:50

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: SEPTEMBER 94
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: None
9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): N/A
10. REASONS FOR RESTRICTION, IF ANY: None

DOCKET NO. 050-0261
COMPLETED BY: JACKIE WOODS
TELEPHONE (803)383-4524

NOTES: There are 238 assemblies with 100 rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

CP&L CO
RUN DATE 10/05/94
RUN TIME 11:20:50

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: JACKIE WOODS
TELEPHONE (803)383-4524

SEPTEMBER 1994

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	674	17	702
2	662	18	703
3	700	19	705
4	703	20	706
5	704	21	707
6	704	22	709
7	704	23	710
8	701	24	711
9	703	25	711
10	702	26	711
11	700	27	712
12	701	28	710
13	701	29	707
14	702	30	704
15	701		
16	701		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH SEPTEMBER

DOCKET NO. 050-0261
UNIT NAME H. B. Robinson
DATE 10/05/94
COMPLETED BY J. B. Woods
TELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ²	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0901	090194	F	-----	B	1	-----	TA	VALVEX	CAUSE OF EVENT: Ramp down from 100 to 65% Power to perform OST-551, Monthly Turbine Valve Test.

1

2

3

4

F: Forced
S: Scheduled

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵ Exhibit 1 - Same Source

SUMMARY: The plant operated at 100% power during the month except for the power reduction on September 1, 1994, to perform the Monthly Turbine Valve Test.

(9/77)

94-1790