

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9506160557 DOC.DATE: ~~95/05/31~~ NOTARIZED: NO DOCKET #
FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
AUTH.NAME AUTHOR AFFILIATION
SCARBOROUGH,J. Carolina Power & Light Co.
KRICH,R.M. Carolina Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for May 1995 for HB Robinson Steam
Electric Plant,Unit 2 W/950608ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 4
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFARI, B	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DISP/PIPB	1 1	NRR/DOPS/OECB	1 1
	RGN2	1 1		
EXTERNAL:	LITCO BRYCE,J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



TS 6.9.1.4

Carolina Power & Light Company

Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File: 15505
Serial: RNP/95-0104

JUN 08 1995

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specifications (TS) Section 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power & Light Company submits the enclosed report of operation statistics and shutdown experience for the month of May 1995. Also in accordance with TS Section 6.9.1.4, this report is being submitted to the Nuclear Regulatory Commission by the tenth day of the month following the calendar month covered by the report.

If you have any questions regarding this report, please contact Mr. Albert Garrou at (803) 857-1544.

Very truly yours,

R. M. Krich
Manager - Regulatory Affairs

SAB:sb

Enclosures

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP

9506160557 950531
PDR ADOCK 05000261
R PDR

Highway 151 and SC 23 Hartsville SC

IE 24
11

CP&L CO -
RUN DATE 06/02/95
RUN TIME 07:46:06

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

DOCKET NO. 050-0261
COMPLETED BY: J. S. SCARBOROUGH
TELEPHONE (803)857-1000

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: MAY 1995
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: N/A
9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): N/A
10. REASONS FOR RESTRICTION, IF ANY: N/A

NOTES: There are 282 assemblies and 1 assembly with 100 rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

	THIS MONTH	YR TO DATE	CUMUL ATIVE
--	---------------	---------------	----------------

INITIAL CRITICALITY	----	----
INITIAL ELECTRICITY	----	----
COMMERCIAL OPERATION	----	----

Enclosure 2 to Serial: RNP/95-0104

Page 1 of 1. .

CP&L CO
RUN DATE 06/02/95
RUN TIME 07:46:06

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: J. S. SCARBOROUGH
TELEPHONE (803)857-1000

MAY 1995

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-6	17	-2
2	-3	18	0
3	-2	19	-2
4	-3	20	-3
5	-3	21	-3
6	-2	22	-3
7	-2	23	-3
8	-2	24	-3
9	-2	25	-3
10	-3	26	-3
11	-1	27	-3
12	-3	28	-5
13	-2	29	-6
14	-2	30	-6
15	-2	31	-5
16	-2		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH MAY

DOCKET NO. 050-0261
UNIT NAME H. B. Robinson
DATE 06/02/95
COMPLETED BY J. S. Scarborough
TELEPHONE (803) 857-1000

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0501*	05/01/95	S	744	C	1	-----	ZZ	ZZZZZZ	Continuation of Cycle 16 Refueling Outage. This outage continue into June 1995. *Continued from previous month.

1 F: Forced	2 Reason: A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)	3 Method: 1-Manual 2-Manual Scram. 3-Automatic Scram. 4-Other (Explain)	4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG- 0161)	5 Exhibit 1 - Same Source
----------------	--	--	---	------------------------------

SUMMARY: The unit remained in Refueling Outage #16 during the entire month of May 1995.