

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9602150025 DOC. DATE: ~~96/01/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co. 05000261
 AUTH. NAME AUTHOR AFFILIATION
 SCARBOROUGH, J. Carolina Power & Light Co.
 KRICH, R.M. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for HB Robinson Steam Electric Plant
 Unit 2 W/960207 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFARI, B	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER</u> 01	1 1
	NRR/DRPM/PECB	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

mk

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



Carolina Power & Light Company
Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File No: 15505
Serial: RNP-RA/96-0031

FEB 07 1996

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specifications (TS) Section 6.9.1.4 for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Carolina Power & Light (CP&L) Company submits the enclosed report of operations statistics and shutdown experience for the month of January 1996. Also, in accordance with TS Section 6.9.1.4, this report is being submitted to the NRC by the 10th day of the month following the calendar month covered by the report.

Questions regarding this matter may be referred to me at (803) 857-1802.

Very truly yours,

R. M. Krich
Manager - Regulatory Affairs

JSK/klb

Enclosures

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP

9602150025 960131
PDR ADOCK 05000261
R PDR

150013

IE 24
11

DOCKET NO. 050-0261

COMPLETED BY J. S. SCARBOROUGH

TELEPHONE (803)857-1447

OPERATING STATUS

1. UNIT NAME: H. B. ROBINSON STEAM ELECTRIC PLANT (HBRSEP),
UNIT NO. 2
2. REPORTING PERIOD: JANUARY 96
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT,
GIVE REASONS: N/A
9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): N/A
10. REASONS FOR RESTRICTION, IF ANY: N/A

NOTES: There are 282 assemblies and 1 assembly with 100 rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	744.00	744.00	218472.00
12. NUMBER OF HOURS REACTOR CRITICAL	744.00	744.00	155576.64
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	744.00	744.00	152420.33
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	1687182.48	1687182.48	313820539.44
17. GROSS ELEC. ENERGY GEN. (MWH)	562046.00	562046.00	101844703.00
18. NET ELEC. ENERGY GENERATED (MWH)	536246.00	536246.00	96267747.00
19. UNIT SERVICE FACTOR	100.00	100.00	69.77
20. UNIT AVAILABILITY FACTOR	100.00	100.00	69.78
21. UNIT CAP. FACTOR (USING MDC NET)	105.53	105.53	65.90
22. UNIT CAP. FACTOR (USING DER NET)	102.97	102.97	62.95
23. UNIT FORCED OUTAGE RATE	.00	.00	14.57
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH):	None		
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP:	N/A		
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	<u>FORECAST</u> <u>ACHIEVED</u>		
INITIAL CRITICALITY	-----	<u>9/20/70</u>	
INITIAL ELECTRICITY	-----	<u>9/70</u>	
COMMERCIAL OPERATION	-----	<u>3/7/71</u>	

CP&L CO
RUN DATE 02/02/96
RUN TIME 11:22:40

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PAGE 1
RPD39-000

DOCKET NO. 050-0261
COMPLETED BY: J. S. SCARBOROUGH
TELEPHONE (803)857-1447

JANUARY 1996

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	729	17	728
2	729	18	728
3	729	19	729
4	729	20	729
5	729	21	728
6	728	22	728
7	728	23	728
8	729	24	729
9	729	25	729
10	728	26	728
11	729	27	729
12	641	28	729
13	580	29	728
14	728	30	727
15	729	31	728
16	728		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JANUARY 1996

DOCKET NO. 050-0261
 UNIT NAME HBRSEP, UNIT NO. 2
 DATE 02/02/96
 COMPLETED BY J. S. Scarborough
 TELEPHONE (803) 857-1447

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions
 For Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File
 (NUREG-0161)

⁵ Exhibit 1 - Same Source

SUMMARY: The Unit operated at full power during the month of January, with the exception of power reduction on 1/12/96, to repair "A" condensate pump motor oil cooler. The motor lube oil cooler was replaced due to leaks.