

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9808140202      DOC.DATE: 98/07/31      NOTARIZED: NO      DOCKET #  
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C      05000261  
 AUTH.NAME      AUTHOR AFFILIATION  
 GARDNER,D.      Carolina Power & Light Co.  
 WILKERSON,T.M.      Carolina Power & Light Co.  
 RECIP.NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for July 1998 for HB Robinson Steam Electric Plant.W/980807 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED:LTR 1 ENCL 1      SIZE: H  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	SUBBARATNAM	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE,J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T

**Carolina Power & Light Company**

Robinson Nuclear Plant  
3581 West Entrance Road  
Hartsville SC 29550

Robinson File No: 15505

Serial: RNP-RA/98-0150

**AUG 7 1998**

United States Nuclear Regulatory Commission

Attn: Document Control Desk

Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-261/LICENSE NO. DPR-23

MONTHLY OPERATING REPORT

Sir or Madam:

In accordance with Technical Specifications (TS) Section 5.6.4 for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Carolina Power & Light (CP&L) Company submits the enclosed report of operations statistics and shutdown experience for the month of July 1998. In accordance with TS Section 5.6.4, this report is being submitted to the NRC by the 15th day of the month following the calendar month covered by the report.

If you have any questions concerning this matter, please contact Mr. H. K. Chernoff of my staff.

Very truly yours,

*Terry M. Wilkerson*

T. M. Wilkerson  
Manager - Regulatory Affairs

KLB/klb

Attachments

c: USNRC Resident Inspector, HBRSEP  
Mr. L. A. Reyes, USNRC, Region II  
Mr. R. Subbaratnam, USNRC

9808140202 980731  
PDR ADOCK 05000261  
R PDR

*IE2411*

CP&L CO  
 RUN DATE 08/03/98  
 RUN TIME 18:07:12

PLANT PERFORMANCE DATA SYSTEM  
 OPERATING DATA REPORT  
 H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PAGE 1 of 1  
 RPD36-000

DOCKET NO. 050-0261  
 COMPLETED BY DARRYL GARDNER  
 TELEPHONE (843)857-1144

## OPERATING STATUS

1. UNIT NAME: H. B. ROBINSON STEAM ELECTRIC PLANT (HBRSEP),  
UNIT NO. 2
2. REPORTING PERIOD: JULY 1998
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT,  
GIVE REASONS:
9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE):
10. REASONS FOR RESTRICTION, IF ANY:

NOTES:

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	744.00	5087.00	240359.00
12. NUMBER OF HOURS REACTOR CRITICAL	744.00	4147.85	175433.86
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	744.00	4118.73	172203.46
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	1679929.20	9307840.56	358711884.24
17. GROSS ELEC. ENERGY GEN. (MWH)	538710.00	3048691.00	116566867.00
18. NET ELEC. ENERGY GENERATED (MWH)	513164.00	2900401.00	110289591.00
19. UNIT SERVICE FACTOR	100.00	80.97	71.64
20. UNIT AVAILABILITY FACTOR	100.00	80.97	71.65
21. UNIT CAP. FACTOR (USING MDC NET)	100.99	83.48	68.49
22. UNIT CAP. FACTOR (USING DER NET)	98.53	81.45	65.55
23. UNIT FORCED OUTAGE RATE	.00	.92	13.18

24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH): N/A
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: N/A
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

9/20/70  
 9/70  
 3/7/71

CP&L CO  
RUN DATE 08/03/98  
RUN TIME 18:07:12

PLANT PERFORMANCE DATA SYSTEM  
APPENDIX B - AVERAGE DAILY POWER LEVEL  
H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PAGE 1 of 1  
RPD39-000

DOCKET NO. 050-0261  
COMPLETED BY: DARRYL GARDNER  
TELEPHONE (843)857-1144

JULY 1998

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	700	17	706
2	699	18	705
3	696	19	705
4	519	20	706
5	525	21	707
6	662	22	706
7	700	23	705
8	702	24	703
9	701	25	702
10	700	26	700
11	700	27	701
12	702	28	703
13	704	29	703
14	705	30	702
15	705	31	702
16	704		

## UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: JULY 1998

DOCKET NO. 050-0261  
 UNIT NAME HBRSEP, UNIT NO. 2  
 DATE 08/05/98  
 COMPLETED BY DARRYL GARDNER  
 TELEPHONE (843) 857-1144

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
98-004	980704	S	0	F	4	-	ZZ	ZZZZZZ	Administrative decision to reduce load to minimize heat input into lake; voluntary plant action to avoid reaching regulatory restriction. Unit load reduced to approximately 75% reactor power for 2 days.

1 F: Forced

S: Scheduled

2 Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training &amp; License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3 Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

4 Exhibit G - Instructions

For Preparation of Data

Entry Sheets for Licensee

Event Report (LER) File

(NUREG-0161)

<sup>5</sup> Exhibit 1 - Same Source

SUMMARY: The unit operated at near full power during the month, with the exception of the event described above.