


				GEN. SUPV.	INDEX			
					SHEET No.	LATEST REV.	DESCRIPTION	SCHEME No.
					16	11	AUXILIARY RELAY SCHEDULE	—
				ENGR. SUPV.	17	1	START-UP TRANSFORMERS X01 ANNUNCIATOR REFLASH.	Q980
					18	1	START-UP TRANSFORMERS X02 ANNUNCIATOR REFLASH.	Q983
				ENGR.	19A	2	MAIN TRANSFORMERS X1 ANNUNCIATION REFLASH.	Q691
					19B	7	MAIN TRANSFORMERS X1 ANNUNCIATION REFLASH.	Q691
				CH'K	19C	6	MAIN TRANSFORMERS X1 ANNUNCIATION REFLASH.	Q690
					20	5	AUXILIARY TRANSFORMERS X11 ANNUNCIATION REFLASH.	Q013
				BY	21	0	START-UP TRANSFORMERS X01 ANNUNCIATION REFLASH.	Q979
					22	0	START-UP TRANSFORMERS X02 ANNUNCIATION REFLASH.	Q982
				REVISIONS	23	4	AUXILIARY TRANSFORMERS X11 ANNUNCIATION REFLASH.	Q014
					24	2	MAIN TRANSFORMER LOW VOLTAGE MONITOR	X103
					25A	2	MAIN TRANSFORMER GAS-IN-OIL MONITOR	X103
					25B	1	TRANSFORMER GAS-IN-OIL MONITOR SWITCH	—
					26	0	AUXILIARY TRANSFORMER GAS-IN-OIL MONITOR	X1106
				FOR REVISION DESCRIPTION SEE INDEX SHT.1				
34	SEE INDEX SH.1 FOR REVISIONS			DATE				
33	SEE INDEX SH.1 FOR REVISIONS							
32	SEE INDEX SH.1 FOR REVISIONS							
31	SEE INDEX SH.1 FOR REVISIONS							
				NO.				

EQUIPMENT (LOCATION) DESIGNATION

- C3093E - TM8 SERVERON AUXILIARY TRANSFORMER MONITOR FOR GAS-IN-OIL
- C3093F - CONTROL CABINET FOR X11 TM8 POWER SUPPLY
- JT3040B - JUNCTION BOX FOR X11 TM8 WIRING
- PS3093E - HELIUM BOTTLE PRESSURE SWITCH FOR TM8 MONITOR AUXILIARY TRANSFORMER GAS-IN-OIL
- UE3093E - MOISTURE/TEMPERATURE ELEMENT FOR X11 TM8 MONITOR

FOR GENERAL NOTES SEE INDEX SH.1.

PREVIOUS REVISION FROM 1-13 DID NOT EXIST

SCALE NONE	DESIGNED	DRAWN DVK	DATE 5-16-89
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1 THE TOLEDO EDISON COMPANY			
ELEMENTARY WIRING DIAGRAMS GENERATOR AND TRANSFORMER PROTECTION TRIPPING AND LOCK-OUT RELAY CKTS			
	DRAWING NO.		REV.
	E-31B INDEX SHT. 2		34