



NUREG-0800

U.S. NUCLEAR REGULATORY COMMISSION STANDARD REVIEW PLAN

~~DRAFT~~ BRANCH TECHNICAL POSITION (BTP) 8-9

OPEN PHASE CONDITIONS IN ELECTRIC POWER SYSTEM

REVIEW RESPONSIBILITIES

Primary -- Organization responsible for electrical engineering

Secondary - None

A. BACKGROUND

~~On January 30, 2012, Byron Station~~ Byron Station is a two-unit pressurized water reactor plant. The electrical distribution system for each unit consists of four nonsafety 6.9-kilo Volt (kV) buses, two nonsafety 4-kV buses, and two engineered safety features (ESF) 4-kV station buses. Both the ESF 4-kV and the two nonsafety 6.9-kV station buses that power the two reactor coolant pumps (RCPs) are normally supplied by station auxiliary transformers (SATs) connected to the 345-kV offsite power switchyard. On January 30, 2012, Unit 2 experienced an automatic reactor trip from full power because the reactor protection scheme detected an undervoltage condition on the 6.9-kV buses that power ~~reactor coolant pumps (the RCPs)~~. The undervoltage condition was caused by a broken ~~inverted porcelain~~ insulator stack of the Phase C conductor for the 345-kV power circuit that supplies both ~~station auxiliary transformers (SATs)~~. The insulator

Revision 0 – July 2015

USNRC STANDARD REVIEW PLAN

This Standard Review Plan (SRP), NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission (NRC) staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC regulations. The SRP is not a substitute for the NRC regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The SRP sections are numbered in accordance with corresponding sections in Regulatory Guide (RG) 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of RG 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)." These documents are made available to the public as part of the NRC policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRO_SRP@nrc.gov.

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under ADAMS Accession No. ML15057A085.

Formatted: Font: Arial

Formatted: Widow/Orphan control, Keep with next

Formatted: Section start: New page, Header distance from edge: 1", Footer distance from edge: 1", Different first page header

Formatted: Font: Arial

Formatted: Centered, Indent: First line: 0.5", Widow/Orphan control, Keep with next, Tab stops: 0", Left + 0.5", Left + 1", Left + 1.5", Left + 2", Left + 2.5", Left + 3", Left + 3.5", Left + 4", Left + 4.5", Left + 5", Left + 5.5", Left

Formatted: Font: 11 pt

Formatted: Widow/Orphan control, Keep with next

Formatted: Font: Not Bold

Formatted: Line spacing: single, Widow/Orphan control, Keep with next

Formatted: Line spacing: single, Widow/Orphan control, Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Keep with next

failure resulted in a high impedance fault through the fallen Phase C conductor and a sustained open phase condition on the high voltage side of the SAT. The open circuit created an unbalanced voltage condition on the two 6.9-kV nonsafety-related RCP buses and the two 4.16-kV ~~engineered safety features (ESF)~~ buses. Some ESF loads ~~remained that were~~ energized ~~momentarily, relying~~ on equipment protective devices to prevent damage from an unbalanced overcurrent condition. The ~~overload phase overcurrent~~ condition ~~caused~~ actuated relays to trip several ESF loads ~~to trip~~.

Approximately 8 minutes after the reactor trip, the control room operators diagnosed the loss of Phase C condition and manually tripped ~~circuit~~ breakers to separate the unit buses from the offsite power source. When the operators opened the SAT feeder breakers to the two 4.16-kV ESF buses, the loss of ~~ESF bus voltage~~ ~~resulted in relays started~~ the emergency diesel generators (EDGs) ~~automatically starting and restoring~~ restored power to the ESF buses. ~~In the event that the operators failed to diagnose the condition in a timely manner, a potential had been allowed to persist for an additional few minutes, damage to the RCP seals could have occurred due to loss of RCP seal cooling water may. This in turn could have resulted in a loss-of-coolant event within a few more minutes from the RCP seals in the containment building.~~

A second event also occurred at Byron Station Unit 1 on February 28, 2012. This event was also initiated by a failed inverted porcelain insulator ~~which that~~ resulted in an open phase as well as a phase ~~to ground~~ fault on the line side of the circuit. In this event, the fault current was high enough to actuate protective relaying on the 345-kV system. The 4.16-kV ESF buses experienced ~~an undervoltage condition~~ a loss of voltage due to the opening of 345-kV system breakers, which resulted in separation of the SATs from the 4.16-kV buses. The ~~4A and 4B~~ two EDGs started and energized the 4.16-kV ESF buses as designed.

~~Past~~ A review of other operating experience ~~has~~ identified design vulnerabilities associated with single-phase open circuit conditions at South Texas, Unit 2; (See Licensee Event Report (LER) 50-499/2001-001, Agencywide Documents Access and Management System (ADAMS) Accession No. ML011010017); Beaver Valley Power Station, Unit 1; (See LER 50-334/2007-002, ADAMS Accession No. ML080280592); and a single event that affected Nine Mile Point, Unit 1 (See LER 50-220/2005-04, ADAMS Accession No. ML060620519) and the neighboring James A. Fitzpatrick ~~Nuclear~~ Power Plant; ~~and Nine Mile Point, Unit 1.~~ (See LER 50-333/2005-06, ADAMS Accession No. ML060610079)

These events involved offsite power circuits that were rendered inoperable ~~by~~ due to an open ~~circuit~~ circuit in one phase. In each instance (except South Texas, Unit 2), the condition went undetected for several weeks because offsite power was not aligned to the ESF buses during normal operation and the surveillance procedures, which recorded phase-to-phase voltage, did not identify the loss of the single phase. At South Texas, Unit 2, offsite power was normally aligned to ESF and nonsafety plant buses and the reactor was manually tripped by the operator when ~~circulation water pump was the three~~ Circulating Water Pumps were tripped by the open phase condition. ~~Recently, two related~~ Operating experience has identified three similar international events ~~occurred. First, the:~~

BTP8-9-2

Draft Revision 0 – July 2015

BTP 8-9-1

Draft Revision 0 – May 2014
Revision 0 – June 2015

Formatted: Widow/Orphan control, Keep with next

1. On December 22, 2012, Unit 1 at Bruce Power Plant in Canada identified that the protective relaying scheme is vulnerable to open phase, or was in shutdown condition when a maintenance cooling system pump (P1) tripped. Operators tried to manually start pumps P1 and P2 but both failed to start due to the electrical protection schemes. Field operators identified a loss-of-phase event based on an event that occurred on December 22, 2012, where condition caused by a break in one of the 3- phases of the 230 kV overhead line connections was broken. Second, the connection.
2. On May 30, 2013, Forsmark, Unit 3 in Sweden reported that protective relaying scheme is vulnerable to open phase events based on an event that occurred on May 30, 2013 (an event resulting from human error. The plant was in a refueling outage with one of the two 400-kV offsite power circuit breakers and a 70-kV back-up power supply breaker to the 400 kV grid was disconnected in two phases, when open due to maintenance work. While testing the protective relaying for the main generator, an erroneous trip signal was sent to the remaining 400-kV offsite power source to circuit breaker. One of the three phases in the circuit breaker failed to open, resulting in a double open phase condition in the power circuit (i.e., two open phases). Some of the operating loads tripped due to phase unbalance, while some safety-related and nonsafety-related loads overheated and failed. The undervoltage relays on the safety buses were in the process of realigning to an alternate 70 kV source). did not detect the degraded voltage conditions because the induced voltage was higher than the trip setpoint of the relays.
3. On April 27, 2014, the Dungeness B power plant in United Kingdom experienced random tripping of large loads resulting from the loss of one of three phases in the 400kV electrical supply to the site. The open phase condition was the result of inadequate contact in one pole of the circuit breaker.

In both events, EDG the events discussed above, the protective relaying schemes did not detect the open phase(s) conditions due to inadequate detection schemes. As a result, degraded power sources continued to supply plant safety-related and nonsafety-related loads. In addition, the emergency diesel generators (onsite power system) did not automatically connect to the safety buses because the plant design did not have features to address detect and automatically isolate the open phase conditions in the offsite power source.

Based on the Byron Station operating event, the staff issued U.S. Nuclear Regulatory Commission (NRC), Information Notice 2012-03, "Design Vulnerability in Electric Power System," dated March 1, 2012 (~~Agencywide Documents Access and Management System (ADAMS)~~ Accession No. ML120480170). On July 27, 2012, the staff issued NRC Bulletin 2012-01, "Design Vulnerability in Electric Power System," (Accession No. ML12074A115) to confirm that licensees comply with Title 10 of the Code of Federal Regulations (10 CFR) 50.55a(h)(2), 10 CFR 50.55a(h)(3), and Appendix A to 10 CFR Part 50, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," General Design Criterion (GDC) 17, "Electric Power Systems," or principal design criteria specified in the updated final safety analysis report. Specifically, the NRC requested licensees to provide information by October 25, 2012, (1) regarding (1) the protection scheme to detect and automatically respond to a single phase open circuit condition or high

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Widow/Orphan control, Keep with next

Formatted

BTP8-9-3

Draft Revision 0 – July 2015

BTP 8-9-1

Draft Revision 0 – May 2014
Revision 0 – June 2015

impedance ground fault condition on GDC 17 power circuits, and (2) the operating configuration of engineered safety features buses at power. The Electrical Engineering Branch staff has reviewed the information that NRC licensees provided and the ~~detail~~ details of this review are documented in a NRC Bulletin 2012-01, "Design Vulnerability in Electric Power System," Summary Report dated February 26, 2013 (ADAMS Accession No. ML13052A711).

~~Safety Significance of open phase condition: At Byron, both offsite and onsite electric power systems were not able to perform their intended safety functions due to the design vulnerability. Manual actions were necessary to restore ESF safety functions. A design basis event concurrent with this open phase condition could have resulted in the plant exceeding the guidance contained in 10 CFR 50.46, "Acceptance Criteria for Emergency Core Cooling Systems for Light Water Nuclear Power Reactors." The accident sequence precursor analyses conducted by the staff calculated a conditional core damage probability of 1×10^{-4} .~~

The purpose of this BTP is to provide guidance to the staff in reviewing various licensing actions related to electric power system design vulnerability due to open phase conditions in offsite electric power ~~systems~~ systems in accordance with Appendix A to 10 CFR Part 50, GDC 17 or principal design criteria specified in the updated final safety analysis report, and 10 CFR 50.36(e)(5)(a)(h)(2) and (e)(3), 10 CFR 50.55a(h)(3), and 10 CFR 50.36(c)(2) and 10 CFR 50.36(c)(3).

B. BRANCH TECHNICAL POSITION

~~The design of the electrical system should address the following open phase conditions:~~

1. Electric power from the transmission network to the onsite electric distribution system is supplied by two physically independent circuits. The design of the electrical system and the protective relaying system should address ~~less~~ the following open phase conditions (OPCs):
 - (i) ~~Loss~~ of one of the three phases of the independent circuits on the high voltage side of a transformer connecting an offsite power circuit to the transmission system ~~under~~. The protection scheme should consider all operating electrical system configurations and loading conditions:
 - a. ~~with~~ a high impedance ground fault condition; and
 - ~~b.~~ b. without a high impedance ground fault condition; and
 - (ii) ~~loss~~ Loss of two of the three phases of the ~~either~~ offsite power circuit (without ground) on the high voltage side of a transformer connecting an offsite power circuit to the transmission system under all operating electrical system configurations and loading conditions.

1. Nuclear Power Plants with Active Safety Features

BTP8-9-4

Draft Revision 0 – July 2015

BTP 8-9-1

Draft Revision 0 – May 2014
Revision 0 – June 2015

Formatted: Indent: First line: 0", Widow/Orphan control, Keep with next

Formatted: Widow/Orphan control, Keep with next

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Numbered + Level: 1 + Numbering Style: i, ii, iii, ... + Start at: 1 + Alignment: Left + Aligned at: 0.5" + Indent at: 1", Keep with next, Tab stops: Not at 1.5"

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Indent: Left: 0.5", Hanging: 0.5", Widow/Orphan control, Keep with next, Tab stops: Not at 1.5"

Formatted: Font color: Auto

Formatted: Font: 11 pt

Formatted: Line spacing: single, Tab stops: Not at 1.5"

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font: 11 pt, Italic, No underline

Formatted: Indent: Left: 0.5", Hanging: 0.5", Widow/Orphan control, Tab stops: Not at 1.5"

For performing licensing reviews for Notes:

- i. The staff should ensure that licensees have considered all potential OPCs on the high voltage and low voltage side of transformers and interconnecting onsite auxiliary power circuits. Any connections that are not evaluated should be documented with an adequate justification. If there is a potential for OPCs in the intervening power path, the licensee should have analyses to show that the above open phase conditions are the limiting conditions.
- ii. For AP 1000 plants, electric power from the transmission network to the onsite electric distribution system is supplied by only one circuit.
- iii. For the purpose of OPC evaluation, high impedance ground faults are ground faults that produce fault currents below the ground fault relay setting.

2. For operating reactors and new reactors with active design safety features, plant designs reviewed under 10 CFR Part 50 and 10 CFR Part 52, "Licenses, Certifications, and Approvals for Nuclear Power Plants," the following criteria should be satisfied when evaluating OPCs:

1. ~~Detection and Alarms~~

~~An open phase condition~~ The OPC should be automatically detected and alarmed in the main control room unless it can be shown that the open phase condition does not prevent functioning of important to safety SSCs.

- a. ~~Detection circuits for the open phase condition, which prevents the functioning of important to safety SSCs, should be sensitive enough to identify an open phase condition under all operating electrical system configurations and plant loading conditions. The detection circuits should be sensitive enough to identify OPCs under all operating electrical system configurations and plant loading conditions for which they the offsite power supplies are required to be operable in accordance with plant technical specifications (TSs) for safe shutdown.~~

The detection circuit should minimize spurious indications for an operable offsite power source in the range of voltage perturbations such as switching surges, transformer inrush currents, load or generation variations, lightning strikes, etc., normally expected in the transmission system. If the plant auxiliaries are supplied from the main generator and the offsite power circuit to the ESF bus is configured as a standby power source, then any failure (i.e., OPC) should be alarmed in the main control room for operators to take corrective action within a reasonable time. In such cases, the consequences of not immediately isolating the degraded power source should be evaluated to demonstrate that any subsequent design bases conditions that rely on offsite power circuit (s) for safe

Formatted: Font color: Auto

Formatted: List Paragraph, Indent: Left: 0", Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 2 + Alignment: Right + Aligned at: 0.5" + Indent at: 0.75", Keep with next

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font: Not Italic, No underline

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 1.25" + Indent at: 1.5", Keep with next, Tab stops: 0.5", Left + 1", Left + 1.5", Left

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

shutdown do not create plant transients or abnormal operating conditions. Also, the remaining power source (s) can be connected to the ESF buses within the time assumed in the accident analysis.

- b. If offsite power circuit(s) is (are) functionally degraded due to OPCs, and safe shutdown capability is not assured, then the ESF buses should be designed to be transferred automatically to the alternate reliable offsite power source or onsite standby power system within the time assumed in the accident analysis and without actuating any protective devices, given a concurrent design basis event.

The II. Actuation circuits

- c. ~~The design of actuation circuit~~ design of protection features for OPCs should address the following:
 - (i) Power quality issues caused by OPCs such as unbalanced voltages and currents, sequence voltages and currents, phase angle shifts, and harmonic distortion that could affect redundant ESF buses. The ESF loads should not be subjected to power quality conditions specified in industry standards such as Institute of Electrical and Electronic Engineers (IEEE) Standard (Std) 308-2001, "Criteria for Class 1E Power Systems for Nuclear Power Generating Stations," Section 4.5, "Power Quality," with respect to the design and operation of electrical systems as indicated in Regulatory Guide (RG) 1.32 "Criteria for Power Systems for Nuclear Plants."
 - (ii) Protection scheme should comply with applicable requirements including single failure criteria for ESF systems as specified in 10 CFR Part 50, Appendix A, GDC17, and 10 CFR 50.55a(h)(2) or 10 CFR 50.55a(h)(3), which require compliance with IEEE Std 279-1971 "Criteria for Protection Systems for Nuclear Power Generating Stations" or IEEE Std 603-1991, "Standard Criteria for Safety Systems for Nuclear Power Generating Stations." RG 1.153, "Criteria for Power, Instrumentation, and Control Portions of Safety Systems," provides additional guidance on this topic.

If protective features are provided in a non-Class 1E system only, a failure of the non-Class 1E scheme should not preclude the onsite electrical power system from performing its safety function given a single failure in the onsite power system.

- (iii) Protection scheme design should minimize misoperation, maloperation, and spurious actuation of an operable off-site power source ~~by providing independent dual sensors and coincidence logics.~~ Additionally, the protective scheme should not separate the operable off-site power source

Formatted: Normal, Keep with next, Tab stops: 0.5", Left + 1.25", Left + 1.5", Left

Formatted: Indent: Left: 1", Hanging: 0.5", Widow/Orphan control, Keep with next

in the range of voltage perturbations such as switching surges, load or generation variations etc., normally expected in the transmission system.—

~~Licensees/applicants should perform failure modes analysis to demonstrate that the additional actuation circuit design does not result in lower overall plant operation reliability. These devices must be coordinated with other protective devices in both the transmission system and the plant's electrical system (e.g., fault protection, overcurrent, etc.).~~

~~III. Circuit Classification~~

~~Class 1E detection and actuation circuits at the ESF bus level meet the applicable requirements of GDC 17. A non-Class 1E detection and actuation circuit at the non-Class 1E level may be acceptable if the following is satisfied:—~~

~~A detection/protection scheme providing equivalent function at the high voltage circuit (non-Class 1E) is acceptable to the NRC if the licensee can demonstrate compliance with NRC regulations in 10 CFR 50.55a (h)(2) or 10 CFR 50.55a(h)(3), "Protection Systems," otherwise, an alternative to the requirements of 10 CFR 50.55a (h)(2) or 10 CFR 50.55a(h)(3) should be submitted and authorized prior to implementation in accordance with 10 CFR 50.55a(a)(3) or an exemption to these requirements in accordance with 10 CFR 50.12, "Specific exemptions," must be processed.—~~

~~IV. Updated Final Safety Analysis Report~~

~~The Updated Final Safety Analysis Report (UFSAR) should be updated to discuss the design features and analyses related to the effects of, and protection for, any open phase condition design vulnerability. This update would typically be to Chapter 8 of the UFSAR and completed in conjunction with the 10 CFR 50.71(e) requirements.~~

~~V. Protective Actions~~

- ~~(iv) The unbalanced voltage/current conditions for ESF components expected during various operating and loading conditions should not exceed motor manufacturer's recommendations. The International Electrotechnical Commission (IEC) Standard IEC 60034-26, National Electrical Manufacturers Association (NEMA) Standard (MG 1) Parts 14.36 and 20.24, and IEEE Std C37.96-2012 (Guide for AC Motor Protection), Section 5.7.2.6, "Unbalanced Protection and Phase Failures," may be used for general guidance.~~

~~Technical Specification Surveillance Requirements and Limiting Conditions of Operation for equipment used for mitigation of OPCs should be identified and implemented consistent with the operability requirements specified in the plant TSs and in accordance with 10 CFR 50.36(c)(2) and 10 CFR 50.36 (c)(3). RG 1.93 "Availability of Electric Power Sources," provides additional guidance on this topic.~~

~~BTP8-9-7~~

~~Draft Revision 0 – July 2015~~

~~BTP 8-9-1~~

~~Draft Revision 0 – May 2014
Revision 0 – June 2015~~

3. ~~For an open phase condition, the staff finds the following method for meeting the design requirements acceptable:~~

~~(1) With no accident condition signal present, the licensee/applicant should demonstrate that:~~

- ~~a. The condition does not adversely affect the function of important to safety structures, systems and components; and~~
- ~~b. Abnormal operating occurrence, transients, events, and accidents (e.g., RCP seal failure) would not be created as a result of the condition;~~
- ~~c. Important to safety equipment is neither prevented from operating because protective devices are actuated nor damaged by the condition; and~~
- ~~d. Safe Shutdown capability is not compromised for all operating and anticipated operational occurrences.~~

~~(2) With an accident condition signal present, the licensee/applicant should demonstrate that:~~

- ~~a. Automatic detection and actuation will transfer loads required to mitigate postulated accidents to an alternate source and ensure that safety functions are preserved, as required by the current licensing bases.~~
- ~~b. Alternatively, a licensee/applicant may demonstrate by analytical analyses and actual testing that all design basis accident acceptance criteria and GDC17 or equivalent criterion are met with the open phase condition, given other plant design features. The analyses should include all design and licensing basis assumptions including single failure criterion.~~

~~(3) Following protection system requirements should be met for the open phase condition:~~

~~The voltage or current sensors should be designed to satisfy the following applicable requirements 10 CFR 50.55a(h)(2) or (h)(3) derived from IEEE Std. 279 and/or IEEE Std. 603, as endorsed by RG 1.153:~~

- ~~i. Class 1E equipment should be used and should be physically located at and electrically connected to the Class 1E switchgear.~~
- ~~ii. An independent scheme should be provided for each division of the Class 1E power system.~~
- ~~iii. The open phase protection should include coincidence logic on a per bus basis to preclude spurious trips of the offsite power source.~~

- iv. ~~The open phase protective devices should automatically initiate the disconnection of offsite power sources whenever the setpoints and time delay limits have been exceeded.~~
- v. ~~Capability for test and calibration during power operation should be provided.~~
- vi. ~~Annunciation must be provided in the control room for any bypasses incorporated in the design.~~

~~If the non Class 1E open phase circuit protection schemes are installed on the offsite power system, the following equivalent protection system requirements specified in 10 CFR 50.55a (h)(2) or 10 CFR 50.55a(h)(3) should be met as a minimum:~~

~~Justifications for complying with NRC regulations 10 CFR 50.55a (h)(2) or 10 CFR 50.55a(h)(3), "Protection Systems," should be provided. Otherwise, an alternative to the requirements of 10 CFR 50.55a (h)(2) or 10 CFR 50.55a(h)(3) must be submitted and authorized prior to implementation in accordance with 10 CFR 50.55a(a)(3) or an exemption to these requirements in accordance with 10 CFR 50.12, "Specific exemptions," must be processed.~~

- i. ~~Non-Class 1E equipment should satisfy separation requirements if interface with safety busses is required.~~
- ii. ~~An independent dual detection scheme should be provided at the non-Class 1E level for each circuit that feeds the division of the Class 1E power system.~~
- new
- iii. ~~The open phase protection should include coincidence logic on a per-train/per phase basis to preclude spurious trips of the offsite power source.~~
- iv. ~~The open phase protective devices should automatically disconnect the offsite power sources when the setpoints and any time delay limits have been satisfied.~~
- v. ~~Capability for test and calibration during power operation should be provided.~~
- vi. ~~Annunciation must be provided in the control room for any bypasses incorporated in the design.~~

~~VI. Surveillances and Limiting Conditions for Operation~~

~~The technical specifications should include requirements in accordance with 10 CFR 50.36(c)(2) and (c)(3) for limiting conditions for operations, surveillance~~

BTP8-9-9

Draft Revision 0 – July 2015

BTP-8-9-1

Draft Revision 0 – May 2014
Revision 0 – June 2015

Formatted: Normal, Keep with next, Tab stops: 0.5", Left + 1.25", Left + 1.5", Left

Formatted: Font color: Auto

requirements, trip setpoints, alarm set points, and maximum and minimum allowable values for the open phase conditions relays and associated time delay devices.

2. Nuclear Power Plants with Passive Safety Features

New reactor licensees, COL applicants, and design centers applications for certification of designs incorporating passive safety features plant designs reviewed under 10 CFR Part 52 should address, the following design criteria: should be satisfied when evaluating OPCs:

Formatted: Indent: Hanging: 0.5", Widow/Orphan control, Keep with next, Tab stops: Not at 0.19" + 0.25" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: No underline

I. Detection and Alarms

If the open phase condition prevents important to safety functions:

An open phase conditiona. The OPC should be automatically detected and alarmed in the main control room unless it can be shown that the open phase condition does not prevent functioning of important to safety SSCs.

Detection under all operating electrical system configurations and plant loading conditions. The detection circuits for the open phase condition, which prevents the functioning of important to safety SSCs, should be sensitive enough to identify an open phase condition OPCs under all operating electrical system configurations and plant loading conditions for which they are required to be operable.

II. Actuation circuits

If open phase condition actuation circuits are required, the design should minimize misoperation, maloperation, and spurious actuation by providing independent dual sensors and actuation logics that could cause separation from an operable off site offsite power source. Additionally, the protective scheme should not separate the operable off site offsite source in the range of voltage unbalance is normally expected in the transmission system. Licensees/applicants should perform failure modes analysis to demonstrate that the additional actuation circuit design does not result in lower overall plan operation reliability. These devices should be coordinated with other protective devices in both the transmission system and the plant's electrical system (e.g., fault protection, overcurrent, etc.) required in accordance with Appendix A to 10 CFR Part 50, GDC 17.

Formatted: Indent: Left: 1", Hanging: 0.5", Widow/Orphan control, Keep with next, Tab stops: Not at 0.25" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

III. Restoration of preferred or Onsite AC Power

Formatted: Font: Not Italic, No underline

- b. Following detection of an open phase condition and alarm in the control room, plant procedures should specify operator actions to ensure the standby diesel generators are connected to the auxiliary alternating current buses if they are not automatically connected in accordance with

Formatted: Indent: Left: 1", Hanging: 0.5", Widow/Orphan control, Keep with next, Tab stops: Not at 0.25" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

the design basis requirements or restore the offsite power source to a functional condition.—

C. _____

IV. Surveillances

Periodic surveillance tests, calibrations, setpoint verifications or inspections (as applicable) should be established for any new detection and alarm circuits to ensure their reliability to perform their intended design functions.

Formatted: Indent: Left: 1", Hanging: 0.5", Widow/Orphan control, Keep with next, Tab stops: 0.5", Left + Not at 0.25" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

3. Considerations for Protective Devices for Alarm and Trip Functions

The following guidelines provide an overview of the analyses that should be performed:

- a. ~~Commercially available software packages that have been adequately verified and validated for safety related applications may be used to analyze and model open phase and unbalanced fault conditions. The software should have capabilities to perform the unbalance load flow study for a steady state solution with opening a single phase at a time. For transformers, the effects of an embedded winding, no load current and losses, transformer type (core and shell), and inter phase A, B, C mutual coupling, including zero sequence shall be included.~~
- b. ~~Establish the capability of the major important to safety components to withstand unbalanced voltage/current conditions expected during various operating and loading conditions. The manufacturer provided parameters maybe acceptable if specified during the procurement process. Industry standards such as NEMA MG 1 2011 (Motors and Generators), Section 20.24, titled, "Effects of Unbalanced Voltages on the Performance of Polyphase Squirrel Cage Induction Motors", and IEEE Std. C37.96 2012 (Guide for AC Motor Protection), Section 5.7.2.6, "Unbalanced protection and phase failures" may be used for general guidance.~~
- c. ~~Establish the limitations of existing protective devices for various operating and loading conditions with open phase conditions on each phase.~~
- d. ~~The magnitude of expected unbalance voltage and current for different open phase or high impedance fault currents may dictate the operating characteristics of proposed protective devices. As an example, a protective device with two settings may be used for (a) alarm only when a low unbalanced voltage/current is detected, (b) trip when higher unbalanced voltage/current that is deemed unacceptable for plant equipment is detected. A time delay may be incorporated in both settings to avoid actuations during transient conditions. Any time delay provided must always meet the accident analysis assumptions.~~

Formatted: Indent: First line: 0", Widow/Orphan control, Keep with next, Tab stops: Not at 0.94" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

C. REFERENCES

BTP8-9-11	Draft Revision 0 – July 2015
BTP 8-9-1	Draft Revision 0 – May 2014
	Revision 0 – June 2015

Formatted: Indent: First line: 0", Widow/Orphan control, Keep with next, Tab stops: 0.5", Left + Not at 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

1. ~~RG 1.153, "Criteria for Power, Instrumentation, and Control Portions of Safety Systems."~~
4. ~~2. NRC Information Notice 2012-03, "Design Vulnerability in Electric Power System," dated March 1, 2012, ADAMS Accession No. Institute of Electrical and Electronics Engineers, ML120480170.~~
2. ~~3. NRC Bulletin 2012-01, "Design Vulnerability in Electric Power System," dated July 27, 2012, ADAMS Accession No. ML12074A115.~~
3. ~~4. Institute of Electrical and Electronics Engineers, IEEE Std. 279-1971, "Criteria for Protection Systems for Nuclear Power Stations."~~
4. ~~5. Institute of Electrical and Electronics Engineers, IEEE Std. 603-1991, "Criteria for Safety Systems for Nuclear Power Generating Stations."~~
5. ~~U. S. Nuclear Regulatory Commission, ML13052A711.~~
6. ~~8. U. S. Nuclear Regulatory Commission, Industry Initiative on Open Phase Condition - Functioning of Important-to-Safety Structures, Systems and Components," ADAMS Accession No. ML13333A142.~~
7. ~~9. SECY-13-0107, U. S. Nuclear Regulatory Commission, Licensee Event Report, Byron Station, Unit 1 and Unit 2, ADAMS Accession No. ML12272A358.~~
8. ~~U. S. Nuclear Regulatory Commission, "Design Vulnerability in Electric Power System," Information Notice 2012-03, dated March 1, 2012, ADAMS Accession No. ML120480170.~~
9. ~~U. S. Nuclear Regulatory Commission, "Design Vulnerability in Electric Power System," NRC Bulletin 2012-01, dated July 27, 2012, ADAMS Accession No. ML12074A115.~~
10. ~~U. S. Nuclear Regulatory Commission, "Design Vulnerability in Electric Power System," Summary Report, NRC Bulletin 2012-01, dated February 26, 2013, ADAMS Accession No. ML13052A711.~~
11. ~~U. S. Nuclear Regulatory Commission, NRC letter dated November 25, 2014, from William Dean, Office of Nuclear Reactor Regulation to Anthony Pietrangelo, Nuclear Energy Institute, ADAMS Accession No. ML14120A203.~~
12. ~~U. S. Nuclear Regulatory Commission, "Criteria for Power, Instrumentation, and Control Portions of Safety Systems," Regulatory Guide 1.153.~~
13. ~~U. S. Nuclear Regulatory Commission, "Criteria For Power Systems For Nuclear Plants." Regulatory Guide 1.32.~~

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5", Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Font color: Red, Strikethrough

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5", Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5", Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Font color: Auto

Formatted: Font color: Auto

Formatted: Font color: Auto

14. U. S. Nuclear Regulatory Commission, "Availability of Electric Power Sources." Regulatory Guide 1.93.
15. U. S. Nuclear Regulatory Commission, "Status of the Accident Sequence Precursor Program and the Standardized Plant Analysis Risk Models," **SECY-13-0107**, dated October 4, 2013, ADAMS Accession No. ML13232A062.
16. U. S. Nuclear Regulatory Commission, "Open Phase Conditions in Electric Power System," Staff's Response to ACRS letter dated December 17, 2014, regarding BTP 8-9, ADAMS Accession No. ML14364A348.
17. U. S. Nuclear Regulatory Commission, "Open Phase Conditions in Electric Power System," Advisory Committee on Reactor Safeguards (ACRS) letter dated December 17, 2014, regarding the ACRS review of BTP 8-9, ADAMS Accession No. ML14343A485.

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5", Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Font color: Auto

Formatted: Font color: Auto

BTP8-9-13

~~Draft~~ Revision 0 – July 2015

~~BTP 8-9-1~~

~~Draft~~ Revision 0 – May 2014

~~Revision 0 – June 2015~~

Formatted: Keep with next, Don't adjust space between Latin and Asian text, Don't adjust space between Asian text and numbers

Formatted: Widow/Orphan control, Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

PAPERWORK REDUCTION ACT STATEMENT

Formatted: Font: 11 pt, Bold

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50, and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval numbers 3150-0011, 3150-0151.

Formatted: Line spacing: single, Widow/Orphan control, Keep with next

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

Formatted: Line spacing: single, Widow/Orphan control, Keep with next, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Font: 11 pt

BTP8-9-14

~~Draft~~ Revision 0 – July 2015

~~BTP 8-9-1~~

~~Draft~~ Revision 0 – May 2014
Revision 0 – June 2015