



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

April 20, 2015

LICENSEE: Entergy Operations, Inc.

FACILITY: Grand Gulf Nuclear Station, Unit 1

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MARCH 19, 2015, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY OPERATIONS, INC., CONCERNING RAI SET 52 FOR THE GRAND GULF NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION (TAC NO. ME7493)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Operations, Inc., (Entergy or the applicant) held a telephone conference call on March 19, 2015, to discuss Request for Additional Information (RAI) Set 52, pertaining to the Grand Gulf Nuclear Station, Unit 1, license renewal application (LRA). The telephone conference call was useful in discussing the issues surrounding the RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a summary of the discussion.

The applicant had an opportunity to comment on this summary.

/RA/

John Daily, Senior Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosures:

1. List of Participants
2. Discussion summary

cc w/encls: Listserv

April 20, 2015

LICENSEE: Entergy Operations, Inc.

FACILITY: Grand Gulf Nuclear Station, Unit 1

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MARCH 19, 2015, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY OPERATIONS, INC., CONCERNING RAI SET 52 FOR THE GRAND GULF NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION (TAC NO. ME7493)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Operations, Inc., (Entergy or the applicant) held a telephone conference call on March 19, 2015, to discuss Request for Additional Information (RAI) Set 52, pertaining to the Grand Gulf Nuclear Station, Unit 1, license renewal application (LRA). The telephone conference call was useful in discussing the issues surrounding the RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a summary of the discussion.

The applicant had an opportunity to comment on this summary.

/RA/

John Daily, Senior Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosures:

1. List of Participants
2. Discussion summary

cc w/encls: Listserv

DISTRIBUTION: See next page

ADAMS Accession No.: ML15092A250

* via e-mail

OFFICE	LA:RPB1:DLR	PM:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	YEdmonds*	JDaily	YDiazSanabria	JDaily
DATE	4/16/15	4/16/15	4/16/15	4/20/15

OFFICIAL RECORD COPY

TELEPHONE CONFERENCE CALL
GRAND GULF NUCLEAR STATION, UNIT 1
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS
March 19, 2015

<u>PARTICIPANTS</u>	<u>AFFILIATIONS</u>
John Daily	Nuclear Regulatory Commission (NRC)
Bill Holston	NRC
Catherine Nolan	NRC
Dave Lach	Entergy Operations, Inc., (Entergy)
Andrew Taylor	Entergy
Alan Cox	Entergy
Keith Brinson	Entergy
David Wootten	Entergy

SUMMARY OF TELEPHONE CONFERENCE CALL
FOR RAI SET 52 PERTAINING TO THE
GRAND GULF NUCLEAR STATION, UNIT 1,
LICENSE RENEWAL APPLICATION
March 19, 2015

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Operations, Inc., (Entergy or the applicant) held a telephone conference call on March 19, 2015, to discuss Request for Additional Information (RAI) Set 52, pertaining to the Grand Gulf Nuclear Station, Unit 1 (GGNS), license renewal application (LRA). The telephone conference call was useful in discussing the issues surrounding the RAIs.

Discussion

The staff and the applicant discussed clarifications to three Fire Water System (FWS) RAIs (3.0.3-1-FWS-1a, -FWS-2a, and -FWS-8) and to 3.0.3-2b. The applicant sought several phrasing clarifications which were discussed, and the staff agreed to incorporate those that clarified the RAIs without changing the intents of the questions. The more noteworthy points adopted were as follows:

- The Issue in -FWS-2a was shortened to “An alternative to adhesion testing was not proposed.”
- The wording of the Request for -FWS-8 was modified to request additional acceptance criteria (as opposed to stating acceptance criteria).
- RAI 3.0.3-2b was shortened to delete the issue discussion on the Fire Water System AMP XI.M27 and to delete the Request (d) portions regarding tests on the FWS tank bottoms. Since the FWS tank bottoms at GGNS are not flat, request (d) would not apply to GGNS.

The applicant also indicated it understood the staff's concerns and would provide responses to them. Finally, the staff and the applicant agreed that a response to RAI Set 52 within 45 days from the date of issuance was an acceptable timeframe.

SUBJECT: Summary of Telephone Conference Call conducted on March 19, 2015

DISTRIBUTION:

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRasb Resource

RidsNrrGrandGulf PMResource

john.daily@nrc.gov

yaira.diaz-sanabria@nrc.gov

rich.smith@nrc.gov,

blake.rice@nrc.gov

greg.pick@nrc.gov