

## ArevaEPRDCDocsPEm Resource

---

**From:** Wunder, George  
**Sent:** Friday, April 10, 2015 10:20 AM  
**To:** ArevaEPRDCDocsPEm Resource  
**Subject:** FW: Section 3.7 audit action item  
**Attachments:** FW: Documents Posted in Electronic Reading Room Based on NRC 3.7 Audit Held MArch 26 - 28, 2013; FW: Revised Section 3.7 Calculations and Advanced Response to RAI 320, Q. 03.07.02-63

---

**From:** HOTTLE Nathan (AREVA) [mailto:Nathan.Hottle@areva.com]  
**Sent:** Friday, April 10, 2015 10:06 AM  
**To:** Wunder, George  
**Subject:** Section 3.7 audit action item

George,

We researched and it appears to us that Action Item #20 was closed. Let me know if this is sufficient.

Action Item #20: Calc 32-7012130-00 is the EPGB shear key behavior appropriate for shell elements not connected to the excavated volume in SASSI

Path Forward: 3/28/13 update – discussed error in calc, Calc will be corrected and placed in the Reading Room for NRC review.

The calculation was posted to the electronic reading room on May 15, 2013 (see attached email from Dennis Williford to Any Snyder).

Mike Miernicki confirmed on June 5, 2013 that Action #20 was closed because Rev 002 of the calc corrects the error (see attached email from Mike Miernicki to Tom Ryan).

*Nathan Hottle*

AREVA Inc.

3315 Old Forest Road

Lynchburg, VA 24501

Phone 434-832-3864

Mobile 434-485-4239

[nathan.hottle@areva.com](mailto:nathan.hottle@areva.com)

**Hearing Identifier:** AREVA\_EPR\_DC\_Docs\_Public  
**Email Number:** 262

**Mail Envelope Properties** (DAC719623E968245BD52D0369611110002D6F3EF2E48)

**Subject:** FW: Section 3.7 audit action item  
**Sent Date:** 4/10/2015 10:19:38 AM  
**Received Date:** 4/10/2015 10:19:39 AM  
**From:** Wunder, George

**Created By:** George.Wunder@nrc.gov

**Recipients:**  
"ArevaEPRDCDocsPEm Resource" <ArevaEPRDCDocsPEm.Resource@nrc.gov>  
Tracking Status: None

**Post Office:** HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1107	4/10/2015 10:19:39 AM
FW: Documents Posted in Electronic Reading Room Based on NRC 3.7 Audit Held MArch 26 - 28, 2013	6345	
FW: Revised Section 3.7 Calculations and Advanced Response to RAI 320, Q. 03.07.02-63	7021	

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**