



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

April 17, 2015

MEMORANDUM TO: Douglas A. Broaddus, Chief
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Richard B. Ennis, Senior Project Manager */RA/*
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNIT 2, DRAFT
REQUEST FOR ADDITIONAL INFORMATION (TAC NO. MF5383)

The attached draft request for additional information (RAI) was transmitted on April 13, 2015, to Mr. David Neff of Exelon Generation Company, LLC (Exelon, the licensee). This information was transmitted to facilitate an upcoming conference call in order to clarify the licensee's amendment request for Peach Bottom Atomic Power Station (PBAPS), Unit 2, dated December 5, 2014. The proposed amendment would revise the Technical Specifications (TSs) related to the Safety Limit Minimum Critical Power Ratios (SLMCPRs). The proposed changes result from a cycle specific analysis performed to support the operation of PBAPS, Unit 2, in the upcoming Cycle 21. The re-analysis was performed to accommodate operation in the Maximum Extended Load Line Limit Analysis Plus (MELLLA+) operating domain based on a separate license amendment request dated September 4, 2014 (ADAMS Accession No. ML14247A503).

The draft RAI was sent to Exelon to ensure that the questions are understandable, the regulatory basis for the questions is clear, and to determine if the information was previously docketed. This memorandum and the attachment do not convey or represent an NRC staff position regarding the licensee's request.

On April 17, 2015, Mr. Neff indicated that a conference call was not required and that a response to the RAI would be provided by April 30, 2015.

Docket No. 50-277

Attachment: Draft RAI

April 17, 2015

MEMORANDUM TO: Douglas A. Broaddus, Chief
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Richard B. Ennis, Senior Project Manager */RAI/*
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNIT 2, DRAFT
REQUEST FOR ADDITIONAL INFORMATION (TAC NO. MF5383)

The attached draft request for additional information (RAI) was transmitted on April 13, 2015, to Mr. David Neff of Exelon Generation Company, LLC (Exelon, the licensee). This information was transmitted to facilitate an upcoming conference call in order to clarify the licensee's amendment request for Peach Bottom Atomic Power Station (PBAPS), Unit 2, dated December 5, 2014. The proposed amendment would revise the Technical Specifications (TSs) related to the Safety Limit Minimum Critical Power Ratios (SLMCPRs). The proposed changes result from a cycle specific analysis performed to support the operation of PBAPS, Unit 2, in the upcoming Cycle 21. The re-analysis was performed to accommodate operation in the Maximum Extended Load Line Limit Analysis Plus (MELLLA+) operating domain based on a separate license amendment request dated September 4, 2014 (ADAMS Accession No. ML14247A503).

The draft RAI was sent to Exelon to ensure that the questions are understandable, the regulatory basis for the questions is clear, and to determine if the information was previously docketed. This memorandum and the attachment do not convey or represent an NRC staff position regarding the licensee's request.

On April 17, 2015, Mr. Neff indicated that a conference call was not required and that a response to the RAI would be provided by April 30, 2015.

Docket No. 50-277

Attachment: Draft RAI

DISTRIBUTION

PUBLIC

FForsaty, NRR/DSSA/SRXB

LPL1-2 R/F

RidsNrrDorlLpl1-2 Resource

RidsNrrDorlDpr Resource

RidsNrrPMPeachBottom Resource

ACCESSION NO.: ML15110A060

OFFICE	LPL1-2/PM
NAME	REnnis
DATE	04/17/2015

OFFICIAL RECORD COPY

DRAFT REQUEST FOR ADDITIONAL INFORMATION
REGARDING PROPOSED LICENSE AMENDMENT
SAFETY LIMIT MINIMUM CRITICAL POWER RATIO CHANGE
EXELON GENERATION COMPANY, LLC
PEACH BOTTOM ATOMIC POWER STATION - UNIT 2
DOCKET NO. 50-277

By letter dated December 5, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14342A229), Exelon Generation Company, LLC (Exelon, the licensee) submitted a license amendment request for Peach Bottom Atomic Power Station (PBAPS), Unit 2. The proposed amendment would revise the Technical Specifications (TSs) related to the Safety Limit Minimum Critical Power Ratios (SLMCPRs). The proposed changes result from a cycle specific analysis performed to support the operation of PBAPS, Unit 2, in the upcoming Cycle 21. The re-analysis was performed to accommodate operation in the Maximum Extended Load Line Limit Analysis Plus (MELLLA+) operating domain based on a separate license amendment request dated September 4, 2014 (ADAMS Accession No. ML14247A503).

The Nuclear Regulatory Commission (NRC) staff has reviewed the information the licensee provided that supports the proposed amendment and would like to discuss the following issues to clarify the submittal.

RAI-1

Provide the differences in design and geometrical considerations between GNF2 and GE14 fuel.

RAI-2

- a) Discuss the methodology and the scheme used for the PBAPS Unit 2 Cycles 20 and 21 core reloads. Is there a noticeable change in the core radial and axial power shapes between the Cycles 20 and 21 reloads?
- b) For the initial core loadings of Cycles 20 and 21, specify the fuel type, number of fresh, once burned, twice and thrice burned fuel.