

1.8.8 VENTING

Venting is the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during Venting. Vent, used in system names, does not imply a venting process.

1.8.9 MEMBER(S) OF THE PUBLIC

Member(s) Of The Public shall include all persons who are not occupationally associated with the plant. This category does not include employees of the utility, its contractors or its vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational, occupational or other purposes not associated with the plant.

1.8.10 UNRESTRICTED AREA

An Unrestricted Area shall be any area at or beyond the site boundary to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials or any area within the site boundary used for residential quarters or industrial, commercial institutional and/or recreational purposes.

1.9 CORE OPERATING LIMITS REPORT

The CORE OPERATING LIMITS REPORT is the unit-specific document that provides core operating limits for the current reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9. Plant operation within these core operating limits is addressed in individual specifications.

1.10 Insert A

9802090039 980130
PDR ADOCK 05000269
P PDR

INSERT A

1.10 Refueling Outage as a Surveillance Interval

Surveillance requirements contained in Section 4 which reference refueling as a frequency (e.g. "refueling outage", "each refueling shutdown", "during each refueling outage", "at each refueling", "at a refueling frequency", "during a refueling", "at least once per refueling cycle"), including Specification 4.0.2, do not require the surveillances to only be performed during a refueling outage. Surveillance specifications using the above phrases (or similar phrases) only stipulate a time duration and are synonymous with 18 months. TS 4.0.2 defines the maximum time interval for "refueling outage" surveillances as 22 month, 15 days.