

ATTACHMENT 2

REPLACEMENT PAGES

INSTRUCTIONS FOR INSERTING REPLACEMENT PAGES:

REMOVE PAGE:

3.19-5

4.1-9

4.1-9a

INSERT PAGE:

3.19-5

4.1-9

4.1-9a

respectively. Other instrumentation is provided to monitor proper operation of the ESV System, but is not required for ESV System operability.

Surveillance testing for the ECCW, ESV, and SSW systems is conducted by performing tests listed in Table 4.1-2. The Emergency Condenser Circulating Water System test is conducted every 18 months. This test verifies that air in-leakage to the ECCW siphon headers will not exceed ESV pump capability.

The Essential Siphon Vacuum System Test is performed quarterly to verify adequate performance of the ESV system. This includes a functional test to ensure the ESV float valves are capable of opening, a test of the ESV pumps performance, a test of ESV Pumps to ensure that they can be automatically restarted upon restoration of emergency power after a loss of off-site power, and a test of active valves which support operability of the ESV System.

Applicability of this Specification as described above for each Oconee unit will begin following completion of the Service Water upgrades on the respective unit. The Service Water upgrade is scheduled for completion in the Unit 2 EOC 16 refueling outage, in the Unit 3 EOC 17 refueling outage, and in the Unit 1 EOC 18 refueling outage.

Table 4.1-2
MINIMUM EQUIPMENT TEST FREQUENCY

<u>Item</u>	<u>Test</u>	<u>Frequency</u>
1. Control Rod Movement ⁽¹⁾	Movement of Each Rod	Monthly
2. Pressurizer Safety Valves	Setpoint	18 months ⁽⁴⁾
3. Main Steam Safety Valves	Setpoint	18 months ⁽⁴⁾
4. Refueling System Interlocks ⁽⁵⁾	Functional	Prior to Refueling
5. Main Steam Stop Valves ⁽¹⁾	Movement of Each Stop Valve	Monthly
6. Reactor Coolant System ⁽²⁾ Leakage	Evaluate	Daily
7. Emergency Condenser ⁽⁶⁾ Circulating Water System Test	Functional	18 months
8. High Pressure Service Water Pumps and Power Supplies	Functional	Monthly
9. Spent Fuel Cooling System	Functional	Prior to Refueling
10. High Pressure and Low ⁽³⁾ Pressure Injection System	Vent Pump Casings	Monthly and Prior to Testing
11. Emergency Feedwater Pump Automatic Start and Automatic Valve Actuation Feature	Functional	18 months
12. (Reserved)		
13. Essential Siphon Vacuum ⁽⁸⁾ System Test	Functional	Quarterly

Oconee 1, 2, and 3

4.1- 9.3

Amendment No. _____ (Unit 1)

Amendment No. _____ (Unit 2)

Amendment No. _____ (Unit 3)

- (1) Applicable only when the reactor is critical.
- (2) Applicable only when the reactor coolant is above 200°F and at a steady-state temperature and pressure.
- (3) Operating pumps excluded.
- (4) Number of safety valves to be tested every 18 months shall be in accordance with ASME Codes Section XI, Article IWV-3511, such that each valve is tested at least once every 5 years.
- (5) Applicable only to the interlocks associated with the Reactor Building Purge System.
- (6) Verification of the Emergency Condenser Circulating Water (ECCW) System function to supply siphon suction to the Low Pressure Service Water System shall be performed to ensure operability of the LPSW System.
- (7) (Reserved)
- (8) Applicability of these surveillances for each Oconee unit will begin following completion of the Service Water upgrade on the respective unit.