

April 15 1998

To: Manual Holders

Subject: Oconee SLC Revision

Please revise your SLC Manual according to instructions. This SLC revision changes the calibration requirement for RIA-56 in SLC 16.7-1 from an annual frequency to a refueling (18 month) frequency. This change makes the documentation in SLC 16.7-1 consistent with the calibration work orders.

Please update your copy of this manual as follows:

Remove These Pages

LOEP 1  
LOEP 3  
SLC 16.7-1

Insert These Pages:

LOEP 1  
LOEP 3  
SLC 16.7-1

Any questions concerning this revision may be directed to Michael E. Bailey at 864-885-4390.

Regulatory Compliance

By: Conice Breazeale  
Regulatory Compliance

9805050410 980415  
PDR ADOCK 05000269  
P PDR

Oconee Nuclear Station  
Selected Licensee Commitments  
List of Effective Pages  
Revision Date

Page  
Cover Letter

LOEP 1 4/14/98

LOEP 2 3/26/97

LOEP 3 4/14/98

LOEP 4 1/5/98

LOEP 5 11/24/97

LOEP 6 11/24/97

LOEP 7 9/19/97

LOEP 8 12/31/97

LOEP 9 9/19/97

Tab 16.0

16.0-1 9/19/97

16.0-2 9/19/97

16.0-3 9/19/97

16.0-4 9/19/97

Tab 16.1

16.1-1

Tab 16.2

16.2-1

16.2-2

16.2-3

Tab 16.3

16.3-1 2/91

Tab 16.5

16.5-1 3/91

16.5-2 3/26/97

16.5-3 2/17/94

16.5-4 2/17/94

4/14/98

Page No.

Revision Date

16.6-4	8/19/96
16.6-5	8/19/96
16.6-6	8/19/96
16.6-7	8/19/96
16.6-8	8/19/96
16.6-9	8/19/96
16.6-10	8/19/96
16.6-11	12/3/97
16.6-12	12/3/97
16.6-13	12/3/97
16.6-14	12/3/97
16.6-15	12/3/97

Tab 16.7

16.7-1	
16.7-2	
16.7-3	
16.7-4	10/91
16.7-5	10/91
16.7-6	01/93
16.7-7	01/93
16.7-8	01/93
16.7-9	10/93
16.7-10	10/93
16.7-11	10/93
16.7-12	10/93

12/3/97

## 16.7 INSTRUMENTATION

### 16.7.1 ACCIDENT MONITORING INSTRUMENTATION NOBLE GAS EFFLUENT MONITOR (RIA-56)

#### COMMITMENT

---

The Noble Gas Effluent Monitor shall be operable.

APPLICABILITY: Above Hot Shutdown

#### ACTION:

- a. If the Noble Gas Effluent Monitor (RIA-56) is inoperable, an alternative noble gas monitoring program shall be instituted within 72 hours.
- b. Alternative methods for monitoring noble gas effluent during inoperability of RIA-56 shall include one or more of the following methods:
  - RIA-45 normal range noble gas monitor on the unit vent.
  - RIA-46 high range noble gas monitor on the unit vent.
  - Actual vent sample.
  - Direct radiation readings on RIA-45 and RIA-46 sample line.

#### SURVEILLANCE:

- a. A channel functional test shall be performed on a monthly frequency.
- b. A channel calibration shall be performed on an annual frequency.

#### BASES:

The Noble Gas Effluent Monitor is utilized for detection of significant releases and release assessment.

#### REFERENCES:

1. Generic Letter 83-37
2. Regulatory Guide 1.97, Rev. 2