

- c. Each of the fire detectors listed in Table 16.9-6 with the exception of generator detectors shall be tested for sensitivity at least annually.

BASES:

OPERABILITY of the Fire Detection Instrumentation ensures that adequate warning capability is available for the prompt detection of fires. This capability is required in order to detect and locate fires in their early stages. Prompt detection of fires will reduce the potential for damage to safety related equipment and is an integral element in the overall facility fire protection program.

In the event that a portion of the Fire Detection Instrumentation is inoperable, the establishment of compensatory actions in the affected areas is required to provide detection capability until the inoperable instrumentation is restored to operability.

This Selected Licensee Commitment is part of the Oconee Fire Protection Program and therefore subject to the provisions of Oconee Facility Operating License Conditions.

REFERENCES:

- 1) Oconee FSAR. Chapter 9.5-1.
- 2) Oconee Fire Protection SER dated August 11, 1978.
- 3) Oconee Fire Protection Review, as revised.
- 4) Oconee Plant Design Basis Specification for Fire Protection, as revised.
- 5) Oconee Plant Design Basis specification for Fire Detection, as revised.

STATION MANAGER APPROVAL



DATE

5/7/98

9806010227 980507
PDR ADDCK 05000269
P PDR

16.9-18

05/07/98