

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9910050259 DOC.DATE: 99/09/29 NOTARIZED: YES DOCKET #  
 FACIL:50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH.NAME AUTHOR AFFILIATION  
 MCCOLLUM,W.R. Duke Power Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 Records Management Branch (Document Control Desk)

*See Reports*

SUBJECT: Application for amends to licenses DPR-38,DPR-47 & DPR-55,  
 to revise containment ISI program of TS 5.5.2 & 5.5.7.TS  
 pages,encl.

DISTRIBUTION CODE: A047D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 4+66  
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	HAWES,C	1 1	LABARGE,D	1 1
INTERNAL:	ACRS	1 1	FILE CENTER 01	1 1
	NUDOCS-ABSTRACT	1 1	OGC/RP	1 0
	RES/DET/ERAB	1 1	RES/DET/MEB	1 1
EXTERNAL:	LITCO ANDERSON	1 1	NOAC	1 1
	NRC PDR	1 1		

**MICROFILMED**

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 10



W. R. McCollum, Jr.  
Vice President

**Duke Power**

Oconee Nuclear Site  
7800 Rochester Highway  
Seneca, SC 29672  
(864) 885-3107 OFFICE  
(864) 885-3564 FAX

September 29, 1999

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287  
Proposed Revision to Technical Specifications  
Containment Inservice Inspection Program  
Technical Specification Change No. 99-08

Pursuant to 10 CFR 50.90, Duke Energy Corporation (Duke) hereby requests an amendment to the Technical Specifications (TS) for Oconee Nuclear Station. This proposed amendment revises the Containment Inservice Inspection (ISI) Program of TS 5.5.2, "Containment Leakage Testing Program," and TS 5.5.7, "Pre-Stressed Concrete Containment Tendon Surveillance Program," for Units 1, 2, and 3.

The proposed amendment conforms the Oconee TSs to the requirements of 10 CFR 50.55a(g) (4) pursuant to the requirements of 10 CFR 50.55a(g) (5) (ii). Additionally, the proposed amendment permits ASME Boiler and Pressure Vessel Code, Section XI, Subsection IWL visual examinations to be performed in lieu of concrete and post-tensioning system general visual examinations required by 10 CFR 50, Appendix J and Regulatory Guide 1.163 between Type A tests. The proposed amendment also permits general visual examinations of the concrete and post-tensioning system that can be performed with a unit in operation to be performed prior to the beginning of a refueling outage during which a Type A test is scheduled.

050080

Oconee Unit 3 is the next unit requiring Containment ISI (general visual and tendon inspections) for which approval of this TS amendment is needed. The required Unit 3 ISI is

9910050259 990929  
PDR ADOCK 05000269  
P PDR

1047 1/1

scheduled to start prior to and continue into a refueling outage currently scheduled to begin on April 17, 2000. Duke requests NRC approval of the proposed TS changes by February 17, 2000. Approval by February 17, 2000, provides 30 days for TS change implementation and 30 days to perform the pre-outage general visual examinations.

Attachments 1 and 2 provide the proposed new TS pages and the markup pages for the TS, respectively. The markup pages identify the added and deleted portions. Attachment 3 provides the supporting technical justification. Attachments 4 and 5 contain the No Significant Hazards Consideration Evaluation and the Environmental Impact Analysis, respectively.

Implementation of this amendment to the Oconee Technical Specifications will impact the Oconee Updated Final Safety Analysis Report (UFSAR). Necessary changes to UFSAR sections 3.8.1.2 and 3.8.1.7 will be made in accordance with 10 CFR 50.71(e).

The Nuclear Safety Review Board and the ONS Plant Operations Review Committee have reviewed and approved this proposed TS amendment.

A copy of this application is being forwarded to the South Carolina Department of Health and Environmental Control for their review and, as appropriate, subsequent consultation with the staff.

If there are any questions regarding this submittal, please contact Robert Douglas at 864-885-3073.

Very truly yours,



W. R. McCollum, Jr.,  
Site Vice President

Attachments (5)

U. S. NRC Document Control Desk  
September 29, 1999

Page 3

cc: Mr. L. A. Reyes  
Regional Administrator, Region II


Mr. D. E. Billings  
Senior Resident Inspector (Acting)

Mr. D. E. Labarge  
ONRR, Senior Project Manager

Mr. V. R. Autry  
DHEC

AFFIDAVIT

W. R. McCollum, Jr., being duly sworn, states that he is Site Vice President of Duke Energy Corporation; that he is authorized on the part of said corporation to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

  
\_\_\_\_\_  
W. R. McCollum, Jr., Site Vice President

Subscribed and sworn to me: 9-29-99  
Date

Notary Public: Conni M. Breayale

My Commission Expires: 2-12-2003  
Date

SEAL