

## IPRenewal NPEmails

---

**From:** Green, Kimberly  
**Sent:** Thursday, April 23, 2015 6:46 AM  
**To:** Walpole, Robert W  
**Cc:** IPRenewal NPEmails  
**Subject:** Additional Comments

Hi Bob,

Last evening, we received additional information to help us prepare for our presentation today. I'm passing along the following to you, as I believe you may be asked about these issues:

- What were the results for Commitment 33 (this was supposed to be completed)?
- What were the results for IP2 for Commitment 43?
- For small-bore piping (socket welds), how are the inspections/locations, which are focused on the most susceptible and risk significant, determined? With regard to this particular question on socket welds, mention is made that Commitment 46 addresses socket welds, and that IPEC will perform 25 volumetric weld inspections of socket welds during each 10-year ISI interval (in the PEO) as specified by IWB-2412.

Kim

**Hearing Identifier:** IndianPointUnits2and3NonPublic\_EX  
**Email Number:** 5098

**Mail Envelope Properties** (F5A4366DF596BF458646C9D433EA37D7022D8C960B7E)

**Subject:** Additional Comments  
**Sent Date:** 4/23/2015 6:46:28 AM  
**Received Date:** 4/23/2015 6:46:30 AM  
**From:** Green, Kimberly

**Created By:** Kimberly.Green@nrc.gov

**Recipients:**  
"IPRenewal NPEmails" <IPRenewal.NPEmails@nrc.gov>  
Tracking Status: None  
"Walpole, Robert W" <rwalpol@entergy.com>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	824	4/23/2015 6:46:30 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**