

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9709240104 DOC. DATE: 97/09/10 NOTARIZED: NO DOCKET #
 FACILITY: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 MCCOLLUM, W.R. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits addl info re exam of HPI nozzle safe-end for Unit 1,
 as follow up to previous ltr dtd 970806 re ISI program for
 third 10-Yr ISI interval.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD2-2 LA | 1 | PD2-2 PD | 1 |
| | LABARGE, D | 1 | | |
| INTERNAL: | ACRS | 1 | AEOD/SPD/RAB | 1 |
| | FILE CENTER 01 | 1 | NRR/DE/EMEB | 1 |
| | NUDOCS-ABSTRACT | 1 | OGC/HDS2 | 1 |
| | RES/DET/EIB | 1 | RES/DET/EMMEB | 1 |
| EXTERNAL: | LITCO ANDERSON | 1 | NOAC | 1 |
| | NRC PDR | 1 | | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 0

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



Duke Power Company
A Duke Energy Company

Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

W. R. McCollum, Jr.
Vice President

(864) 885-3107 OFFICE
(864) 885-3564 FAX

September 10, 1997

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, -270, -287
Inservice Inspection Program
Third Ten-Year Inservice Inspection Interval
Generic Letter 85-20 Supplemental Information

In a letter dated August 6, 1997, Duke Energy (Duke) submitted a revision to the Oconee Third Ten-Year Inservice Inspection (ISI) Program. This revision was made to enhance and clarify the general requirements of the Augmented Inspection Program, and to meet or exceed the requirements previously committed to in Generic Letter (GL) 85-20 regarding examination of High Pressure Injection (HPI) System nozzle components.

As a follow up to our previous letter dated August 6, 1997, Duke offers the following additional information regarding the examination of the HPI Nozzle Safe-End for Oconee Unit 1:

- The examinations were performed while Oconee Unit 1 was at cold shutdown. The temperature of the components examined ranged from 80 to 83° F.

As4710

9709240104 970910
PDR ADOCK 05000269
Q PDR



U. S. Nuclear Regulatory Commission


September 10, 1997

Page 2

- There were basically three different types of UT examinations performed. (1) The UT examination of the HPI Nozzle and HPI Nozzle Inside Radius was performed to meet the requirements of the 1989 Edition of ASME Section XI, Appendix I. (2) The UT examination of the HPI Safe-End to HPI Nozzle weld was performed to meet the requirements of the 1989 Edition of ASME Section XI, Appendix III. (3) The UT examination of the Safe-End base metal, Pipe to Safe-End Weld, Pipe to Valve Weld and the Base Metal of the Piping (between the Pipe to Safe-End weld and Pipe to Valve weld) was performed to meet the requirements of the 1992 Edition with the 1993 Addenda of ASME Section XI, Appendix VIII. The reason for using Appendix III for the HPI Safe-End to HPI Nozzle Weld was that an Appendix VIII examination procedures had not been qualified by Duke for dissimilar metal welds at the time that the examinations were performed.
- Additionally, six months prior to the start of the Fourth Inservice Inspection Interval, Duke will submit a letter to describe the frequency and type of examinations to be performed on the HPI Nozzle components for all three Units at Oconee Nuclear Station.

If there are any questions you may contact D. A. Nix at (864) 885-3634.

Very truly yours,


W. R. McCollum, Jr. *for*
Site Vice-President

U. S. Nuclear Regulatory Commission

September 10, 1997

Page 3

xc: D. E. LaBarge, Projects Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. L. A. Reyes
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. M. A. Scott
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Max Batavia
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201