

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9806020059 DOC. DATE: 98/05/28 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 MCCOLLUM, W.R. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits supplemental response to GL 96-06, "Assurance of Equipment Operability & Containment Integrity During Design-Basis Conditions." Delay of commitments, discussed.

DISTRIBUTION CODE: A072D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: GL 96-06, "Assurance of Equip Oprblty & Contain. Integ. during Design

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
NRR/WETZEL, B.	1 1	PD2-2 PD	1 1
LABARGE, D	1 1		
INTERNAL: <u>FILE CENTER</u> 01	1 1	NRR/DE/EMEB	1 1
<u>NRR/DSSA/SCSB</u>	1 1	NRR/DSSA/SPLB	1 1
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

2



Duke Power Company
A Duke Energy Company

Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

W. R. McCollum, Jr.
Vice President

(864) 885-3107 OFFICE
(864) 885-3564 FAX

May 28, 1998

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, 50-270, 50-287
Supplemental Response to Generic Letter 96-06:
Assurance of Equipment Operability and Containment
Integrity During Design-Basis Conditions
Delay of Commitment

Generic Letter (GL) 96-06, "Assurance of Equipment Operability and Containment Integrity During Design Basis Conditions", was issued on September 30, 1996. GL 96-06 requested licensees to determine if containment air cooler cooling water systems are susceptible to either waterhammer or two-phase flow conditions during postulated accident conditions and to determine if piping systems that penetrate containment are susceptible to thermal expansion of fluid that could lead to overpressurization of piping. Duke Energy Corporation (Duke) responded to GL 96-06 in submittals to the NRC dated October 29, 1996, January 28, 1997, April 15, 1997, June 30, 1997, August 1, 1997, and October 30, 1997.

In the August 1, 1997 submittal, Duke stated that an evaluation was in progress on two independent methods for prediction of conditions within the Low Pressure Service Water (LPSW) system. That evaluation has now been completed and the process of generating force time histories is being finalized. The resulting structural analysis of the subject piping system and attendant support structures is in progress.

9806020059 980528
PDR ADOCK 05000269
P PDR

1072 / 10

U. S. Nuclear Regulatory Commission

May 28, 1998

Page 2

In the August 1, 1997 submittal, Duke also provided expected completion dates for the various action items needed to close this issue. In Action Item 13, Duke committed to complete the review of Unit 3 piping and hanger loads based on force time histories and determine if code allowables have been exceeded with all Reactor Building Auxiliary Coolers (RBAC) valved in and all RBAC fans on. Due to the complexities involved in generation of the appropriate force time histories, structural analysis of the piping and attendant support structures has been delayed. Preliminary structural analysis work continues to support operability of the Reactor Building Cooling Units (RBCU) and the RBACU's.

Confirmation of the conclusions regarding operability of the Unit 3 LPSW system with the RBAC's valved in and all RBAC fans on is scheduled for August 1, 1998. Duke believes the delay is prudent based on the complexities of the issue. In addition, Duke plans to participate in a joint NRC/NEI GL 96-06 conference which is scheduled for May 27-28, 1998. This conference will likely address a number of issues associated with waterhammer analyses. As a result, the insights gained from this conference may affect the schedule for completion of the structural analysis.

Please address any questions to D. A. Nix at (864) 885-3634.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'W. R. McCollum, Jr.', with a stylized flourish at the end.

W. R. McCollum, Jr.
Site Vice President

U. S. Nuclear Regulatory Commission
May 28, 1998
Page 3

xc: Mr. L. A. Reyes
Regional Administrator, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303

Mr. M. A. Scott
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. D. E. LaBarge
Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555