

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9808260187 DOC.DATE: 98/08/04 NOTARIZED: NO DOCKET #
 FACIL:50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 50-369 William B. McGuire Nuclear Station, Unit 1, Duke Powe 05000369
 50-370 William B. McGuire Nuclear Station, Unit 2, Duke Powe 05000370
 50-413 Catawba Nuclear Station, Unit 1, Duke Power Co. 05000413
 50-414 Catawba Nuclear Station, Unit 2, Duke Power Co. 05000414

AUTH.NAME AUTHOR AFFILIATION
 TUCKMAN,M.S. Duke Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 REYES,L.A. Region 2 (Post 820201)

SUBJECT: Provides update on util plan for addressing fire barrier penetration seal deficiencies & enhancing design-basis documentation.Overall completion of project is scheduled for each plant,as listed.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 3
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-2 PD	1 1	LABARGE,D	1 1
RINALDI,F	1 1	TAM,P.	1 1
INTERNAL: ACRS	2 2	AEOD/SPD/RAB	1 1
AEOD/TTC	1 1	DEDRO	1 1
FILE CENTER	1 1	NRR/DRCH/HOHB	1 1
NRR/DRPM/PECB	1 1	NRR/DRPM/PERB	1 1
NUDOCS-ABSTRACT	1 1	OE DIR	1 1
OGC/HDS2	1 1	RGN2 FILE 01	1 1
EXTERNAL: LITCO BRYCE,J H	1 1	NOAC	1 1
NRC PDR	1 1	NUDOCS FULLTEXT	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION; CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 0



M. S. Tuckman
Executive Vice President
Nuclear Generation

Duke Energy Corporation

526 South Church Street
P.O. Box 1006 (EC07H)
Charlotte, NC 28201-1006
(704) 382-2200 OFFICE
(704) 382-4360 FAX

August 4, 1998

U.S. Nuclear Regulatory Commission
ATTN: Mr. L. A. Reyes
Regional Administrator
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Subject: Duke Energy Corporation
Oconee Nuclear Station - Units 1, 2, & 3
Docket Nos. 50-269, 50-270, and 50-287
McGuire Nuclear Station - Units 1 & 2
Docket Nos. 50-369 and 50-370
Catawba Nuclear station - Units 1 & 2
Docket Nos. 50-413 and 50-414
Fire Barrier Penetration Seals

Dear Mr. Reyes:

During recent Duke Triennial Fire Protection Audits at Catawba and Oconee, deficiencies were noted with some fire barrier penetration seals in that there were some through-wall gaps in the silicone foam filler material. These deficiencies were discussed with Mr. G. Wiseman of your staff and various personnel at Duke during his recent inspections at all three sites. The issue of design-basis documentation for penetrations was also discussed.

This letter is voluntarily submitted to update the Region on Duke's plan for addressing the fire barrier penetration seal deficiencies and enhancing design-basis documentation.

Identified fire barrier deficiencies are being corrected in a timely manner and further inspections are being conducted at all three stations to determine if other discrepancies exist. At Catawba and McGuire inspections are in progress and to date no further deficiencies have been identified at these sites.

9808260187 980804
PDR ADOCK 05000269
G PDR

U. S. Nuclear Regulatory Commission

August 4, 1998

Page 2

The Oconee inspections were started immediately during the audit. Additional installation problems were identified during the initial sample inspection. Repairs are initiated as deficient installations are identified. As of July 29, 1998, about 450 penetration seals have been inspected at Oconee. Additional inspections are in progress and will continue until there is confidence that penetration seals are properly installed.

At each station, the results of the sample inspections will be evaluated to determine if additional sample inspections are warranted. Additionally, foam dispensing specifications, and maintenance and inspection procedures are being enhanced.

Duke is in the process of developing a three-site plan to update penetration seal design-basis documentation and configuration information. The plan will include inspections to document as-built penetration seal configuration and development of a comprehensive design-basis document that will include this information and describe the qualification criteria for the penetration (analysis/testing). This plan will include milestone schedules for each station (this project is currently under way at Oconee). Overall completion of this project is scheduled as follows:

Oconee	6/1/99
Catawba	12/31/00
McGuire	12/31/00.

If this schedule changes Duke will notify you in writing.

Please note that our inspections/evaluations to date have determined that none of the discrepancies identified would have resulted in the inability to achieve safe shutdown in the event of a fire.

Very truly yours,



M.S. Tuckman

U. S. Nuclear Regulatory Commission
August 4, 1998
Page 3

cc: U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Mr. F. Rinaldi
U. S. Nuclear Regulatory Commission
Senior Project Manager
Office of Nuclear Reactor Regulation
Washington, DC 20555

Mr. P. S. Tam
U. S. Nuclear Regulatory Commission
Senior Project Manager
Mail Stop O-14 H25
Washington, DC 20555

Mr. D. E. Labarge
U. S. Nuclear Regulatory Commission
Senior Project Manager
Mail Stop O-14 H25
Washington, DC 20555

Mr. S. M. Shaeffer
U. S. Nuclear Regulatory Commission
Senior Resident Inspector
McGuire Nuclear Station

Mr. D. J. Roberts
U. S. Nuclear Regulatory Commission
Senior Resident Inspector
Catawba Nuclear Station

Mr. M. A. Scott
U. S. Nuclear Regulatory Commission
Senior Resident Inspector
Oconee Nuclear Station