

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9801060213 DOC.DATE: 97/12/31 NOTARIZED: NO DOCKET #
FACIL:50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
72-0004 Oconee ISFSI, 50-269, 50-270 & 50-287, 07200004

AUTH.NAME AUTHOR AFFILIATION
MCCOLLUM,W.R. Duke Power Co.
RECIP.NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Provides further addl info re NRC Bulletin 96-04, "Chemical, Galvanic, or Other Reactions Spent Fuel Storage & Transportation Casks," per 971205 ltr.

DISTRIBUTION CODE: A068D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3
TITLE: Responses to GL-96-04: Boraflex Degradation in Spent Fuel Storage Rac

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 PD	1 1	LABARGE,D	1 1
	KOBETZ,T	1 1		
INTERNAL:	ACRS	1 1	FILE CENTER 01	1 1
	NRR/DE/EMCB	1 1	NRR/DE/SRXB	1 1
	NRR/DRPW/PD4-2	1 1	NRR/DSSA/SPLB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 1
	RES	1 1		
EXTERNAL:	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 13



Duke Power Company
A Duke Energy Company

Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

W. R. McCollum, Jr.
Vice President

(864) 885-3107 OFFICE
(864) 885-3564 FAX

December 31, 1997

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Site
Docket Nos. 72-04, 50-269, -270, -287
Bulletin 96-04, "Chemical, Galvanic, or Other Reactions
Spent Fuel Storage and Transportation Casks"
Request for Additional Information

In a letter dated August 19, 1996, Duke Energy Corporation (Duke) responded to NRC Bulletin 96-04, "Chemical, Galvanic, or Other Reactions Spent Fuel Storage and Transportation Casks". In a letter dated April 8, 1997, the NRC staff requested additional information from Duke regarding NRC Bulletin 96-04. That additional information was provided by Duke in a letter dated November 3, 1997. In a letter dated December 5, 1997, the NRC staff requested further additional information from Duke regarding NRC Bulletin 96-04. That additional information is provided in this letter and attachment.

If there are further questions about this item, please contact Ed Price at (864) 885-4388.

Very truly yours,

W. R. McCollum, Jr.
Vice President, Oconee Nuclear Site

AV68

9801060213 971231
PDR ADOCK 05000269
Q PDR

050002



NRC Document Control Desk

Decemeber 31, 1997

Page 2

cc:

Director, Office of Nuclear Material and Safeguards
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. L. A. Reyes, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. D. E. LaBarge, Project Manager
Office of Nuclear Reactor Regulation

Mr. M. A. Scott
Senior Resident Inspector
Oconee Nuclear Site

ATTACHMENT
Response to NRC Bulletin 96-04 RAI

The NRC has asserted that the vapor space of dry storage canisters (DSC) coated with flame-sprayed aluminum should be monitored continuously, rather than periodically, during welding or cutting to ensure that the hydrogen concentration does not exceed 2.4% by volume. To ensure continuous monitoring is performed, the NRC requests that the licensee revise loading and unloading procedures to include continuous monitoring of the DSC vapor space during welding, grinding, or cutting operations.

Duke Power agrees to revise its DSC loading (MP/0/A/1500/007 & MP/0/A/1500/016) and DSC unloading (MP/0/A/1500/015 & MP/0/A/1500/017) procedures to include provisions for continuous monitoring of the vapor space of DSC's coated with flame-sprayed aluminum for hydrogen. For the loading procedures, this continuous monitoring will be conducted during any welding, grinding or cutting until the DSC is sealed. For the unloading procedures, continuous monitoring will be done during any welding, grinding or cutting once the interior of the DSC has been breached.

Duke Power also agrees to complete these procedure changes prior to either loading or unloading any DSC's in the future.