

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9801230093 DOC. DATE: 98/01/07 NOTARIZED: NO DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
AUTH. NAME AUTHOR AFFILIATION
MCCOLLUM, W.R. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Summarizes that DPC commits to perform all future ultrasonic exam & insp of HPIS nozzle components to meet requirements of ASME Code, Section XI, App VIII, or use calibration blocks w/cracks that simulate type of cracks observed at unit 2.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	LABARGE, D	1 1		
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	1 1
	FILE CENTER 01	1 1	NRR/DE/EMEB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
	RES/DET/EIB	1 1	RES/DET/EMMEB	1 1
EXTERNAL:	LITCO ANDERSON	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 2



Duke Power Company

A Duke Energy Company

Oconee Nuclear Site

P.O. Box 1439

Seneca, SC 29679

W. R. McCollum, Jr.
Vice President

(864) 885-3107 OFFICE

(864) 885-3564 FAX

January 7, 1998

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, -270, -287
Inservice Inspection Program
Third Ten-Year Inservice Inspection Interval
Generic Letter 85-20 Supplemental Information

In letters dated August 6, 1997, and September 10, 1997, Duke Energy (Duke) submitted a revision to the Oconee Third Ten-Year Inservice Inspection (ISI) Program. This revision was made to enhance and clarify the general requirements of the Augmented Inspection Program, and to meet or exceed the requirements previously committed to in Generic Letter (GL) 85-20 regarding examination of High Pressure Injection (HPI) System nozzle components.

In a letter dated October 23, 1997, the NRC staff approved this revision to the Oconee ISI Program. This letter requested that Duke provide commitments regarding performance of the GL 85-20 examinations of HPI System nozzle components. Accordingly, Duke commits to the following activities with regard to examination of HPI System nozzle components:

Duke will perform all future ultrasonic examinations and inspections of the HPI nozzles, HPI nozzles inner radii, and HPI safe-end-to HPI nozzle weld, to either meet the requirements of the 1992 Edition with the 1993 Addenda of the ASME Code, Section XI, Appendix VIII, or use calibration blocks with cracks that simulate the type of crack observed in Oconee Unit 2.

AD47/10

220138


9801230093 980107
PDR ADDCK 05000269
Q PDR



U. S. Nuclear Regulatory Commission
January 7, 1998
Page 2

If there are any questions you may contact D. A. Nix at (864)
885-3634.

Very truly yours,

A handwritten signature in dark ink, appearing to read "W. R. McCollum, Jr.", written in a cursive style.

W. R. McCollum, Jr.
Site Vice-President

U. S. Nuclear Regulatory Commission
January 7, 1998
Page 3

xc: D. E. LaBarge, Projects Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. L. A. Reyes
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. M. A. Scott
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Max Batavia
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201