

OCONEE NUCLEAR STATION  
MONTHLY OPERATING STATUS REPORT

October 1992

1. Personnel Exposure -

For the month of October, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

Revision 1

## UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October 1992

DOCKET NO.	50-287
UNIT NAME	OCONEE 3
DATE	11/15/92
COMPLETED BY	N. C. SIMMONS
TELEPHONE	(704)-382-5263

N O .	DATE	(1)  T Y P E	DURATION HOURS	(2)  R E A S O N	(3)  M E T- H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4)  S Y S- T E M C O D E	(5)  C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
17-P	92-10- 1	F	--	B	--		IA	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION
18-P	92-10- 1	F	--	A	--		XX	XXXXXX	OPERATER AIDED COMPUTER OUT OF SERVICE
19-P	92-10- 1	F	--	B	--		RC	INSTRU	POWER ESCALATION TESTING
13	92-10- 1	F	318.65	A	1		HA	GENERA	GENERATOR SEAL OIL PROBLEMS
20-P	92-10-15	F	--	B	--		CG	XXXXXX	HOLD FOR CHEMISTRY
21-P	92-10-15	F	--	B	--		IA	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION
22-P	92-10-16	F	--	B	--		IA	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION

(1)  
F Forced  
S Scheduled

(2)  
Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operator Error (Explain)  
H-Other (Explain)

(3)  
Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Other (Explain)

(4)  
Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets For Licensee  
Event Report (LER)  
File (NUREG-0161)

(5)  
Exhibit I - Same Source