

OCONEE NUCLEAR STATION  
MONTHLY OPERATING STATUS REPORT  
APRIL 1993

1. Personnel Exposure -

The total station liquid release for April has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for April has been compared with the Technical Specification maximum annual dose commitment and was less than 10 percent of this list.

9306170048 930615  
PDR ADOCK 05000269  
R PDR