

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9307190258 DOC. DATE: 93/06/30 NOTARIZED: NO DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
AUTH. NAME AUTHOR AFFILIATION
WILLIAMS, R.A. Duke Power Co.
MCCRAW, E.O. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for June 1993 for Oconee Nuclear Station, Units 1, 2 & 3. W/930715 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 18
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	3 3	PD2-3 PD	1 1
	WIENS, L	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	NRR/DORS/OEAB	1 1
	NRR/DRIL/RPEB	1 1	<u>REG FILE</u> 01	1 1
	RGN2	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

Duke Power Company
Electric Center
P.O. Box 1006
Charlotte, N.C. 28201-1006



DUKE POWER

July 15, 1993

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

RE: Oconee Nuclear Station
Docket No. 50-269, -270, -287
File: GS-801.01

Dear Sir:

Please find attached information concerning the performance and operating status of the Oconee Nuclear Station for the month of June, 1993.

Very truly yours,

E. O. McCraw, Manager
Operations, Performance & Automation

EOM/raw
Attachments

xc: Stewart D. Ebnetter
Regional Administrator/Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30323

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
Town Center, Suite 300S
29 South Main Street
West Hartford, CT 06107-2445

L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Ms. Margaret Aucoin
Nuclear Assurance Corporation
Suite 200
655 Engineering Drive
Norcross, GA 30092-2843

P. E. Harmon
Senior Resident Inspector
Oconee Nuclear Station

9307190258 930722D
PDR ADOCK 05000269
R PDR

IE2A
11

U.S. NRC - Oconee
July 15, 1993
Page 2

bc: K. S. Canady (EC08H)
D. L. Davidson (ONS)
Richard Edwards (B&W)
M. E. Patrick (ONS)
T. E. Mooney (EC05N)
B. J. Horsley (EC03U)
N. A. Rutherford (EC07I)
R. Henderson (ONS)
R. A. Williams (EC07A) (3)
J. C. Wimbish (EC07B)
M. Pruitt (ONS)
E. C. Fisher (MNS)
B. W. Walsh (EC11C)
Jim Thomae (CNS)
C. D. Denton (PB05E)
G. A. Copp (EC050) (File)
Candace Paton (PB02L)

OPERATING DATA REPORT

DOCKET NO 50-269

DATE July 15, 1993

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 1
2. Reporting Period: June 1, 1993-June 30, 1993
3. Licensed Thermal Power (Mwt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason For Restrictions, If any: _____

This Month Yr.-to-Date Cumulative

11. Hours In Reporting Period	720.0	4343.0	174960.0
12. Number Of Hours Reactor Was Critical	720.0	3599.0	134393.8
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	720.0	3518.8	131725.6
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	1849584	8930472	322678102
17. Gross Electrical Energy Generated (MWH)	639606	3086044	111625689
18. Net Electrical Energy Generated (MWH)	612119	2946509	106033942
19. Unit Service Factor	100.0	81.0	75.3
20. Unit Availability Factor	100.0	81.0	75.3
21. Unit Capacity Factor (Using MDC Net)	100.5	80.2	70.7
22. Unit Capacity Factor (Using DER Net)	96.0	76.6	68.3
23. Unit Forced Outage Rate	0.0	2.0	10.6
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	NONE		

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-269
UNIT Oconee 1
DATE July 15, 1993
COMPLETED BY R.A. Williams
TELEPHONE 704-382-5346

MONTH June, 1993

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
1	<u>856</u>
2	<u>856</u>
3	<u>856</u>
4	<u>856</u>
5	<u>855</u>
6	<u>855</u>
7	<u>855</u>
8	<u>855</u>
9	<u>855</u>
10	<u>855</u>
11	<u>854</u>
12	<u>854</u>
13	<u>854</u>
14	<u>854</u>
15	<u>854</u>
16	<u>854</u>

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
17	<u>849</u>
18	<u>844</u>
19	<u>842</u>
20	<u>840</u>
21	<u>839</u>
22	<u>838</u>
23	<u>838</u>
24	<u>841</u>
25	<u>847</u>
26	<u>849</u>
27	<u>850</u>
28	<u>850</u>
29	<u>850</u>
30	<u>849</u>

REPORT MONTH June 1993

DOCKET NO. 50-269
UNIT NAME OCONEE 1
DATE 07/15/93
COMPLETED BY N. C. SIMMONS
TELEPHONE (704)-382-5263

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T - H O D O F S H U T D O W N R /X	L I C E N S E E V E N T R E P O R T N O.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	C A U S E A N D C O R R E C T I V E A C T I O N T O P R E V E N T R E C U R R E N C E
		NO	SHUTDOWNS	OR		REDUCTION	S		

(1) F Forced
S Scheduled

(2) Reason:
A-Equipment Failure (Explain)
B-Maintenance or test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operator Error (Explain)
H-Other (Explain)

(3) Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

(4) Exhibit G - Instructions
for Preparation of Data
Entry Sheets For License
Event Report (LER)
File (NUREG-0161)

(5) Exhibit I - Same Source

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 1
2. Scheduled next refueling shutdown: April 1994
3. Scheduled restart following refueling: June 1994

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
(b) in the spent fuel pool: 1022*
(c) in the ISFSI: 528****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present licensed capacity: February 2013***

DUKE POWER COMPANY

DATE: July 15, 1993

Name of Contact: N. C. Simmons

Phone: 704-382-5263

* Represents the combined total for Units 1 and 2

** On January 29, 1990, received a license for ISFSI which will store 2112 assemblies

*** This date is based on 88 Dry Storage Modules. We currently have 20 modules (480 spaces). Additional modules will be built on an as needed basis.

**** Represents the combined total for Units 1,2 and 3

DOCKET: 50-269

UNIT: Oconee 1

Date: 07/15/93

NARRATIVE SUMMARY

MONTH: June 1993

Oconee Unit 1 began the month of June operating at 100% full power. The unit operated at or near 100% full power for the entire month.

Prepared by N. C. Simmons
Telephone: 704-382-5263

OPERATING DATA REPORT

DOCKET NO 50-270

DATE July 15, 1993

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 2
2. Reporting Period: June 1, 1993-June 30, 1993
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason For Restrictions, If any: _____

This Month Yr.-to-Date Cumulative

11. Hours In Reporting Period	720.0	4343.0	164880.0
12. Number Of Hours Reactor Was Critical	209.5	3045.6	129619.8
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	154.4	2986.1	127769.1
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	355608	7626360	310234670
17. Gross Electrical Energy Generated (MWH)	122748	2659452	106011996
18. Net Electrical Energy Generated (MWH)	110002	2538454	100924408
19. Unit Service Factor	21.4	68.8	77.5
20. Unit Availability Factor	21.4	68.8	77.5
21. Unit Capacity Factor (Using MDC Net)	18.1	69.1	71.4
22. Unit Capacity Factor (Using DER Net)	17.2	66.0	69.0
23. Unit Forced Outage Rate	0.0	0.0	9.1
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	NONE		

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-270
 UNIT Oconee 2
 DATE July 15, 1993
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

MONTH June, 1993

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>52</u>
25	<u>530</u>
26	<u>846</u>
27	<u>859</u>
28	<u>858</u>
29	<u>858</u>
30	<u>834</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH June 1993

DOCKET NO. 50-270
 UNIT NAME OCONEE 2
 DATE 07/15/93
 COMPLETED BY N. C. SIMMONS
 TELEPHONE (704)-382-5263

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	93- 6- 1	S	456.75	C	--		RC	FUELXX	END-OF-CYCLE 13 REFUELING OUTAGE
2	93- 6-20	S	24.00	A	--		CA	XXXXXX	1 DAY OUTAGE EXTENSION DUE TO REACTOR HEAD ASSEMBLY
3	93- 6-21	S	36.87	A	--		RC	FUELXX	1.5 DAY OUTAGE EXTENSION DUE TO DEFUELED MAINTENANCE
4	93- 6-22	S	24.00	A	--		RC	FUELXX	1 DAY OUTAGE EXTENSION DUE TO FUEL MOVEMENT PROBLEMS
5	93- 6-23	S	24.00	A	--		RC	ZZZZZZ	1 DAY OUTAGE EXTENSION DUE TO ZERO POWER PHYSICS TESTING
2-P	93- 6-24	F	--	A	--		HB	HTEXCH	MOISTURE SEPERATOR/REHEATER PROBLEMS
3-P	93- 6-25	S	--	B	--		IA	XXXXXX	INTERMEDIATE POWER TESTING

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For License
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 2
2. Scheduled next refueling shutdown: September 1994
3. Scheduled restart following refueling: November 1994

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
(b) in the spent fuel pool: 1022*
(c) in the ISFSI: See Unit 1****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present licensed capacity: October 2013***

DUKE POWER COMPANY

DATE: July 15, 1993

Name of Contact: N. C. Simmons

Phone: 704-382-5263

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 20 modules (480 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

DOCKET: 50-270

UNIT: Oconee 2

Date: 07/15/93

NARRATIVE SUMMARY

MONTH: June 1993

Oconee Unit 2 began the month of June in end-of-cycle 13 refueling outage. The unit was in the refueling outage until 6/24 at 1337. The outage was 56.54 days and was scheduled for 52 days. The refueling outage end date was delayed; 1 day due to reactor head work delays, 1.5 day due to delays during defueled maintenance, 1 day due to fuel movement problems, and 1 day due to delays during zero power physics testing. During power escalation, the unit held at approximately 20% power from 1420 to 1720 due to moisture separator/reheater problems. The unit held at 73% power from 6/25 at 1430 to 1923 for intermediate power testing. The unit reached 100% full power on 6/26 at 0603. The unit operated at or near 100% full power for the remainder of the month.

OPERATING DATA REPORT

DOCKET NO 50-287

DATE July 15, 1993

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 3
2. Reporting Period: June 1, 1993-June 30, 1993
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.0	4343.0	162527.0
12. Number Of Hours Reactor Was Critical	720.0	4329.3	124864.9
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	720.0	4325.6	123132.0
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	1848960	11091912	305307561
17. Gross Electrical Energy Generated (MWH)	648903	3897419	105297277
18. Net Electrical Energy Generated (MWH)	621851	3739930	100423941
19. Unit Service Factor	100.0	99.6	75.8
20. Unit Availability Factor	100.0	99.6	75.8
21. Unit Capacity Factor (Using MDC Net)	102.1	101.8	72.1
22. Unit Capacity Factor (Using DER Net)	97.5	97.2	69.7
23. Unit Forced Outage Rate	0.0	0.4	10.7

24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling - December 28, 1993 55 days

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-287
UNIT Oconee 3
DATE July 15, 1993
COMPLETED BY R.A. Williams
TELEPHONE 704-382-5346

MONTH June, 1993

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>867</u>
2	<u>858</u>
3	<u>866</u>
4	<u>868</u>
5	<u>868</u>
6	<u>867</u>
7	<u>866</u>
8	<u>867</u>
9	<u>866</u>
10	<u>866</u>
11	<u>865</u>
12	<u>865</u>
13	<u>863</u>
14	<u>862</u>
15	<u>861</u>
16	<u>859</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>859</u>
18	<u>863</u>
19	<u>864</u>
20	<u>864</u>
21	<u>864</u>
22	<u>864</u>
23	<u>865</u>
24	<u>865</u>
25	<u>865</u>
26	<u>865</u>
27	<u>865</u>
28	<u>865</u>
29	<u>865</u>
30	<u>841</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH June 1993

DOCKET NO. 50-287
 UNIT NAME OCONEE 3
 DATE 07/15/93
 COMPLETED BY N. C. SIMMONS
 TELEPHONE (704)-382-5263

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
		NO	SHUTDOWNS	OR		REDUCTION	S		

(1)
F Forced
S Scheduled

(2)
Reason:
A-Equipment Failure (Explain)
B-Maintenance or test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operator Error (Explain)
H-Other (Explain)

(3)
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

(4)
Exhibit G - Instructions
for Preparation of Data
Entry Sheets For License
Event Report (LER)
File (NUREG-0161)

(5)
Exhibit I - Same Source

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 3
2. Scheduled next refueling shutdown: December 1993
3. Scheduled restart following refueling: February 1994

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
(b) in the spent fuel pool: 516
(c) in the ISFSI: See Unit 1****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present licensed capacity: July 2014***

DUKE POWER COMPANY

DATE: July 15, 1993

Name of Contact: N. C. Simmons

Phone: 704-382-5263

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 20 modules (480 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

DOCKET: 50-287

UNIT: Oconee 3

Date: 07/15/93

NARRATIVE SUMMARY

MONTH: June 1993

Oconee Unit 3 began the month of June operating at 100% full power. The unit operated at or near 100% full power for the entire month.

Prepared by N. C. Simmons
Telephone: 704-382-5263

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

May 1993

1. Personnel Exposure -

The total station liquid release for May has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for May has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.