

OPERATING DATA REPORT

DOCKET NO 50-269

DATE December 15, 1997

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 1
2. Reporting Period: November 1, 1997-November 30, 1997
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason For Restrictions, If any: _____

This Month Yr.-to-Date Cumulative

11. Hours In Reporting Period	720.0	8016.0	213697.0
12. Number Of Hours Reactor Was Critical	0.0	4437.4	164871.3
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	0.0	4398.9	161888.2
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	0	9825368	398191422
17. Gross Electrical Energy Generated (MWH)	0	3364812	137615888
18. Net Electrical Energy Generated (MWH)	-2529	3181969	130792316
19. Unit Service Factor	0.0	54.9	75.8
20. Unit Availability Factor	0.0	54.9	75.8
21. Unit Capacity Factor (Using MDC Net)	0.0	46.9	71.6
22. Unit Capacity Factor (Using DER Net)	0.0	44.8	69.0
23. Unit Forced Outage Rate	0.0	15.6	9.5
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

Currently Refueling

25. If Shut Down At End Of Report Period. Estimated Date of Startup: December 21, 1997

26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf-934 MW

9712180430 971215
PDR ADOCK 05000269
R PDR

OPERATING DATA REPORT

DOCKET NO 50-269
UNIT Oconee 1
DATE December 15, 1997
COMPLETED BY R.A. Williams
TELEPHONE 704-382-5346

MONTH November, 1997

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November 1997DOCKET NO. 50-269UNIT NAME OCONEE 1DATE 12/15/97COMPLETED BY R. A. WilliamsTELEPHONE (704)-382-5346

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
5	97-11- 1	S	314.70	C	--		RC	FUELXX	END-OF-CYCLE 17 REFUELING OUTAGE
6	97-11-14	S	405.30	C	--		RC	FUELXX	OUTAGE EXTENSION DUE TO END-OF-CYCLE 17 REFUELING ACTIVITIES

(1)
F Forced
S Scheduled

(2)
Reason:
A-Equipment Failure (Explain)
B-Maintenance or test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operator Error (Explain)
H-Other (Explain)

(3)
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

(4)
Exhibit G - Instructions
for Preparation of Data
Entry Sheets For Licensee
Event Report (LER)
File (NUREG-0161)

(5)
Exhibit I - Same Source

DOCKET: 50 - 269

UNIT: Oconee 1

DATE: 12/15/97

NARRATIVE SUMMARY

MONTH: November, 1997

Oconee Unit 1 began the month of November in end-of-cycle 17 refueling outage. The unit was in the refueling outage the remainder of the month.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 1
2. Scheduled next refueling shutdown: Currently Refueling
3. Scheduled restart following refueling: December 1997

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 1034*
(c) in the ISFSI: 960****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: February 2013***

DUKE POWER COMPANY

DATE: December 15, 1997

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** On January 29, 1990, received a license for ISFSI which will store 2112 assemblies

*** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as-needed basis.

**** Represents the combined total for Units 1, 2, and 3

OPERATING DATA REPORT

DOCKET NO 50-270

DATE December 15, 1997

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 2
2. Reporting Period: November 1, 1997-November 30, 1997
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.0	8016.0	203617.0
12. Number Of Hours Reactor Was Critical	720.0	6318.7	161328.6
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	720.0	6233.2	159234.2
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	1830470	15919510	390424668
17. Gross Electrical Energy Generated (MWH)	636773	5495960	133765749
18. Net Electrical Energy Generated (MWH)	609452	5231250	127384995
19. Unit Service Factor	100.0	77.8	78.2
20. Unit Availability Factor	100.0	77.8	78.2
21. Unit Capacity Factor (Using MDC Net)	100.1	77.1	73.2
22. Unit Capacity Factor (Using DER Net)	95.5	73.7	70.6
23. Unit Forced Outage Rate	0.0	22.2	10.2
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Refueling - March 26, 1998			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation): _____

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

NRC Calculated from Generator Nameplate Data:
1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-270
UNIT Oconee 2
DATE December 15, 1997
COMPLETED BY R.A. Williams
TELEPHONE 704-382-5346

MONTH November, 1997

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>849</u>
2	<u>851</u>
3	<u>852</u>
4	<u>852</u>
5	<u>853</u>
6	<u>678</u>
7	<u>768</u>
8	<u>843</u>
9	<u>843</u>
10	<u>854</u>
11	<u>858</u>
12	<u>858</u>
13	<u>858</u>
14	<u>858</u>
15	<u>860</u>
16	<u>859</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>859</u>
18	<u>859</u>
19	<u>859</u>
20	<u>860</u>
21	<u>860</u>
22	<u>860</u>
23	<u>860</u>
24	<u>860</u>
25	<u>861</u>
26	<u>861</u>
27	<u>860</u>
28	<u>861</u>
29	<u>857</u>
30	<u>822</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November 1997

DOCKET NO. 50-270
 UNIT NAME OCONEE 2
 DATE 12/15/97
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T - H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
13-P	97-11- 6	F	--	A	--		HA	PUMPXX	REPAIR MAIN SEAL OIL PUMP BEARINGS
14-P	97-11- 7	F	--	B	--		IA	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION CHECK

(1)
F Forced
S Scheduled

(2) Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3) Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4) Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5) Exhibit I - Same Source

DOCKET: 50 - 270

UNIT: Oconee 2

Date: 12/15/97

NARRATIVE SUMMARY

MONTH: November, 1997

Oconee Unit 2 began the month of November operating at 100% full power. On 11/06/97 at 1220 the unit began decreasing power and held at 55% power from 1419 to 11/07/97 at 0319 to repair main seal oil pump bearings. During power escalation, the unit held at 65% power from 0350 to 0406 due to nuclear instrumentation calibration check. The unit returned to 100% full power on 11/07/97 at 0605, and operated at or near 100% full power the remainder of the month.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 2
2. Scheduled next refueling shutdown: March 1998
3. Scheduled restart following refueling: May 1998

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 1034*
(c) in the ISFSI: See unit 1 ****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: October 2013***

DUKE POWER COMPANY

DATE: December 15, 1997

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

OPERATING DATA REPORT

OPERATING STATUS

DOCKET NO 50-287

DATE December 15, 1997

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

1. Unit Name: Oconee 3
2. Reporting Period: November 1, 1997-November 30, 1997
3. Licensed Thermal Power (Mwt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.0	8016.0	201264.0
12. Number Of Hours Reactor Was Critical	720.0	5423.3	155534.4
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	720.0	4891.6	153184.3
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	1847111	12379409	381746042
17. Gross Electrical Energy Generated (MWH)	650243	4242156	131786233
18. Net Electrical Energy Generated (MWH)	623113	4010007	125674692
19. Unit Service Factor	100.0	61.0	76.1
20. Unit Availability Factor	100.0	61.0	76.1
21. Unit Capacity Factor (Using MDC Net)	102.3	59.1	73.0
22. Unit Capacity Factor (Using DER Net)	97.7	56.5	70.4
23. Unit Forced Outage Rate	0.0	32.7	10.6
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			
None			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

OPERATING DATA REPORT

DOCKET NO 50-287
UNIT Oconee 3
DATE December 15, 1997
COMPLETED BY R.A. Williams
TELEPHONE 704-382-5346

MONTH November, 1997

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	<u>861</u>
2	<u>862</u>
3	<u>861</u>
4	<u>862</u>
5	<u>862</u>
6	<u>860</u>
7	<u>864</u>
8	<u>866</u>
9	<u>866</u>
10	<u>866</u>
11	<u>867</u>
12	<u>868</u>
13	<u>867</u>
14	<u>867</u>
15	<u>868</u>
16	<u>868</u>

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
17	<u>868</u>
18	<u>868</u>
19	<u>869</u>
20	<u>869</u>
21	<u>869</u>
22	<u>870</u>
23	<u>870</u>
24	<u>869</u>
25	<u>869</u>
26	<u>868</u>
27	<u>868</u>
28	<u>866</u>
29	<u>864</u>
30	<u>842</u>

REPORT MONTH November 1997

UNIT NAME O'CONNOR 3

DATE 12/15/97

COMPLETED BY R. A. Williams

TELEPHONE (704) - 382-5346

(1)	F Forced S Scheduled	(2)	Reason: A-Equipment Failure (Explain) B-Maintenance or test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operator Error (Explain) H-Other (Explain)	(3)	Method: 1-Manual 2-Manual Scram 3-Automatic Scram 4-Other (Explain)	(4)	Exhibit G - Instructions for Preparation of Data Entry Sheets For Licensee Event Report (LER) File (NUREG-0161)
						(5)	Exhibit I - Same Source

DOCKET: 50 - 287

UNIT: Oconee 3

Date: 12/15/97

NARRATIVE SUMMARY

MONTH: November, 1997

Oconee Unit 3 began the month of November operating at 100% full power. The unit operated at or near 100% full power for the entire month.

Prepared by: R. A Williams
Telephone: (704) - 382-5346

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 3
2. Scheduled next refueling shutdown: September 1998
3. Scheduled restart following refueling: October 1998

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 552
(c) in the ISFSI: See Unit 1 ****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: July 2014***

DUKE POWER COMPANY

DATE: December 15, 1997

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

** See footnote of Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1