

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

November 1997

1. Personnel Exposure -

The total station liquid release for November has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for November has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9801220077 980115
PDR ADDCK 05000269
R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269

UNIT NAME OCONEE 1

DATE 12/15/97

COMPLETED BY R. A. Williams

TELEPHONE (704)-382-5346

REPORT MONTH November 1997

* REVISION 1

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T - H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
5	97-11- 1	S	314.70	C	--		RC	FUELXX	END-OF-CYCLE 17 REFUELING OUTAGE
6	97-11-14	S	38.00	A	--		SA	XXXXXX	OUTAGE DELAY OF 1.58 DAYS DUE TO REACTOR BUILDING HIGH TEMPERATURE
7	97-11-15	S	61.00	A	--		SE	RECOMB	OUTAGE DELAY OF 2.54 DAYS DUE TO HYDROGEN RECOMBINER MODIFICATIONS
8	97-11-18	S	306.30	B	--		SF	XXXXXX	OUTAGE DELAY OF 12.76 DAYS DUE TO FAILED INTER-SYSTEM LOCA LEAK RATE TEST

(1)
F Forced
S Scheduled

(2)
Reason:
A-Equipment Failure (Explain)
B-Maintenance or test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operator Error (Explain)
H-Other (Explain)

(3)
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

(4)
Exhibit G - Instructions
for Preparation of Data
Entry Sheets For Licensee
Event Report (LER)
File (NUREG-0161)

(5)
Exhibit I - Same Source