

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

January 1998

1. Personnel Exposure -

The total station liquid release for January has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for January has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9803180110 980313  
PDR ADOCK 05000269  
R PDR

## UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269

UNIT NAME OCONEE 1

DATE 02/13/98

COMPLETED BY R. A. Williams

TELEPHONE (704)-382-5346

REVISION 1

REPORT MONTH January 1998

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	98- 1- 1	F	624.78	A	--		CH	HTEXCH	STEAM GENERATOR "1A" TUBE LEAK
2	98- 1-27	F	119.22	A	--		CB	PIPEXX	PRESSURIZER DRAIN LINE LEAK

(1)  
F Forced  
S Scheduled

(2)  
Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operator Error (Explain)  
H-Other (Explain)

(3)  
Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Other (Explain)

(4)  
Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets For Licensee  
Event Report (LER)  
File (NUREG-0161)

(5)  
Exhibit I - Same Source

DOCKET: 50 - 269

UNIT: Oconee 1

DATE: 02/13/98

### NARRATIVE SUMMARY

#### REVISION 1

MONTH: January, 1998

Oconee Unit 1 began the month of January in an outage due to steam generator "1A" tube leak. The unit was in the outage until 01/27/98 at 0047. On 01/27/98 at 0047 during heat-up a weld leak occurred on the pressurizer drain line. The unit was in the outage the remainder of the month.

Prepared by: R. A. Williams  
Telephone: (704) - 382-5346