

Operating Data Report

Docket No.	50-269
Date	March 11, 1999
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: February 1, 1999 - February 28, 1999
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	672.0	1416.0	224617.0
12. Number of Hours Reactor was Critical	672.0	1416.0	173723.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	672.0	1416.0	170646.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1724463	3596227	420102831
17. Gross Electrical Energy Generated (MWH)	601812	1256099	145179859
18. Net Electrical Energy Generated (MWH)	576142	1202017	137986278
19. Unit Service Factor	100.0	100.0	76.0
20. Unit Availability Factor	100.0	100.0	76.0
21. Unit Capacity Factor (Using MDC Net)	101.3	100.3	71.9
22. Unit Capacity Factor (Using DER Net)	96.8	95.8	69.3
23. Unit Forced Outage Rate	0.0	0.0	10.1
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

9903240013 990315
PDR ADOCK 05000269
R PDR

UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME: Oconee 1DATE: March 15, 1999COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: February, 1999

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: May 1999
3. Scheduled restart following refueling: July 1999

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 1094*
(c) in the ISFSI: 984****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: March 2013***

DUKE POWER COMPANY

DATE: March 15, 1999

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

- * Represents the combined total for Units 1 and 2
- ** On March 29, 1990, received a license for ISFSI which will store 2112 assemblies
- *** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as-needed basis.
- **** Represents the combined total for Units 1, 2, and 3

● Operating Data Report ●

Docket No.	<u>50-270</u>
Date	<u>March 11, 1999</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

Operating Status

- | | |
|---|--------------------------------------|
| 1. Unit Name: | Oconee 2 |
| 2. Reporting Period: | February 1, 1999 - February 28, 1999 |
| 3. Licensed Thermal Power (MWt): | 2568 |
| 4. Nameplate Rating (Gross MWe): | 934 |
| 5. Design Electrical Rating (Net MWe): | 886 |
| 6. Maximum Dependable Capacity (Gross MWe): | 886 |
| 7. Maximum Dependable Capacity (Net MWe): | 846 |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: | |

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

-
9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason for Restrictions, If any: _____
-

	This Month	YTD	Cumulative
11. Hours in Reporting Period	672.0	1416.0	214537.0
12. Number of Hours Reactor was Critical	584.2	1328.2	170370.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	575.6	1319.6	168075.7
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1454515	3363258	412763802
17. Gross Electrical Energy Generated (MWH)	508661	1179274	141546205
18. Net Electrical Energy Generated (MWH)	484778	1127965	134802263
19. Unit Service Factor	85.6	93.2	78.3
20. Unit Availability Factor	85.6	93.2	78.3
21. Unit Capacity Factor (Using MDC Net)	85.3	94.2	73.5
22. Unit Capacity Factor (Using DER Net)	81.4	89.9	70.9
23. Unit Forced Outage Rate	14.4	6.8	9.9
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-270UNIT NAME: Oconee 2DATE: March 15, 1999COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: February, 1999

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	02/23/99	F	93.13	A	1		STEAM GENERATOR RISER RING LEAK
2	02/28/99	F	3.32	A	3		TURBINE/REACTOR TRIP DUE TO MAIN TURBINE CONTROL VALVES RAMPING CLOSED

Summary:

The unit began the month of February operating at 100% full power. The unit operated at or near 100% full power until 02/23/99 at 0001, when the unit began decreasing power to repair steam generator riser ring leak. The unit was taken off-line at 0357. The unit was placed on-line 02/27/99 at 0105. During power escalation, the unit held at 30% power from 02/27/99 at 0301 to 0520 due to nuclear instrumentation calibration. The unit held at 40% power from 0621 to 1101 to place "D" heater drain and "2B" main feedwater pumps inservice. The unit held at 65% power from 1241 to 1255 for nuclear instrumentation calibration check. The unit returned to 100% full power on 02/27/99 at 2150. On 02/28/99 at 1607 the unit began decreasing power to investigate main steam pressure hi/lo statalarm. On 02/28/99 at 2041 the unit experienced a turbine/reactor trip due to main turbine control valves ramping closed. The unit was in the outage the remainder of the month.

(1) Reason

A - Equipment failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction

E - Operator Training/License Examination
 F - Administrative
 G - Operator Error (Explain)
 H - Other (Explain)

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: November 1999
3. Scheduled restart following refueling: December 1999

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies

(a) in the core: 177

(b) in the spent fuel pool: 1094*

(c) in the ISFSI: See unit 1 ****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: October 2013***

DUKE POWER COMPANY

DATE: March 15, 1999

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

- | | |
|------|---|
| * | Represents the combined total for Units 1 and 2 |
| ** | See footnote on Unit 1 |
| *** | This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as needed basis. |
| **** | See footnote on Unit 1 |

Operating Data Report

Docket No.	50-287
Date	March 11, 1999
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: February 1, 1999 - February 28, 1999
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

-
9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason for Restrictions, If any: _____
-

	This Month	YTD	Cumulative
11. Hours in Reporting Period	672.0	1416.0	212184.0
12. Number of Hours Reactor was Critical	672.0	1390.1	164751.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	672.0	1381.1	162335.9
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1694264	3493918	404522146
17. Gross Electrical Energy Generated (MWH)	604870	1234873	139751914
18. Net Electrical Energy Generated (MWH)	580629	1183380	133276031
19. Unit Service Factor	100.0	97.5	76.5
20. Unit Availability Factor	100.0	97.5	76.5
21. Unit Capacity Factor (Using MDC Net)	102.1	98.8	73.5
22. Unit Capacity Factor (Using DER Net)	97.5	94.3	70.9
23. Unit Forced Outage Rate	0.0	2.5	10.4
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-287UNIT NAME: Oconee 3DATE: March 15, 1999COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: February, 1999

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: April 2000
3. Scheduled restart following refueling: May 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
 - (a) in the core: 177
 - (b) in the spent fuel pool: 612
 - (c) in the ISFSI: See Unit 1 ****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: July 2014***

DUKE POWER COMPANY

DATE: March 15, 1999

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

** See footnote of Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 48-modules (1152 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1