

● Operating Data Report ●

Docket No.	50-269
Date	July 14, 1999
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: June 1, 1999 - June 30, 1999
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

-
9. Power Level To Which Restricted, If Any (Net MWe): _____
 10. Reason for Restrictions, If any: _____
-

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	4343.0	227544.0
12. Number of Hours Reactor was Critical	0.0	3337.0	175644.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	0.0	3335.2	172565.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0	8522474	425029078
17. Gross Electrical Energy Generated (MWH)	0	2980719	146904479
18. Net Electrical Energy Generated (MWH)	0	2848285	139632546
19. Unit Service Factor	0.0	76.8	75.9
20. Unit Availability Factor	0.0	76.8	75.9
21. Unit Capacity Factor (Using MDC Net)	0.0	77.5	71.8
22. Unit Capacity Factor (Using DER Net)	0.0	74.0	69.3
23. Unit Forced Outage Rate	0.0	0.0	10.0
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

9907200154 990714
 PDR ADOCK 05000269
 R PDR

3A - 7/14/99

UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME: Oconee 1DATE: July 14, 1999COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: June, 1999

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	06/01/99	S	720.00	C	4		END-OF-CYCLE 18 REFUELING OUTAGE

Summary:

Oconee Unit 1 began the month of June in end-of-cycle 18 refueling outage. The unit was in the refueling outage the remainder of the month.

(1) Reason

A - Equipment failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction

E - Operator Training/License Examination
 F - Administrative
 G - Operator Error (Explain)
 H - Other (Explain)

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: Currently Refueling
3. Scheduled restart following refueling: July 1999

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies

(a)	in the core: <u>177</u>
(b)	in the spent fuel pool: <u>1058*</u>
(c)	in the ISFSI: <u>1056****</u>
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: March 2013***

DUKE POWER COMPANY

DATE: July 14, 1999

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** On March 29, 1990, received a license for ISFSI which will store 2112 assemblies

*** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as-needed basis.

**** Represents the combined total for Units 1, 2, and 3

Operating Data Report

Docket No.	50-270
Date	July 14, 1999
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: June 1, 1999 - June 30, 1999
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

-
9. Power Level To Which Restricted, If Any (Net MWe): _____
 10. Reason for Restrictions, If any: _____
-

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	4343.0	217464.0
12. Number of Hours Reactor was Critical	631.0	4135.3	173177.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	620.2	4105.2	170861.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1572849	19000530	428401074
17. Gross Electrical Energy Generated (MWH)	550229	3676936	144043867
18. Net Electrical Energy Generated (MWH)	523927	3516601	137190899
19. Unit Service Factor	86.1	94.5	78.6
20. Unit Availability Factor	86.1	94.5	78.6
21. Unit Capacity Factor (Using MDC Net)	86.0	95.7	73.8
22. Unit Capacity Factor (Using DER Net)	82.1	91.4	71.2
23. Unit Forced Outage Rate	13.9	5.5	9.8
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

Page: 1 of 1

DOCKET NO. 50-270

UNIT NAME: Oconee 2

DATE: July 14, 1999

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: June, 1999

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
3	06/19/99	F	99.85	A	3		REACTOR/TURBINE TRIP DUE TO MOISTURE SEPARATOR DRAIN TANK HIGH LEVEL ALARM

Summary:

Oconee Unit 2 began the month of June operating at 100% full power. The unit operated at or near 100% full power until 06/19/99 at 0030 when the unit began decreasing power and held at 68% power on 06/19/99 from 0218 to 1015 to investigate/repair '2A1' reactor coolant pump low oil level. The unit experienced an reactor/turbine trip on 06/19/99 at 1015 due to moisture separator drain tank high level alarm. The unit was placed on-line 06/23/99 at 1406 holding at 15% power for reactor coolant system boron update. The unit began increasing power on 06/23/99 at 1512. On 06/23/99 from 1540 to 1543 the unit held at 20% power and from 1650 to 1705 at 30% power due to nuclear instrumentation calibration checks. The unit held at 50% power from 1833 to 2020 to place 2nd main feedwater pump inservice and for shift turnover. The unit held at 65% power on 06/23/99 from 2200 to 2225 and at 95% power on 06/24/99 from 0106 to 0238 due to nuclear instrumentation calibration check. On 06/24/99 at 0305 the unit began decreasing power and held at 91% power from 0314 to 0624 due to reduce high turbine header pressure. The unit returned to 100% full power on 06/24/99 at 0709 and operated at or near 100% full power the remainder of the month.

(1) Reason

A - Equipment failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory restriction

E - Operator Training/License Examination
F - Administrative
G - Operator Error (Explain)
H - Other (Explain)

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: November 1999
3. Scheduled restart following refueling: December 1999

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies

(a)	in the core: <u>177</u>
(b)	in the spent fuel pool: <u>1058*</u>
(c)	in the ISFSI: <u>See unit 1 ****</u>
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: October 2013***

DUKE POWER COMPANY

DATE: July 14, 1999

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

Operating Data Report

Docket No.	50-287
Date	July 14, 1999
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: June 1, 1999 - June 30, 1999
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

-
9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason for Restrictions, If any: _____
-

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	4343.0	215111.0
12. Number of Hours Reactor was Critical	720.0	4273.9	167635.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	4259.4	165214.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1848960	29865020	430893248
17. Gross Electrical Energy Generated (MWH)	645752	3817971	142335012
18. Net Electrical Energy Generated (MWH)	618698	3657521	135750172
19. Unit Service Factor	100.0	98.1	76.8
20. Unit Availability Factor	100.0	98.1	76.8
21. Unit Capacity Factor (Using MDC Net)	101.6	99.5	73.9
22. Unit Capacity Factor (Using DER Net)	97.0	95.1	71.2
23. Unit Forced Outage Rate	0.0	0.8	10.2
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-287UNIT NAME: Oconee 3DATE: July 14, 1999COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: June, 1999

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: April 2000
3. Scheduled restart following refueling: May 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies

(a)	in the core: <u>177</u>
(b)	in the spent fuel pool: <u>612</u>
(c)	in the ISFSI: <u>See Unit 1 ****</u>
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: July 2014***

DUKE POWER COMPANY

DATE: July 14, 1999

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

** See footnote of Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 48 modules (1152 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1