

SummerRAIsPEm Resource

From: McGovern, Denise
Sent: Thursday, April 23, 2015 4:01 PM
To: SummerRAIsPEm Resource
Subject: VC Summer LAR 14-03 Follow-up Public Meeting May 7 - 2015.docx
Attachments: VC Summer LAR 14-03 Follow-up Public Meeting May 7 - 2015.docx

Hearing Identifier: Summer_COL_eRAIs
Email Number: 114

Mail Envelope Properties (2BE05B77CE8C0F4B976DC472236ABD342673274236)

Subject: VC Summer LAR 14-03 Follow-up Public Meeting May 7 - 2015.docx
Sent Date: 4/23/2015 4:00:59 PM
Received Date: 4/23/2015 4:01:01 PM
From: McGovern, Denise

Created By: Denise.McGovern@nrc.gov

Recipients:
"SummerRAIsPEm Resource" <SummerRAIsPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time	
MESSAGE	3	4/23/2015 4:01:01 PM	
VC Summer LAR 14-03 Follow-up Public Meeting May 7 - 2015.docx			22118

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Meeting Material for May 7, 2015 Public Meeting:

VC Summer LAR 14-03 Follow-up RAI

When evaluating LAR 14-03 for a proposed Tier 2* modification to UFSAR Section 5.2.1.1, "Compliance with 10 CFR 50.55a," related to the portion of the chemical volume and control system (CVS) inside containment with an ASME B31.1 classification at VC Summer Units 2 and 3, the NRC staff requested in RAI 7671 that the licensee address where the operation and maintenance provisions in Chapter VII of the 2007 version of the ASME B31.1 Code are addressed in the 1989 version of the ASME B31.1 Code. In its response dated November 21, 2014, the licensee refers to the requirement in UFSAR Section 5.2.1.1 that inservice inspection (ISI) of the reactor coolant pressure boundary (RCPB) is conducted in accordance with the applicable edition and addenda of the ASME *Boiler and Pressure Vessel Code* (BPV Code), Section XI, as described in UFSAR Section 5.2.4, "Inservice Inspection and Testing of Class 1 Components." The licensee also refers to the requirement in UFSAR Section 5.2.1.1 that inservice testing (IST) of RCPB components is performed in accordance with the edition and addenda of the ASME *Code for Operation and Maintenance of Nuclear Power Plants* (OM Code) as discussed in Section 3.9.6, "Inservice Testing of Pumps and Valves," and Section 3.9.3.4.4, "Inspection, Testing, Repair, and/or Replacement of Snubbers." The licensee indicates that operation and maintenance requirements are not prescribed in ASME B31.1, but rather addressed in the ASME BPV Code, Section XI, and ASME OM Code. The staff requests that the licensee clarify its response to RAI 7671 by specifying the operation and maintenance requirements that will be applied to the portion of the CVS inside containment with the ASME B31.1 classification.