

Draft for Comment



U.S. NUCLEAR REGULATORY COMMISSION **DESIGN-SPECIFIC REVIEW STANDARD FOR NuScale SMR DESIGN**

6.2.1 CONTAINMENT FUNCTIONAL DESIGN

REVIEW RESPONSIBILITIES

Primary - Organization responsible for the review of Containment Integrity

Secondary - None

I. AREAS OF REVIEW

NuScale is an integral pressurized water, small modular reactor (SMR) with the reactor, steam generator, pressurizer, and control rod drives all located in a single pressure vessel. The NuScale reactor containment is an evacuated, low alloy steel vessel surrounding the smaller reactor vessel and immersed in a bay of a large, borated, reactor building pool that serves as the passive ultimate heat sink for containment heat removal.

The responsible staff reviews information regarding the functional capability of the reactor containment presented in Design Specific Review Standard (DSRS) Section 6.2.1 of the applicant's application. The containment encloses the reactor system and is the final barrier against the release of significant amounts of radioactive fission products in the event of an accident. The containment structure must be capable of withstanding, without loss of function, the pressure and temperature conditions resulting from postulated loss-of-coolant (LOCA), steam line, or feedwater line break accidents. The containment structure must also maintain functional integrity in the long term following a postulated accident; i.e., it must remain a low leakage barrier against the release of fission products for as long as postulated accident conditions require. The containment structure must be able to withstand postulated hydraulic forces caused by being immersed in the reactor building pool and from flooding and tsunami hazards.

The design and sizing of containment systems are largely based on the pressure and temperature conditions which result from release of the reactor coolant in the event of a LOCA. The containment design basis includes the effects of stored energy in the reactor coolant system, decay energy, and energy from other sources such as the secondary system, and metal-water reactions including the recombination of hydrogen and oxygen. The containment system is not required to be a complete and independent safeguard against a LOCA by itself, but functions to contain any fission products released while the emergency core cooling system (ECCS) cools the reactor core.

The evaluation of a containment functional design includes calculation of the various effects associated with the postulated rupture in the primary or secondary coolant system piping. The subsequent thermodynamic effects in the containment resulting from the release of the coolant mass and energy are determined from a solution of the incremental space and time-dependent energy, mass, and momentum conservation equations. The basic functional design requirements for containment are given in General Design Criteria (GDC) 4, 16 and 50 in Appendix A to Title 10 of *Code of Federal Regulations* (10 CFR) Part 50, and in 10 CFR Part 50, Appendix K. GDC 4 provides the basic environmental and dynamic effects design requirements

for all structures, systems, and components important to safety including leak-before-break. GDC 16 establishes the fundamental requirement to design a containment that is essentially a leak-tight barrier against the uncontrolled release of radioactivity to the environment. GDC 50, among other things, requires that consideration be given to the potential consequences of degraded engineered safety features, such as the containment heat removal system and the emergency core cooling system, the limitations in defining accident phenomena, and the conservatism of calculation models and input parameters in assessing containment design margins. 10 CFR Part 50 Appendix K.I.D.2 requires that the containment pressure used for evaluating cooling effectiveness during reflood and spray cooling shall not exceed a pressure calculated conservatively for this purpose. 10 CFR 50 Appendix K.I.A provides the sources of energy that are required and acceptable to be included in determining the mass and energy release from loss-of-coolant accidents and ~~SMR~~ secondary systems pipe ruptures.

The various aspects to be reviewed under this DSRS section have been separated and assigned to a set of other Standard Review Plan (SRP) and DSRS sections as follows:

1. NuScale SMR evacuated containment (DSRS Section 6.2.1.1A).
2. Subcompartment analysis (SRP Section 6.2.1.2).
3. Mass and energy release analysis for postulated loss-of-coolant accidents (DSRS Section 6.2.1.3).
4. Mass and energy release analysis for postulated secondary system pipe ruptures (DSRS Section 6.2.1.4).
5. Minimum containment pressure analysis for emergency core cooling system (ECCS) performance capability studies (SRP Section 6.2.1.5).

Areas related to the evaluation of the containment functional capability are treated in other DSRS sections; e.g., Containment Heat Removal (DSRS Section 6.2.2), Containment Isolation System (DSRS Section 6.2.4), Combustible Gas Control (DSRS Section 6.2.5), and Containment Leakage Testing (DSRS Section 6.2.6). In addition, the evaluation of the secondary containment functional design capability is reviewed in SRP Section 6.2.3 even though the NuScale SMR design does not credit secondary containment functions.

The specific areas of review are described in the "Areas of Review" subsections of the five SRP and DSRS sections listed above.

Review Interfaces:

Other SRP and DSRS sections interface with this section as follows:

1. The review of effects of static and dynamic hydraulic forces on containment caused by tsunami hazards under SRP Section 2.4.6.
2. The review of flooding protection measures under DSRS Section 2.4.10.
3. The review of effects of groundwater on the underground containment structure, including effects of groundwater levels, piezometric/hydraulic heads and other hydrodynamic effects of groundwater on the design bases of subsurface safety-related SSCs under DSRS Section 2.4.12.

4. The review of areas relating to concrete and steel internal structures of steel/concrete containments under SRP Section 3.8.3.
5. The review of areas relating to steel containments or to other Class MC steel portions of steel/concrete containments under DSRS Section 3.8.2.
6. Determination of SSC risk significance under SRP Section 19.0.

II. ACCEPTANCE CRITERIA

Requirements

Acceptance criteria are given in the "Acceptance Criteria" subsections of the SRP and DSRS sections listed above.

DSRS Acceptance Criteria

Specific DSRS acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are set forth below. The DSRS is not a substitute for the NRC's regulations, and compliance with it is not required. As an alternative, and as described in more detail below, an applicant may identify the differences between a DSRS section and the design features (DC and COL applications only), analytical techniques, and procedural measures proposed in an application and discuss how the proposed alternative provides an acceptable method of complying with the NRC regulations that underlie the DSRS acceptance criteria.

III. EVALUATION FINDINGS

The reviewer verifies that the applicant has provided sufficient information and that the staff's technical review and analysis, as augmented by the application of programmatic requirements in accordance with the staff's technical review approach in the DSRS Introduction, support conclusions of the following type to be included in the staff's safety evaluation report. The reviewer also states the bases for those conclusions.

1. Containment Functional Design

The scope of review of the functional design of the containment for the NuScale nuclear power plant design has included a review of plant arrangement drawings, system drawings, and descriptive information for the containment building, subcompartments, and associated systems, components, and structures that are essential to the functional capability and integrity of the containment. The review has included the applicant's proposed design bases for the containment building and internal structures, and associated structures and systems upon which the containment function depends, and the applicant's analysis of postulated accidents and operational occurrences which support the adequacy of the design bases.

The basis for the staff's acceptance has been conformance of designs and design bases for the containment building, internal structures, and associated systems, components, and structures to the Commission's regulations as set forth in the general design criteria, and to applicable regulatory guides, branch technical positions, and industry codes and standards. (Special problems or exceptions that the staff takes to the design or functional capability of containment structures, systems, and components should be discussed.)

To support the basis for the staff's acceptance of the containment system, the reviewer of the containment system should include in the staff's safety evaluation report, as necessary, the results of the reviews for the five SRP and DSRS sections above. The SER write-up should demonstrate conformance with the Commission regulations in the manner indicated. The staff concludes that the containment functional design is acceptable and meets the requirements of General Design Criteria 4, 16, 50 and 10 CFR Part 50 Appendix K. The conclusion is based on the following: [The reviewer should discuss each item of the regulations or related set of regulations as indicated.]

2. The applicant has met the requirements of (cite regulation) with respect to (state limits of review in relation to regulation) by (for each item that is applicable to the review, state how it was met and why it is acceptable with respect to regulation being discussed):
 - A. meeting the regulatory positions in Regulatory Guide _____ or Guides;
 - B. providing and meeting an alternative method to regulatory positions in Regulatory Guide _____, that the staff has reviewed and found to be acceptable because _____;
 - C. meeting the regulatory position in the branch technical position (BTP);
 - D. using calculation methods for (state what was evaluated) that have previously been reviewed by the staff and found acceptable; the staff has reviewed the impact parameters in this case and found them to be suitably conservative or performed independent calculations to verify acceptability of their analysis; and/or
 - E. meeting the provisions of (industry standard number and title) that has been reviewed by the staff and determined to be appropriate for this application.
3. Repeat discussion for each regulation cited above.
4. The temperature/pressure profiles provided in the applicant's technical submittal for the spectrum of LOCA and main steam line break accidents are acceptable for use in equipment qualification, i.e., there is reasonable assurance that the actual temperatures and pressures for the postulated accidents will not exceed these profiles anywhere within the specified environmental zones, except in the break zone.

IV. IMPLEMENTATION

The regulations in 10 CFR 52.17(a)(1)(xii), 10 CFR 52.47(a)(9), and 10 CFR 52.79(a)(41) establish requirements for applications for ESPs, DCs, and COLs, respectively. These regulations require the application to include an evaluation of the site (ESP), standard plant design (DC), or facility (COL) against the Standard Review Plan (SRP) revision in effect six months before the docket date of the application. While the SRP provides generic guidance, the staff developed the SRP guidance based on the staff's experience in reviewing applications for construction permits and operating licenses for large light-water nuclear power reactors. The proposed small modular reactor (SMR) designs, however, differ significantly from large light-water nuclear reactor power plant designs.

In view of the differences between the designs of SMRs and the designs of large light-water power reactors, the Commission issued SRM- COMGBJ-10-0004/COMGEA-10-0001, "Use of Risk Insights to Enhance the Safety Focus of Small Modular Reactor Reviews," dated August 31,

2010 (ML102510405) (SRM). In the SRM, the Commission directed the staff to develop risk-informed licensing review plans for each of the SMR design reviews, including plans for the associated pre-application activities. Accordingly, the staff has developed the content of the DSRS as an alternative method for the evaluation of a NuScale-specific application submitted pursuant to 10 CFR Part 52, and the staff has determined that each application may address the DSRS in lieu of addressing the SRP, with specified exceptions. These exceptions include particular review areas in which the DSRS directs reviewers to consult the SRP and others in which the SRP is used for the review. If an applicant chooses to address the DSRS, the application should identify and describe all differences between the design features (DC and COL applications only), analytical techniques, and procedural measures proposed in an application and the guidance of the applicable DSRS section (or SRP section as specified in the DSRS), and discuss how the proposed alternative provides an acceptable method of complying with the regulations that underlie the DSRS acceptance criteria.

The staff has accepted the content of the DSRS as an alternative method for evaluating whether an application complies with NRC regulations for NuScale SMR applications, provided that the application does not deviate significantly from the design and siting assumptions made by the NRC staff while preparing the DSRS. If the design or siting assumptions in a NuScale application deviate significantly from the design and siting assumptions the staff used in preparing the DSRS, the staff will use the more general guidance in the SRP as specified in 10 CFR 52.17(a)(1)(xii), 10 CFR 52.47(a)(9), or 10 CFR 52.79(a)(41), depending on the type of application. Alternatively, the staff may supplement the DSRS section by adding appropriate criteria in order to address new design or siting assumptions.

VI. REFERENCES

1. 10 CFR Part 20, "Standards for Protection Against Radiation."
2. 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities."
3. 10 CFR Part 52, "Early Site Permits; Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."
4. GDC 61, "Fuel Storage and Handling and Radioactivity Control."
5. GDC 19, "Control Room."
6. GDC 4, "Environmental and Dynamic Effects Design Bases."
7. RG 1.7, "Control of Combustible Gas Concentrations in Containment Following a Loss-of-Coolant Accident."
8. RG 1.112, "Calculations of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light-Water-Cooled Power Reactors."
9. RG 1.183, "Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors."
10. ANSI/ANS Standard 18.1-1999, "Source Term Specification," American National Standards Institute/American Nuclear Society."

11. NUREG-0737, "Clarification of TMI Action Plan Requirements."
12. 40 CFR Part 190, "Environmental Radiation Protection Standards For Nuclear Power Operations."
13. RG 1.89, "Environmental Qualification of Certain Electric Equipment Important to Safety for Nuclear Power Plants."
14. RG 1.143, "Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants."
15. RG 1.26, "Quality Group Classifications and Standards for Water-, Steam-, and Radioactive-Waste-Containing Components of Nuclear Power Plants."
16. RG 1.29, "Seismic Design Classification."
17. RG 1.117, "Tornado Design Classification."
18. RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."
19. EPRI, "Pressurized Water Reactor Primary Water Chemistry Guidelines."
20. EPRI, "Pressurized Water Reactor Primary Water Zinc Application Guidelines."
21. EPRI, "Advanced Light Water Reactor Utility Requirements Document, Volume III, ALWR Passive Plant."
22. NUREG-1242, "NRC Review of Electric Power Research Institute's Advanced Light Water Reactor Utility Requirements Document, Passive Plant Designs" Volume 3, Part 1 and Volume 3, Part 2 (ADAMS Accession Nos. ML070600372 and ML070600373).
23. EPRI, "Cobalt Reduction Guidelines."
24. RG 8.8, "Information Relevant to Assuring that Occupational Radiation Exposures at Nuclear Power Stations Will Be as Low as is Reasonably Achievable."