



**Pacific Gas and
Electric Company®**

James M. Welsch
Site Vice President

Diablo Canyon Power Plant
Mail Code 104/6
P. O. Box 56
Avila Beach, CA 93424

805.545.3242
Internal: 691.3242
Fax: 805.545.4884

May 7, 2015

PG&E Letter DCL-15-062

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

10 CFR 50.73

Docket No. 50-275, OL-DPR-80
Diablo Canyon Power Plant, Unit 1
Expected Submittal Date for Licensee Event Report 2015-001-01

Reference: Licensee Event Report 2015-001-00, "Both Trains of Residual Heat Removal Inoperable Due to Circumferential Crack on a Socket Weld," dated March 2, 2015 (ADAMS Accession No. ML15061A548)

Dear Commissioners and Staff:

In the above reference, Pacific Gas and Electric Company (PG&E) submitted a Licensee Event Report (LER) for Unit 1 regarding both trains of residual heat removal being inoperable as the result of seepage from a socket weld. In the referenced letter, PG&E indicated that it would provide an LER supplement by May 8, 2015, which would include the event cause and corrective action upon completion of the root cause evaluation.

PG&E is still performing detailed analysis necessary to complete the root cause evaluation. This analysis will require data to be gathered during the next Unit 1 refueling outage scheduled for October 2015. Based on the current plan for completion, PG&E will submit the LER supplement no later than January 28, 2016.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this letter.

Sincerely,

NIMICK FOR WELSCH

James M. Welsch

aph8/6470/50680117

cc: Marc L. Dapas, NRC Region IV Administrator
Thomas R. Hipschman, NRC Senior Resident Inspector
Siva P. Lingam, NRR Project Manager
INPO
Diablo Distribution