

MANUAL HARD COPY DISTRIBUTION
DOCUMENT TRANSMITTAL 2015-18560

USER INFORMATION:

GERLACH*ROSEY M EMPL#: 028401 CA#: 0363
Address: NUCSA2
Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO: GERLACH*ROSEY M 04/29/2015

LOCATION: USNRC

FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)

THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.

ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TRM2 - TECHNICAL REQUIREMENTS MANUAL UNIT 2

REMOVE MANUAL TABLE OF CONTENTS DATE: 04/14/2015

ADD MANUAL TABLE OF CONTENTS DATE: 04/28/2015

CATEGORY: DOCUMENTS TYPE: TRM2

A001
NRK

ID: TEXT 3.2.1

ADD: REV: 11

REMOVE: REV:10

CATEGORY: DOCUMENTS TYPE: TRM2

ID: TEXT LOES

ADD: REV: 85

REMOVE: REV:84

CATEGORY: DOCUMENTS TYPE: TRM2

ID: TEXT TOC

REMOVE: REV:23

ADD: REV: 24

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 3 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

SSS MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

Table Of Contents

Issue Date: 04/28/2015

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES	85	04/28/2015		
Title: LIST OF EFFECTIVE SECTIONS				
TEXT TOC	24	04/28/2015		
Title: TABLE OF CONTENTS				
TEXT 1.1	0	11/19/2002		
Title: USE AND APPLICATION DEFINITIONS				
TEXT 2.1	1	02/04/2005		
Title: PLANT PROGRAMS AND SETPOINTS PLANT PROGRAMS				
TEXT 2.2	11	01/31/2014		
Title: PLANT PROGRAMS AND SETPOINTS INSTRUMENT TRIP SETPOINT TABLE				
TEXT 3.0	6	03/05/2015		
Title: APPLICABILITY TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY				
TEXT 3.1.1	1	11/09/2007		
Title: REACTIVITY CONTROL SYSTEMS ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION				
TEXT 3.1.2	0	11/19/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD DRIVE (CRD) HOUSING SUPPORT				
TEXT 3.1.3	4	05/14/2009		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD BLOCK INSTRUMENTATION				
TEXT 3.1.4	0	11/19/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE				
TEXT 3.2.1	11	04/28/2015		
Title: CORE OPERATING LIMITS CORE OPERATING LIMITS REPORT (COLR)				

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.3.1	0	11/19/2002
Title: INSTRUMENTATION RADIATION MONITORING INSTRUMENTATION		
TEXT 3.3.2	3	03/31/2011
Title: INSTRUMENTATION SEISMIC MONITORING INSTRUMENTATION		
TEXT 3.3.3	2	11/09/2007
Title: INSTRUMENTATION METEOROLOGICAL MONITORING INSTRUMENTATION		
TEXT 3.3.4	7	03/05/2015
Title: INSTRUMENTATION TRM POST-ACCIDENT MONITORING INSTRUMENTATION		
TEXT 3.3.5	0	11/19/2002
Title: INSTRUMENTATION THIS PAGE INTENTIONALLY LEFT BLANK		
TEXT 3.3.6	4	04/29/2014
Title: INSTRUMENTATION TRM ISOLATION ACTUATION INSTRUMENTATION		
TEXT 3.3.7	1	11/09/2007
Title: INSTRUMENTATION MAIN TURBINE OVERSPEED PROTECTION SYSTEM		
TEXT 3.3.8	1	10/22/2003
Title: INSTRUMENTATION TRM RPS INSTRUMENTATION		
TEXT 3.3.9	3	05/14/2009
Title: INSTRUMENTATION LPRM UPSCALE ALARM INSTRUMENTATION		
TEXT 3.3.10	1	12/14/2004
Title: INSTRUMENTATION REACTOR RECIRCULATION PUMP MG SET STOPS		
TEXT 3.3.11	1	10/22/2003
Title: INSTRUMENTATION MVP ISOLATION INSTRUMENTATION		
TEXT 3.3.12	1	03/05/2015
Title: WATER MONITORING INSTRUMENTATION		

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.4.1 1 04/26/2006

Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM CHEMISTRY

TEXT 3.4.2 1 04/16/2009

Title: REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY

TEXT 3.4.3 1 11/09/2007

Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM (RCS)

TEXT 3.4.4 2 05/14/2009

Title: REACTOR COOLANT SYSTEM REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT

TEXT 3.4.5 1 04/26/2006

Title: REACTOR COOLANT SYSTEM REACTOR VESSEL MATERIALS

TEXT 3.4.6 1 04/25/2013

Title: REACTOR RECIRCULATION SINGLE LOOP OPERATION SLO FLOW RATE RESTRICTION

TEXT 3.5.1 1 02/04/2005

Title: ECCS AND RCIC ADS MANUAL INHIBIT

TEXT 3.5.2 1 11/09/2007

Title: ECCS AND RCIC ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION

TEXT 3.5.3 0 11/19/2002

Title: ECCS AND RCIC LONG TERM NITROGEN SUPPLY TO ADS

TEXT 3.6.1 0 11/19/2002

Title: CONTAINMENT VENTING OR PURGING

TEXT 3.6.2 2 04/29/2014

Title: SUPPRESSION CHAMBER TO DRYWELL VACUUM BREAKER POSITION INDICATION

TEXT 3.6.3 0 11/19/2002

Title: CONTAINMENT SUPPRESSION POOL ALARM INSTRUMENTATION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.6.4 0 11/19/2002
Title: CONTAINMENT PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES

TEXT 3.7.1 0 11/19/2002
Title: PLANT SYSTEMS EMERGENCY SERVICE WATER SYSTEM (ESW) SHUTDOWN

TEXT 3.7.2 0 11/19/2002
Title: PLANT SYSTEMS ULTIMATE HEAT SINK (UHS) AND GROUND WATER LEVEL

TEXT 3.7.3.1 2 04/16/2009
Title: PLANT SYSTEMS FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT 3.7.3.2 3 04/16/2009
Title: PLANT SYSTEMS SPRAY AND SPRINKLER SYSTEMS

TEXT 3.7.3.3 3 04/16/2009
Title: PLANT SYSTEMS CO2 SYSTEMS

TEXT 3.7.3.4 2 04/16/2009
Title: PLANT SYSTEMS HALON SYSTEMS

TEXT 3.7.3.5 2 04/16/2009
Title: PLANT SYSTEMS FIRE HOSE STATIONS

TEXT 3.7.3.6 2 04/16/2009
Title: PLANT SYSTEMS YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT 3.7.3.7 1 04/26/2006
Title: PLANT SYSTEMS FIRE RATED ASSEMBLIES

TEXT 3.7.3.8 11 09/27/2012
Title: PLANT SYSTEMS FIRE DETECTION INSTRUMENTATION

TEXT 3.7.4 1 04/26/2006
Title: PLANT SYSTEMS SOLID RADWASTE SYSTEM

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.5.1 1 03/05/2015

Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT 3.7.5.2 0 11/19/2002

Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

TEXT 3.7.5.3 1 04/26/2006

Title: PLANT SYSTEMS LIQUID HOLDUP TANKS

TEXT 3.7.6 3 06/04/2012

Title: PLANT SYSTEMS ESSW PUMPHOUSE VENTILATION

TEXT 3.7.7 2 09/05/2008

Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION
MONITORING INSTRUMENTATION

TEXT 3.7.8 9 03/05/2015

Title: PLANT SYSTEMS SNUBBERS

TEXT 3.7.9 1 08/28/2006

Title: PLANT SYSTEMS CONTROL STRUCTURE HVAC

TEXT 3.7.10 2 04/29/2014

Title: PLANT SYSTEMS SPENT FUEL STORAGE POOLS (SFSPS)

TEXT 3.7.11 1 10/02/2009

Title: PLANT SYSTEMS

TEXT 3.8.1 3 06/20/2012

Title: ELECTRICAL POWER PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT
PROTECTIVE DEVICES

TEXT 3.8.2.1 2 11/09/2007

Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION -
CONTINUOUS

TEXT 3.8.2.2 2 12/14/2004

Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION -
AUTOMATIC

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.8.3 2 06/20/2012

Title: ELECTRICAL POWER DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

TEXT 3.8.4 1 02/04/2005

Title: ELECTRICAL POWER 24 VDC ELECTRICAL SUBSYSTEM

TEXT 3.8.5 1 11/14/2013

Title: ELECTRICAL POWER DEGRADED VOLTAGE PROTECTION

TEXT 3.8.6 2 12/14/2006

Title: ELECTRICAL POWER EMERGENCY SWITCHGEAR ROOM COOLING

TEXT 3.8.7 2 10/22/2009

Title: BATTERY MAINTENANCE AND MONITORING PROGRAM

TEXT 3.9.1 0 11/19/2002

Title: REFUELING OPERATIONS DECAY TIME

TEXT 3.9.2 0 11/19/2002

Title: REFUELING OPERATIONS COMMUNICATIONS

TEXT 3.9.3 0 11/19/2002

Title: REFUELING OPERATIONS REFUELING PLATFORM

TEXT 3.10.1 1 04/26/2006

Title: MISCELLANEOUS SEALED SOURCE CONTAMINATION

TEXT 3.10.2 1 04/09/2007

Title: MISCELLANEOUS SHUTDOWN MARGIN TEST RPS INSTRUMENTATION

TEXT 3.10.3 2 06/15/2010

Title: MISCELLANEOUS INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)

TEXT 3.11.1.1 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS CONCENTRATION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.1.2 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS DOSE

TEXT 3.11.1.3 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS LIQUID WASTE TREATMENT SYSTEM

TEXT 3.11.1.4 2 10/09/2012

Title: RADIOACTIVE EFFLUENTS LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION

TEXT 3.11.1.5 3 03/05/2015

Title: RADIOACTIVE EFFLUENTS RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION

TEXT 3.11.2.1 3 04/26/2006

Title: RADIOACTIVE EFFLUENTS DOSE RATE

TEXT 3.11.2.2 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS DOSE - NOBLE GASES

TEXT 3.11.2.3 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATE FORM

TEXT 3.11.2.4 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS GASEOUS RADWASTE TREATMENT SYSTEM

TEXT 3.11.2.5 4 07/03/2013

Title: RADIOACTIVE EFFLUENTS VENTILATION EXHAUST TREATMENT SYSTEM

TEXT 3.11.2.6 5 03/05/2015

Title: RADIOACTIVE EFFLUENTS RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

TEXT 3.11.3 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS TOTAL DOSE

TEXT 3.11.4.1 4 03/05/2015

Title: RADIOACTIVE EFFLUENTS MONITORING PROGRAM

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.4.2 2 04/26/2006

Title: RADIOACTIVE EFFLUENTS LAND USE CENSUS

TEXT 3.11.4.3 1 04/26/2006

Title: RADIOACTIVE EFFLUENTS INTERLABORATORY COMPARISON PROGRAM

TEXT 3.12.1 0 11/19/2002

Title: LOADS CONTROL PROGRAM CRANE TRAVEL-SPENT FUEL STORAGE POOL

TEXT 3.12.2 4 04/17/2008

Title: LOADS CONTROL PROGRAM HEAVY LOADS REQUIREMENTS

TEXT 3.12.3 0 11/19/2002

Title: LOADS CONTROL PROGRAM LIGHT LOADS REQUIREMENTS

TEXT 4.1 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS ORGANIZATION

TEXT 4.2 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS REPORTABLE EVENT ACTION

TEXT 4.3 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS SAFETY LIMIT VIOLATION

TEXT 4.4 1 12/18/2008

Title: ADMINISTRATIVE CONTROLS PROCEDURES & PROGRAMS

TEXT 4.5 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS REPORTING REQUIREMENTS

TEXT 4.6 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS RADIATION PROTECTION PROGRAM

TEXT 4.7 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS TRAINING

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.0	6	03/05/2015	Title: APPLICABILITY BASES TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY
TEXT B3.1.1	2	04/29/2014	Title: REACTIVITY CONTROL SYSTEM BASES ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION
TEXT B3.1.2	0	11/19/2002	Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD DRIVE (CRD) HOUSING SUPPORT
TEXT B3.1.3	3	04/10/2007	Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD BLOCK INSTRUMENTATION
TEXT B3.1.4	0	11/19/2002	Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE
TEXT B3.2.1	0	11/19/2002	Title: CORE OPERATING LIMITS BASES CORE OPERATING LIMITS REPORT (COLR)
TEXT B3.3.1	1	01/31/2014	Title: INSTRUMENTATION BASES RADIATION MONITORING INSTRUMENTATION
TEXT B3.3.2	2	03/31/2011	Title: INSTRUMENTATION BASES SEISMIC MONITORING INSTRUMENTATION
TEXT B3.3.3	2	11/09/2007	Title: INSTRUMENTATION BASES METEOROLOGICAL MONITORING INSTRUMENTATION
TEXT B3.3.4	4	07/09/2010	Title: INSTRUMENTATION BASES TRM POST ACCIDENT MONITORING (PAM) INSTRUMENTATION
TEXT B3.3.5	2	11/09/2007	Title: INSTRUMENTATION BASES THIS PAGE INTENTIONALLY LEFT BLANK
TEXT B3.3.6	5	01/31/2014	Title: INSTRUMENTATION BASES TRM ISOLATION ACTUATION INSTRUMENTATION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.3.7 1 11/09/2007

Title: INSTRUMENTATION BASES MAIN TURBINE OVERSPEED PROTECTION SYSTEM

TEXT B3.3.8 1 10/22/2003

Title: INSTRUMENTATION BASES TRM RPS INSTRUMENTATION

TEXT B3.3.9 3 05/14/2009

Title: INSTRUMENTATION BASES LPRM UPSCALE ALARM INSTRUMENTATION

TEXT B3.3.10 3 02/22/2012

Title: INSTRUMENTATION BASES REACTOR RECIRCULATION PUMP MG SET STOPS

TEXT B3.3.11 1 10/22/2003

Title: INSTRUMENTATION BASES MVP ISOLATION INSTRUMENTATION

TEXT B3.3.12 0 04/16/2009

Title: WATER MONITORING INSTRUMENTATION

TEXT B3.4.1 0 11/19/2002

Title: REACTOR COOLANT SYSTEM BASES REACTOR COOLANT SYSTEM CHEMISTRY

TEXT B3.4.2 1 04/16/2009

Title: REACTOR COOLANT SYSTEM BASES STRUCTURAL INTEGRITY

TEXT B3.4.3 1 11/09/2007

Title: REACTOR COOLANT SYSTEM BASES HIGH/LOW PRESSURE INTERFACE LEAKAGE MONITOR

TEXT B3.4.4 0 11/19/2002

Title: REACTOR COOLANT SYSTEM BASES REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT

TEXT B3.4.5 0 11/19/2002

Title: REACTOR COOLANT SYSTEM BASES REACTOR VESSEL MATERIALS

TEXT B3.4.6 1 04/25/2013

Title: REACTOR RECIRCULATION SINGLE LOOP OPERATION SLO FLOW RATE RESTRICTION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.5.1 0 11/19/2002

Title: ECCS AND RCIC BASES ADS MANUAL INHIBIT

TEXT B3.5.2 1 11/09/2007

Title: ECCS AND RCIC BASES ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION

TEXT B3.5.3 1 11/09/2007

Title: ECCS AND RCIC BASES LONG TERM NITROGEN SUPPLY TO ADS

TEXT B3.6.1 0 11/19/2002

Title: CONTAINMENT BASES VENTING OR PURGING

TEXT B3.6.2 0 11/19/2002

Title: CONTAINMENT BASES SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION

TEXT B3.6.3 1 04/19/2007

Title: CONTAINMENT BASES SUPPRESSION POOL ALARM INSTRUMENTATION

TEXT B3.6.4 1 12/14/2004

Title: CONTAINMENT BASES PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES

TEXT B3.7.1 0 11/19/2002

Title: PLANT SYSTEMS BASES EMERGENCY SERVICE WATER SYSTEM (SHUTDOWN)

TEXT B3.7.2 0 11/19/2002

Title: PLANT SYSTEMS BASES ULTIMATE HEAT SINK (UHS) GROUND WATER LEVEL

TEXT B3.7.3.1 3 06/15/2010

Title: PLANT SYSTEMS BASES FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT B3.7.3.2 2 04/26/2006

Title: PLANT SYSTEMS BASES SPRAY AND SPRINKLER SYSTEMS

TEXT B3.7.3.3 0 11/19/2002

Title: PLANT SYSTEMS BASES CO2 SYSTEMS

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.3.4 2 04/29/2014

Title: PLANT SYSTEMS BASES HALON SYSTEMS

TEXT B3.7.3.5 1 04/26/2006

Title: PLANT SYSTEMS BASES FIRE HOSE STATIONS

TEXT B3.7.3.6 1 04/26/2006

Title: PLANT SYSTEMS BASES YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT B3.7.3.7 0 11/19/2002

Title: PLANT SYSTEMS BASES FIRE RATED ASSEMBLIES

TEXT B3.7.3.8 3 09/27/2012

Title: PLANT SYSTEMS BASES FIRE DETECTION INSTRUMENTATION

TEXT B3.7.4 0 11/19/2002

Title: PLANT SYSTEMS BASES SOLID RADWASTE SYSTEM

TEXT B3.7.5.1 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT B3.7.5.2 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

TEXT B3.7.5.3 0 11/19/2002

Title: PLANT SYSTEMS BASES LIQUID HOLDUP TANKS

TEXT B3.7.6 4 06/04/2013

Title: PLANT SYSTEMS BASES ESSW PUMPHOUSE VENTILATION

TEXT B3.7.7 2 01/31/2008

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION
MONITORING INSTRUMENTATION

TEXT B3.7.8 4 01/31/2014

Title: PLANT SYSTEMS BASES SNUBBERS

SSS MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.9 2 12/08/2011

Title: PLANT SYSTEMS BASES CONTROL STRUCTURE HVAC

TEXT B3.7.10 1 12/14/2004

Title: PLANT SYSTEMS BASES SPENT FUEL STORAGE POOLS

TEXT B3.7.11 2 04/14/2010

Title: STRUCTURAL INTEGRITY

TEXT B3.8.1 2 03/10/2010

Title: ELECTRICAL POWER BASES PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

TEXT B3.8.2.1 0 11/19/2002

Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS

TEXT B3.8.2.2 1 09/17/2004

Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC

TEXT B3.8.3 0 11/19/2002

Title: ELECTRICAL POWER BASES DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

TEXT B3.8.4 0 11/19/2002

Title: ELECTRICAL POWER BASES 24 VDC ELECTRICAL POWER SUBSYSTEM

TEXT B3.8.5 1 11/14/2013

Title: ELECTRICAL POWER BASES DEGRADED VOLTAGE PROTECTION

TEXT B3.8.6 3 06/20/2012

Title: ELECTRICAL POWER BASES EMERGENCY SWITCHGEAR ROOM COOLING

TEXT B3.8.7 2 06/04/2013

Title: BATTERY MAINTENANCE AND MONITORING PROGRAM

TEXT B3.9.1 0 11/19/2002

Title: REFUELING OPERATIONS BASES DECAY TIME

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.9.2 0 11/19/2002

Title: REFUELING OPERATIONS BASES COMMUNICATIONS

TEXT B3.9.3 0 11/19/2002

Title: REFUELING OPERATIONS BASES REFUELING PLATFORM

TEXT B3.10.1 0 11/19/2002

Title: MISCELLANEOUS BASES SEALED SOURCE CONTAMINATION

TEXT B3.10.2 1 04/10/2007

Title: MISCELLANEOUS BASES SHUTDOWN MARGIN TEST RPS INSTRUMENTATION

TEXT B3.10.3 0 11/19/2002

Title: MISCELLANEOUS BASES INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)

TEXT B3.11.1.1 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS CONCENTRATION

TEXT B3.11.1.2 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS DOSE

TEXT B3.11.1.3 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS BASES LIQUID WASTE TREATMENT SYSTEM

TEXT B3.11.1.4 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS BASES LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION

TEXT B3.11.1.5 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE LIQUID PROCESS MONITORING
INSTRUMENTATION

TEXT B3.11.2.1 1 12/14/2004

Title: RADIOACTIVE EFFLUENTS BASES DOSE RATE

TEXT B3.11.2.2 0 11/19/2002

Title: RADIOACTIVE EFFLUENTS BASES DOSE - NOBLE GASES

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.11.2.3	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATES FORM		
TEXT B3.11.2.4	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES GASEOUS RADWASTE TREATMENT SYSTEM		
TEXT B3.11.2.5	5	07/03/2013
Title: RADIOACTIVE EFFLUENTS BASES VENTILATION EXHAUST TREATMENT SYSTEM		
TEXT B3.11.2.6	1	01/27/2004
Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION		
TEXT B3.11.3	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES TOTAL DOSE		
TEXT B3.11.4.1	5	03/05/2015
Title: RADIOACTIVE EFFLUENTS BASES MONITORING PROGRAM		
TEXT B3.11.4.2	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES LAND USE CENSUS		
TEXT B3.11.4.3	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES INTERLABORATORY COMPARISON PROGRAM		
TEXT B3.12.1	1	10/04/2007
Title: LOADS CONTROL PROGRAM BASES CRANE TRAVEL-SPENT FUEL STORAGE POOL		
TEXT B3.12.2	1	12/03/2010
Title: LOADS CONTROL PROGRAM BASES HEAVY LOADS REQUIREMENTS		
TEXT B3.12.3	0	11/19/2002
Title: LOADS CONTROL PROGRAM BASES LIGHT LOADS REQUIREMENTS		

SUSQUEHANNA STEAM ELECTRIC STATION
TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 24

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	USE AND APPLICATION	1.0-1
1.1	Definitions	1.0-1
2.0	PLANT PROGRAMS AND SETPOINTS	2.0-1
2.1	Plant Programs	2.0-1
2.2	Instrument Trip Setpoint Table	TRM/2.0-5
3.0	APPLICABILITY	TRM/3.0-1
3.0	Technical Requirement for Operation (TRO) Applicability	TRM/3.0-1
3.0	Technical Requirement Surveillance (TRS) Applicability	TRM/3.0-3
3.1	REACTIVITY CONTROL SYSTEMS	TRM/3.1-1
3.1.1	Anticipated Transient Without Scram Alternate Rod Injection (ATWS-ARI) Instrumentation	TRM/3.1-1
3.1.2	Control Rod Drive (CRD) Housing Support	TRM/3.1-4
3.1.3	Control Rod Block Instrumentation	TRM/3.1-5
3.1.4	Control Rod Scram Accumulators Instrumentation and Check Valve	TRM/3.1-9
3.2	CORE OPERATING LIMITS REPORT	TRM/3.2-1
3.2.1	Core Operating Limits Report	TRM/3.2-1
3.3	INSTRUMENTATION	TRM/3.3-1
3.3.1	Radiation Monitoring Instrumentation	TRM/3.3-1
3.3.2	Seismic Monitoring Instrumentation	TRM/3.3-4
3.3.3	Meteorological Monitoring Instrumentation	TRM/3.3-7
3.3.4	TRM Post-Accident Monitoring Instrumentation	TRM/3.3-9
3.3.5	Section Not Used	TRM/3.3-12
3.3.6	TRM Isolation Actuation Instrumentation	TRM/3.3-13
3.3.7	Main Turbine Overspeed Protection System	TRM/3.3-17
3.3.8	Section Not Used	TRM/3.3-19
3.3.9	OPRM Instrumentation Configuration	TRM/3.3-21
3.3.10	Reactor Recirculation Pump MG Set Stops	TRM/3.3-22
3.3.11	MVP Isolation Instrumentation	TRM/3.3-24
3.3.12	Water Monitoring Instrumentation	TRM/3.3-26
3.4	REACTOR COOLANT SYSTEM	TRM/3.4-1
3.4.1	Reactor Coolant System Chemistry	TRM/3.4-1
3.4.2	Not Used	TRM/3.4-6
3.4.3	High/Low Pressure Interface Leakage Monitors	TRM/3.4-9
3.4.4	Reactor Recirculation Flow and Rod Line Limit	TRM/3.4-12
3.4.5	Reactor Vessel Materials	TRM/3.4-13
3.4.6	Reactor Recirculation Single Loop Operation (SLO) Flow Rate Restriction	TRM/3.4-14

SUSQUEHANNA STEAM ELECTRIC STATION
TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 24

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.5	EMERGENCY CORE COOLING AND RCIC	TRM/3.5-1
3.5.1	ADS Manual Inhibit	TRM/3.5-1
3.5.2	ECCS and RCIC System Monitoring Instrumentation	TRM/3.5-3
3.5.3	Long Term Nitrogen Supply to ADS	3.5-6
3.6	CONTAINMENT	3.6-1
3.6.1	Venting or Purging	3.6-1
3.6.2	Suppression Chamber-to-Drywell Vacuum Breaker Position Indication	TRM/3.6-3
3.6.3	Suppression Pool Alarm Instrumentation	3.6-4
3.6.4	Primary Containment Closed System Boundaries	TRM/3.6-7
3.7	PLANT SYSTEMS	TRM/3.7-1
3.7.1	Emergency Service Water System (ESW) Shutdown	TRM/3.7-1
3.7.2	Ultimate Heat Sink (UHS) and Ground Water Level	3.7-3
3.7.3	Fire Protection	TRM/3.7-4
3.7.3.1	Fire Suppression Water Supply System	TRM/3.7-4
3.7.3.2	Spray and Sprinkler Systems	TRM/3.7-8
3.7.3.3	CO2 systems	TRM/3.7-12
3.7.3.4	Halon Systems	TRM/3.7-16
3.7.3.5	Fire Hose Stations	TRM/3.7-18
3.7.3.6	Yard Fire Hydrants and Hydrant Hose Houses	TRM/3.7-22
3.7.3.7	Fire Rated Assemblies	TRM/3.7-24
3.7.3.8	Fire Detection Instrumentation	TRM/3.7-26
3.7.4	Solid Radwaste System	TRM/3.7-34
3.7.5	Explosive Gas and Storage Tank Radioactivity Monitoring Program	TRM/3.7-37
3.7.5.1	Main Condenser Offgas Hydrogen Monitor	TRM/3.7-37
3.7.5.2	Main Condenser Offgas Explosive Gas Mixture	3.7-38
3.7.5.3	Liquid Holdup Tanks	TRM/3.7-39
3.7.6	ESSW Pumphouse Ventilation	TRM/3.7-40
3.7.7	Main Condenser Offgas Pretreatment Logarithmic Radiation Monitoring Instrumentation	TRM/3.7-41
3.7.8	Snubbers	TRM/3.7-43
3.7.9	Control Structure HVAC	TRM/3.7-49
3.7.10	Spent Fuel Storage Pools (SFSPs)	TRM/3.7-51
3.7.11	Structural Integrity	TRM/3.7-54
3.8	ELECTRICAL POWER	TRM/3.8-1
3.8.1	Primary Containment Penetration Conductor Overcurrent Protective Devices	TRM/3.8-1
3.8.2	Motor Operated Valves Thermal Overload Protection	TRM/3.8.5
3.8.2.1	Motor Operated Valves (MOV) Thermal Overload Protection - Continuous	TRM/3.8-5
3.8.2.2	Motor Operated Valves (MOV) Thermal Overload Protection - Automatic	TRM/3.8-11
3.8.3	Diesel Generator (DG) Maintenance Activities	TRM/3.8-13

SUSQUEHANNA STEAM ELECTRIC STATION
TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 24

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.8.4	24 VDC Electrical Power Subsystem.....	TRM/3.8-15
3.8.5	Degraded Voltage Protection	TRM/3.8-21
3.8.6	Emergency Switchgear Room Cooling	TRM/3.8-24
3.8.7	Battery Monitoring and Maintenance Program.....	TRM/3.8-26
3.9	REFUELING OPERATIONS.....	3.9-1
3.9.1	Decay Time	3.9-1
3.9.2	Communications.....	3.9-2
3.9.3	Refueling Platform	3.9-3
3.10	MISCELLANEOUS	TRM/3.10-1
3.10.1	Sealed Source Contamination	TRM/3.10-1
3.10.2	Shutdown Margin Test RPS Instrumentation	3.10-4
3.10.3	Independent Spent Fuel Storage Installation (ISFSI).....	TRM/3.10-7
3.11	RADIOACTIVE EFFLUENTS.....	TRM/3.11-1
3.11.1	Liquid Effluents.....	TRM/3.11-1
3.11.1.1	Liquid Effluents Concentration.....	TRM/3.11-1
3.11.1.2	Liquid Effluents Dose	TRM/3.11-4
3.11.1.3	Liquid Waste Treatment System	TRM/3.11-6
3.11.1.4	Liquid Radwaste Effluent Monitoring Instrumentation.....	TRM/3.11-8
3.11.1.5	Radioactive Liquid Process Monitoring Instrumentation	TRM/3.11-13
3.11.2	Gaseous Effluents	TRM/3.11-17
3.11.2.1	Dose Rate.....	TRM/3.11-17
3.11.2.2	Dose - Noble Gases	TRM/3.11-20
3.11.2.3	Dose - Iodine, Tritium, and Radionuclides in Particulate Form	TRM/3.11-21
3.11.2.4	Gaseous Radwaste Treatment System	TRM/3.11-22
3.11.2.5	Ventilation Exhaust Treatment System.....	TRM/3.11-23
3.11.2.6	Radioactive Gaseous Effluent Monitoring Instrumentation.....	TRM/3.11-25
3.11.3	Total Dose	TRM/3.11-33
3.11.4	Radiological Environmental Monitoring.....	TRM/3.11-35
3.11.4.1	Monitoring Program	TRM/3.11-35
3.11.4.2	Land Use Census	TRM/3.11-45
3.11.4.3	Interlaboratory Comparison Program.....	TRM/3.11-47
3.12	LOADS CONTROL PROGRAM.....	TRM/3.12-1
3.12.1	Crane Travel - Spent Fuel Storage Pool.....	TRM/3.12-1
3.12.2	Heavy Loads Requirements	TRM/3.12-3
3.12.3	Light Loads Requirements.....	TRM/3.12-5

SUSQUEHANNA STEAM ELECTRIC STATION
TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 24

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
4.0	ADMINISTRATIVE CONTROLS	4.0-1
4.1	Organization	4.0-1
4.2	Reportable Event Action	4.0-2
4.3	Safety Limit Violation	4.0-3
4.4	Procedures and Programs	TRM/4.0-4
4.5	Reporting Requirements	4.0-5
4.5.1	Startup Reports	4.0-5
4.5.2	Annual Reports	4.0-6
4.5.3	Special Reports	4.0-6
4.6	Radiation Protection Program	4.0-7
4.7	Training	4.0-8

SUSQUEHANNA STEAM ELECTRIC STATION
TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 24

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
B 3.0	Technical Requirement for Operation (TRO) Applicability	TRM/B 3.0-1
B 3.0	Technical Requirement Surveillance (TRS) Applicability	TRM/B 3.0-9
B 3.1.1	Anticipated Transient Without Scram Alternate Rod Injection (ATWS-ARI) Instrumentation	TRM/B 3.1-1
B 3.1.2	Control Rod Drive (CRD) Housing Support	B 3.1-4
B 3.1.3	Control Rod Block Instrumentation	TRM/B 3.1-5
B 3.1.4	Control Rod Scram Accumulators Instrumentation and Check Valve	TRM/B 3.1-8
B 3.2.1	Core Operating Limits Report (COLR)	B 3.2-1
B 3.3.1	Radiation Monitoring Instrumentation	TRM/B 3.3-1
B 3.3.2	Seismic Monitoring Instrumentation	TRM/B 3.3-2
B 3.3.3	Meteorological Monitoring Instrumentation	TRM/B 3.3-3
B 3.3.4	TRM Post-Accident Monitoring Instrumentation	TRM/B 3.3-4
B 3.3.5	Section Not Used	TRM/B 3.3-9
B 3.3.6	TRM Isolation Actuation Instrumentation	TRM/B 3.3-10
B 3.3.7	Turbine Overspeed Protection System	TRM/B 3.3-14
B 3.3.8	Section Not Used	TRM/B 3.3-15
B 3.3.9	OPRM Instrumentation	TRM/B 3.3-18
B 3.3.10	Reactor Recirculation Pump MG Set Stops	TRM/B 3.3-20
B 3.3.11	MVP Isolation Instrumentation	TRM/B 3.3-22
B 3.3.12	Water Monitoring Instrumentation	TRM/B 3.3-24
B 3.4.1	Reactor Coolant System Chemistry	B 3.4-1
B 3.4.2	Not Used	TRM/B 3.4-2
B 3.4.3	High/Low Pressure Interface Leakage Monitor	TRM/B 3.4-4
B 3.4.4	Reactor Recirculation Flow and Rod Line Limit	TRM/B 3.4-5
B 3.4.5	Reactor Vessel Materials	B 3.4-6
B 3.4.6	Reactor Recirculation Single Loop Operation (SLO) Flow Rate Restriction	TRM/B3.4-7
B 3.5.1	ADS Manual Inhibit	B 3.5-1
B 3.5.2	ECCS and RCIC System Monitoring Instrumentation	TRM/B 3.5-3
B 3.5.3	Long Term Nitrogen Supply to ADS	TRM/B 3.5-4
B 3.6.1	Venting or Purging	TRM/B 3.6-1
B 3.6.2	Suppression Chamber-to-Drywell Vacuum Breaker Position Indication	B 3.6-3
B 3.6.3	Suppression Pool Alarm Instrumentation	TRM/B 3.6-4
B 3.6.4	Primary Containment Closed System Boundaries	TRM/B 3.6-6
B 3.7.1	Emergency Service Water System (Shutdown)	B 3.7-1
B 3.7.2	Ultimate Heat Sink (UHS) Ground Water Level	B 3.7-2
B 3.7.3.1	Fire Suppression Water Supply System	TRM/B 3.7-3

SUSQUEHANNA STEAM ELECTRIC STATION
TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 24

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
B 3.7.3.2	Spray and Sprinkler Systems	TRM/B 3.7-5
B 3.7.3.3	CO2 Systems	TRM/B 3.7-7
B 3.7.3.4	Halon Systems	TRM/B 3.7-8
B 3.7.3.5	Fire Hose Stations	TRM/B 3.7-10
B 3.7.3.6	Yard Fire Hydrants and Hydrant Hose Houses.....	TRM/B 3.7-11
B 3.7.3.7	Fire Rated Assemblies.....	TRM/B 3.7-12
B 3.7.3.8	Fire Detection Instrumentation.....	TRM/B 3.7-14
B 3.7.4	Solid Radwaste System.....	TRM/B 3.7-15
B 3.7.5.1	Main Condenser Offgas Hydrogen Monitor	B 3.7-17
B 3.7.5.2	Main Condenser Offgas Explosive Gas Mixture	B 3.7-19
B 3.7.5.3	Liquid Holdup Tanks.....	B 3.7-20
B 3.7.6	ESSW Pumphouse Ventilation.....	TRM/B 3.7-21
B 3.7.7	Main Condenser Offgas Pretreatment Logarithmic Radiation Monitoring Instrumentation	TRM/B 3.7-22
B 3.7.8	Snubbers.....	TRM/B 3.7-24
B 3.7.9	Control Structure HVAC.....	TRM/B 3.7-31
B 3.7.10	Spent Fuel Storage Pools.....	TRM/B 3.7-33
B 3.7.11	Structural Integrity.....	TRM/B 3.7-36
B 3.8.1	Primary Containment Penetration Conductor Overcurrent Protective Devices	TRM/B 3.8-1
B 3.8.2.1	Motor Operated Valves (MOV) Thermal Overload Protection - Continuous	TRM/B 3.8-3
B 3.8.2.2	Motor Operated Valves (MOV) Thermal Overload Protection - Automatic.....	TRM/B 3.8-4
B 3.8.3	Diesel Generator (DG) Maintenance Activities	B 3.8-5
B 3.8.4	24 VDC Electrical Power Subsystem.....	TRM/B 3.8-6
B 3.8.5	Degraded Voltage Protection	TRM/B 3.8-16
B 3.8.6	Emergency Switchgear Room Cooling	TRM/B 3.8-17
B 3.8.7	Battery Monitoring and Maintenance Program.....	TRM/B 3.8-18
B.3.9.1	Decay Time	B 3.9-1
B 3.9.2	Communications.....	B 3.9-2
B 3.9.3	Refueling Platform.....	B 3.9-3
B 3.10.1	Sealed Source Contamination.....	B 3.10-1
B 3.10.2	Shutdown Margin Test RPS Instrumentation.....	B 3.10-2
B 3.10.3	Independent Spent Fuel Storage Installation (ISFSI).....	TRM/B 3.10-4
B 3.11.1.1	Liquid Effluents Concentration.....	B 3.11-1
B 3.11.1.2	Liquid Effluents Dose	B 3.11-4
B 3.11.1.3	Liquid Waste Treatment System	B 3.11-6
B 3.11.1.4	Liquid Radwaste Effluent Monitoring Instrumentation.....	B 3.11-7
B 3.11.1.5	Radioactive Liquid Process Monitoring Instrumentation	TRM/B 3.11-10

TABLE OF CONTENTS (TECHNICAL REQUIREMENTS MANUAL)

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
B 3.11.2.1	Dose Rate.....	TRM/B 3.11-12
B 3.11.2.2	Dose - Noble Gases	B 3.11-16
B 3.11.2.3	Dose - Iodine, Tritium, and Radionuclides in Particulates Form.....	B 3.11-18
B 3.11.2.4	Gaseous Radwaste Treatment System	TRM/B 3.11-20
B 3.11.2.5	Ventilation Exhaust Treatment System.....	TRM/B 3.11-21
B 3.11.2.6	Radioactive Gaseous Effluent Monitoring Instrumentation.....	TRM/B 3.11-24
B 3.11.3	Total Dose	B 3.11-26
B 3.11.4.1	Monitoring Program	TRM/B 3.11-28
B 3.11.4.2	Land Use Census	B 3.11-34
B 3.11.4.3	Interlaboratory Comparison Program.....	TRM/B 3.11-36
B.3.12.1	Crane Travel - Spent Fuel Storage Pool	TRM/B 3.12-1
B.3.12.2	Heavy Loads Requirements	TRM/B 3.12-2
B.3.12.3	Light Loads Requirements.....	TRM/B 3.12-3

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
TOC	TABLE OF CONTENTS	04/23/2015
1.0	USE AND APPLICATION	
	Page TRM / 1.0-1	08/31/1998
	Page TRM / 1.0-2	10/04/2002
	Page TRM / 1.0-3	08/31/1998
2.0	PLANT PROGRAMS	
	Page 2.0-1	08/31/1998
	Pages TRM / 2.0-2 and TRM 2.0-3	01/28/2005
	Page TRM / 2.0-4	06/25/2002
	Page TRM / 2.0-5	01/21/2014
	Page TRM / 2.0-6	04/15/2009
	Page TRM / 2.0-7	05/15/2008
	Pages TRM / 2.0-8 and TRM / 2.0-9	01/07/2011
	Page TRM / 2.0-10	02/02/2010
	Page TRM / 2.0-11	11/15/2004
	Page TRM / 2.0-12	04/15/2009
	Pages TRM / 2.0-13 and TRM / 2.0-14	11/15/2004
	Page TRM / 2.0-15	11/15/2005
3.0	APPLICABILITY	
	Pages TRM / 3.0-1 and TRM / 3.0-2	02/19/2015
	Page TRM / 3.0-3	03/15/2002
	Page TRM / 3.0-4	02/19/2015
3.1	REACTIVITY CONTROL SYSTEMS	
	Page TRM / 3.1-1	10/31/2007
	Pages TRM / 3.1-2 through TRM / 3.1-5	08/31/1998
	Page TRM / 3.1-6	03/27/2007
	Page TRM / 3.1-7	04/15/2009
	Page TRM / 3.1-8	03/27/2007
	Pages TRM / 3.1-9 and TRM / 3.1-9a	02/18/1999
	Page TRM / 3.1-10	02/18/1999
3.2	CORE OPERATING LIMITS REPORT	
	Page TRM / 3.2-1	08/31/1998
	Pages TRM / 3.2-2 through TRM / 3.2-54	04/21/2015
3.3	INSTRUMENTATION	
	Pages TRM / 3.3-1 through TRM / 3.3-3	07/16/1999
	Pages TRM / 3.3-4 and TRM / 3.3-5	10/31/2007
	Page TRM / 3.3-6	03/10/2011
	Page TRM 3.3-7	10/31/2007
	Page 3.3-8	08/31/1998

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Pages TRM / 3.3-9 and TRM / 3.3-9a	06/30/2010
	Page TRM / 3.3-10	10/31/2007
	Page TRM / 3.3-11	06/30/2010
	Page TRM / 3.3-11a	02/19/2015
	Page TRM / 3.3-12	03/30/2001
	Page TRM / 3.3-13	01/07/2011
	Page TRM / 3.3-14	12/14/1998
	Page TRM / 3.3-15	04/11/2014
	Page TRM / 3.3-16	01/07/2011
	Page TRM / 3.3-17	06/14/2002
	Page TRM / 3.3-18	10/31/2007
	Pages TRM / 3.3-19 and TRM / 3.3-20	10/22/2003
	Page TRM / 3.3-21	04/15/2009
	Page TRM / 3.3-21a	11/15/2004
	Pages TRM / 3.3-21b through TRM / 3.3-21d	03/27/2007
	Page TRM / 3.3-22	12/03/2004
	Pages TRM / 3.3-23 and TRM / 3.3-24	05/16/2003
	Page TRM / 3.3-25	10/22/2003
	Page TRM / 3.3-26	02/19/2015
	Page TRM / 3.3-27	04/07/2009
3.4	REACTOR COOLANT SYSTEM	
	Page TRM / 3.4-1	03/31/2006
	Pages 3.4-2 through 3.4-5	10/23/1998
	Pages TRM / 3.4-6 through TRM / 3.4-8	04/01/2009
	Page 3.4-9	08/31/1998
	Page 3.4-10	10/31/2007
	Page 3.4-11	08/31/1998
	Page TRM / 3.4-12	04/17/2009
	Page TRM / 3.4-13	03/31/2006
	Page TRM / 3.4-14	04/25/2013
3.5	EMERGENCY CORE COOLING AND RCIC	
	Page TRM / 3.5-1	01/28/2005
	Pages 3.5-2 and 3.5-3	08/31/1998
	Page TRM / 3.5-4	10/31/2007
	Pages 3.5-5 through 3.5-7	08/31/1998
3.6	CONTAINMENT	
	Pages 3.6-1 and 3.6-2	08/31/1998
	Pages TRM / 3.6-3 and TRM / 3.6-3a	04/16/2014
	Page 3.6-4	08/31/1998
	Page TRM / 3.6-5	01/07/2002
	Page 3.6-6	08/31/1998
	Pages TRM / 3.6-7 through TRM / 3.6-9	12/31/2002

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.7	PLANT SYSTEMS	
	Pages TRM / 3.7-1 and TRM / 3.7-2	07/29/1999
	Page 3.7-3	08/31/1998
	Page TRM / 3.7-4	03/31/2006
	Page TRM / 3.7-5	04/07/2009
	Pages TRM / 3.7-6 through TRM / 3.7-8	08/02/1999
	Pages TRM / 3.7-9 and TRM / 3.7-10	04/07/2009
	Page TRM / 3.7-11	01/21/2000
	Page TRM / 3.7-12	08/02/1999
	Page TRM / 3.7-13	04/07/2009
	Page TRM / 3.7-14	08/09/2005
	Pages TRM / 3.7-15 and TRM / 3.7-16	08/02/1999
	Page TRM / 3.7-17	04/07/2009
	Page TRM / 3.7-18	08/02/1999
	Page TRM / 3.7-19	04/07/2009
	Pages TRM / 3.7-20 through TRM / 3.7-22	08/02/1999
	Page TRM / 3.7-23	04/07/2009
	Page TRM / 3.7-24	03/31/2006
	Page TRM / 3.7-25	08/02/1999
	Page TRM / 3.7-26	09/25/2012
	Page TRM / 3.7-27	11/24/2011
	Pages TRM / 3.7-28 through TRM / 3.7-32a	09/25/2012
	Page TRM / 3.7-33	09/25/2012
	Page TRM / 3.7-34	03/31/2006
	Pages TRM / 3.7-35 and TRM / 3.7-36	02/01/1999
	Page TRM / 3.7-37	02/19/2015
	Page TRM / 3.7-38	08/31/1998
	Page TRM / 3.7-39	03/31/2006
	Page TRM / 3.7-40	05/24/2012
	Pages TRM / 3.7-40a through TRM / 3.7-40c	05/24/2012
	Page TRM / 3.7-41	09/04/2008
	Page TRM / 3.7-42	08/31/1998
	Pages TRM / 3.7-43	02/19/2015
	Pages TRM / 3.7-44 and TRM / 3.7-45	10/05/2006
	Page TRM / 3.7-46	06/07/2007
	Page TRM / 3.7-47	09/05/2012
	Page TRM / 3.7-48	06/07/2007
	Page TRM / 3.7-49	03/09/2001
	Page TRM / 3.7-50	08/16/2006
	Page TRM / 3.7-51	12/03/2004
	Page TRM / 3.7-52	04/15/2003
	Page TRM / 3.7-53	07/29/1999
	Page TRM / 3.7-54	04/01/2009
	Page TRM / 3.7-55	09/25/2009
	Page TRM / 3.7-56	04/01/2009

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.8	ELECTRICAL POWER	
	Page TRM / 3.8-1	04/02/2002
	Page TRM / 3.8-2	01/28/2005
	Pages TRM / 3.8-3 and TRM / 3.8-4	06/12/2012
	Pages TRM / 3.8-5 and TRM / 3.8-6	04/02/2002
	Pages TRM / 3.8-7 through TRM / 3.8-10	10/31/2007
	Page TRM / 3.8-11	09/03/2004
	Page TRM / 3.8-12	12/03/2004
	Page TRM / 3.8-13	06/12/2012
	Page TRM / 3.8-14	08/31/1998
	Page TRM / 3.8-15	01/28/2005
	Pages TRM / 3.8-16 and TRM / 3.8-17	04/02/2002
	Page 3.8-18	02/01/1999
	Page TRM / 3.8-19	04/02/2002
	Page TRM / 3.8-20	02/01/1999
	Pages TRM / 3.8-21 and TRM / 3.8-22	06/06/1999
	Page TRM / 3.8-23	11/07/2013
	Page TRM / 3.8-24	11/30/2011
	Page TRM / 3.8-25	06/11/2012
	Pages TRM / 3.8-25a and TRM / 3.8-25b	11/30/2011
	Page TRM / 3.8-26	05/28/2009
	Page TRM / 3.8-27	11/29/2006
	Page TRM / 3.8-28	05/28/2009
	Page TRM / 3.8-29	10/20/2009
3.9	REFUELING OPERATIONS	
	Pages 3.9-1 through 3.9-3	08/31/1998
3.10	MISCELLANEOUS	
	Page TRM / 3.10-1	03/31/2006
	Pages 3.10-2 through 3.10-4	08/30/1998
	Pages TRM / 3.10-5 and TRM / 3.10-6	03/27/2007
	Page TRM / 3.10-7	06/10/2010
3.11	RADIOACTIVE EFFLUENTS	
	Page TRM / 3.11-1	03/31/2006
	Pages 3.11-2 through 3.11-3	08/31/1998
	Page TRM / 3.11-4	03/31/2006
	Page 3.11-5	08/31/1998
	Page TRM / 3.11-6	03/31/2006
	Pages 3.11-7 and TRM / 3.11-8	08/31/1998
	Pages TRM / 3.11-9 and TRM / 3.11-10	10/09/2012
	Pages TRM / 3.11-11 and TRM / 3.11-12	08/31/1998

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / 3.11-13	02/19/2015
	Page TRM / 3.11-14	12/03/2004
	Pages 3.11-15 and 3.11-16	09/01/1998
	Page TRM / 3.11-17	03/31/2006
	Page 3.11-18	08/31/1998
	Page TRM / 3.11-19	08/15/2005
	Pages TRM / 3.11-20 and TRM / 3.11-21	03/31/2006
	Page TRM / 3.11-22	04/02/2002
	Page TRM / 3.11-23	11/14/2006
	Page TRM / 3.11-24	06/18/2013
	Page TRM / 3.11-25	04/12/2007
	Pages TRM / 3.11-26 and TRM / 3.11-27	01/21/2004
	Page TRM / 3.11-28	09/08/2009
	Page TRM / 3.11-29	12/03/2004
	Pages TRM 3.11-30 and TRM / 3.11-31	01/21/2004
	Page TRM / 3.11-32	02/19/2015
	Page TRM / 3.11-33	03/31/2006
	Page 3.11-34	08/31/1998
	Page TRM / 3.11-35	03/31/2006
	Pages TRM / 3.11-36 through TRM / 3.11-39	11/30/2005
	Page TRM / 3.11-40	02/19/2015
	Pages TRM / 3.11-41 through TRM / 3.11-44	08/31/1998
	Page TRM / 3.11-45	03/31/2006
	Page 3.11-46	08/31/1998
	Page TRM / 3.11-47	03/31/2006
3.12	LOADS CONTROL PROGRAM	
	Pages TRM / 3.12-1 through TRM / 3.12-3	02/05/1999
	Page TRM / 3.12-4	03/14/2008
	Page TRM / 3.12-5	02/05/1999
4.0	ADMINISTRATIVE CONTROLS	
	Pages TRM / 4.0-1 through TRM / 4.0-3	08/31/1998
	Page TRM / 4.0-4	12/11/2008
	Pages TRM / 4.0-5 through TRM / 4.0-8	08/31/1998

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.0	APPLICABILITY BASES	
	Pages TRM / B 3.0-1 through TRM / B 3.0-3	08/31/1998
	Page TRM / B 3.0-4	02/19/2015
	Pages TRM / B 3.0-4a and TRM / B 3.0-4b	02/19/2015
	Page TRM / B 3.0-5	02/19/2015
	Pages TRM / B 3.0-6 and TRM / B 3.0-7	06/12/2012
	Pages TRM / B 3.0-8 through TRM / B 3.0-10	08/31/1998
	Pages TRM / B 3.0-11 and TRM / B 3.0-12	03/15/2002
	Pages TRM / B 3.0-13 through TRM / B 3.0-15	02/19/2015
B 3.1	REACTIVITY CONTROL SYSTEMS BASES	
	Page TRM / B 3.1-1	07/13/1999
	Page TRM / B 3.1-2	04/16/2014
	Page TRM / B 3.1-3	10/31/2007
	Page B 3.1-4	08/31/1998
	Pages TRM / B 3.1-5 through TRM / B 3.1-7	03/27/2007
	Page TRM / B 3.1-8	02/18/1999
B 3.2	CORE OPERATING LIMITS BASES	
	Page B 3.2-1	08/31/1998
B 3.3	INSTRUMENTATION BASES	
	Page TRM / B 3.3-1	01/21/2014
	Page TRM / B 3.3-2	03/10/2011
	Page TRM / B-3.3-2a	10/31/2007
	Pages TRM / B 3.3-3 and TRM / B 3.3-3a	10/31/2007
	Page TRM / B 3.3-4	06/30/2010
	Page TRM / B 3.3-5	05/30/2006
	Page TRM / B 3.3-6	06/30/2010
	Page TRM / B 3.3-7	10/31/2007
	Page TRM / B 3.3-8	06/30/2010
	Page TRM / B 3.3-9	10/31/2007
	Page TRM / B 3.3-10	01/07/2011
	Page TRM / B 3.3-11	02/21/2014
	Pages TRM / B 3.3-12 and TRM / B 3.3-13	01/07/2011
	Page TRM / B 3.3-14	06/25/2002
	Page TRM / B 3.3-14a	10/31/2007
	Page TRM / B 3.3-14b	06/14/2002
	Pages TRM / B 3.3-15 through TRM / B 3.3-17	10/22/2003
	Pages TRM / B 3.3-18 and TRM / B 3.3-19	03/27/2007
	Pages TRM / B 3.3-19a and TRM / B 3.3-19b	03/27/2007
	Page TRM / B 3.3-19c	04/17/2009

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Pages TRM / B 3.3-19d and TRM / B 3.3-19e	03/27/2007
	Page TRM / B 3.3-20	02/16/2012
	Page TRM / B 3.3-21	08/03/2010
	Page TRM / B 3.3-22	10/22/2003
	Page TRM / B 3.3-23	05/16/2003
	Pages TRM / B 3.3-24 and TRM / B 3.3-25	04/07/2009
 B 3.4	 REACTOR COOLANT SYSTEM BASES	
	Page TRM / B 3.4-1	08/31/1998
	Pages TRM / B 3.4-2 and TRM / B3.4-3	04/01/2009
	Pages TRM / B 3.4-4 and TRM / B 3.4-4a	10/31/2007
	Page TRM / B 3.4-5	10/15/1999
	Page B 3.4-6	08/31/1998
	Page TRM / B 3.4-7	04/25/2013
 B 3.5	 ECCS AND RCIC BASES	
	Pages B 3.5-1 and B 3.5-2	08/31/1998
	Pages TRM / B 3.5-3 and TRM / B 3.5-3a	10/31/2007
	Page B 3.5-4	08/31/1998
	Page TRM / B 3.5-5	10/31/2007
 B 3.6	 CONTAINMENT BASES	
	Page TRM / B 3.6-1	07/26/2001
	Page TRM / B 3.6-2	02/01/1999
	Page B 3.6-3	08/31/1998
	Page TRM / B 3.6-4	03/29/2007
	Page TRM / B 3.6-5	04/04/2007
	Page TRM / B 3.6-6	12/03/2004
	Pages TRM / B 3.6-7 through TRM / B 3.6-11	12/31/2002
 B 3.7	 PLANT SYSTEMS BASES	
	Pages B 3.7-1 and B 3.7-2	08/31/1998
	Page TRM / B 3.7-3	06/10/2010
	Page TRM / B 3.7-3a	12/27/2007
	Page TRM / B 3.7-4	03/31/2006
	Page TRM / B 3.7-5	08/02/1999
	Pages TRM / B 3.7-6 and TRM / B 3.7-6a	03/31/2006
	Pages TRM / B 3.7-7 and TRM / B 3.7-7a	08/02/1999
	Page TRM / B 3.7-8	08/02/1999
	Page TRM / B 3.7-9	04/11/2014
	Page TRM / B 3.7-10	08/02/1999

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Pages TRM / B 3.7-10a through TRM / B 3.7-11a	03/31/2006
	Pages TRM / B 3.7-12 and TRM / B 3.7-13	08/02/1999
	Pages TRM / B 3.7-14 through TRM / B 3.7-14b	09/25/2012
	Pages TRM / B 3.7-15 and TRM / B 3.7-16	02/01/1999
	Pages B 3.7-17 through B 3.7-20	08/31/1998
	Page TRM / B 3.7-21	05/29/2013
	Pages TRM / B 3.7-21a through TRM / B 3.7-21d	05/24/2012
	Pages TRM / B 3.7-21e through TRM / B 3.7-21g	05/29/2013
	Pages TRM / B 3.7-22 and TRM / B 3.7-23	01/30/2008
	Page TRM / B 3.7-24	10/05/2006
	Page TRM / B 3.7-25	01/21/2014
	Pages TRM / B 3.7-26 through TRM / B 3.7-29	10/05/2006
	Page TRM / B 3.7-30	06/07/2007
	Page TRM / B 3.7-30a	10/05/2006
	Page TRM / B 3.7-30b	01/21/2014
	Page TRM / B 3.7-31	11/30/2011
	Page TRM / B 3.7-32	03/09/2001
	Page TRM / B 3.7-33	04/15/2003
	Page TRM / B 3.7-34	12/03/2004
	Page TRM / B 3.7-35	07/05/2000
	Pages TRM / B 3.7-36 and TRM / B 3.7-37	04/01/2009
	Page TRM / B 3.7-38	09/25/2009
	Page TRM / B 3.7-39	04/01/2009
	Page TRM / B 3.7-40	04/08/2010
B 3.8	ELECTRICAL POWER BASES	
	Page TRM / B 3.8-1	04/02/2002
	Pages TRM / B 3.8-2	01/28/2005
	Page TRM / B 3.8-2a	03/01/2010
	Pages TRM / B 3.8-3 and TRM / B 3.8-3a	04/02/2002
	Page TRM / B 3.8-4	09/03/2004
	Page TRM / B 3.8-4a	04/02/2002
	Page TRM / B 3.8-5	08/31/1998
	Pages TRM / B 3.8-6 through TRM / B 3.8-15	04/02/2002
	Page TRM / B 3.8-16	11/07/2013
	Page TRM / B 3.8-17	11/30/2011
	Page TRM / B 3.8-17a	06/11/2012
	Page TRM / B 3.8-17b	11/30/2011
	Pages TRM / B 3.8-18 through TRM / B 3.8-20	05/29/2013
	Pages TRM / B 3.8-21 and TRM / B 3.8-22	05/28/2009
	Page TRM / B 3.8-23	05/29/2013
	Page TRM / B 3.8-24	05/28/2009

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B.3.9	REFUELING OPERATIONS BASES	
	Pages B 3.9-1 and B 3.9-2	08/31/1998
	Pages B 3.9-3 through B 3.9-7	10/23/1998
B 3.10	MISCELLANEOUS BASES	
	Page B 3.10-1	08/31/1998
	Pages TRM / B 3.10-2 and TRM / B 3.10-3	03/27/2007
	Pages TRM / B 3.10-4 and TRM / B 3.10-5	08/23/1999
B 3.11	RADIOACTIVE EFFLUENTS BASES	
	Pages B 3.11-1 through B 3.11-9,	08/31/1998
	Page TRM / B 3.11-10	02/01/1999
	Pages TRM / B 3.11-11 and TRM / B 3.11-11a	04/07/2000
	Pages TRM / B 3.11-12 and TRM / B 3.11-13	02/01/1999
	Page TRM / B 3.11-14	12/03/2004
	Page TRM / B 3.11-15	02/01/1999
	Pages B 3.11-16 through B 3.11-19	08/31/1998
	Pages TRM / B 3.11-20 and TRM / B 3.11-20a	04/02/2002
	Page TRM / B 3.11-21	05/13/2005
	Pages TRM / B 3.11-22 and TRM / B 3.11-23	11/14/2006
	Pages TRM / B 3.11-23a and TRM / B 3.11-23b	06/18/2013
	Pages TRM / B 3.11-24 and TRM / B 3.11-25	01/21/2004
	Pages B 3.11-26 through B 3.11-27	08/31/1998
	Page TRM / B 3.11-28	11/30/2005
	Page TRM / B 3.11-29	02/19/2015
	Pages TRM / B 3.11-30 and TRM / B 3.11-31	05/29/2013
	Page TRM / B 3.11-32	08/31/1998
	Page TRM / B 3.11-33	06/30/2010
	Pages TRM / B 3.11-34 and TRM / B 3.11-35	08/31/1998
	Page TRM / B 3.11-36	02/12/1999
B.3.12	LOADS CONTROL PROGRAM BASES	
	Page TRM / B 3.12-1	09/19/2007
	Page TRM / B 3.12-2	11/29/2010
	Page TRM / B 3.12-3	02/05/1999

TRM2 text LOES.doc
4/23/2015

3.2 Core Operating Limits Report (COLR)

3.2.1 Core Operating Limits Report (COLR)

TRO 3.2.1 The Core Operating Limits specified in the attached COLR shall be met.

APPLICABILITY: Specified in the referenced Technical Specifications.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Core Operating Limits not met.	A.1 Perform action(s) described in referenced Technical Specification.	Specified in referenced Technical Specifications.

TECHNICAL REQUIREMENT SURVEILLANCE

SURVEILLANCE	FREQUENCY
-----NOTE----- No associated Surveillances. Surveillances are implemented in the applicable Technical Specifications.	N/A

Susquehanna SES Unit 2 Cycle 18

CORE OPERATING LIMITS REPORT

**Nuclear Fuels
Engineering**

April 2015



**CORE OPERATING LIMITS REPORT
REVISION DESCRIPTION INDEX**

Rev. No.	Affected Sections	Description/Purpose of Revision
0	ALL	Issuance of this COLR is in support of Unit 2 Cycle 18 operation.

**SUSQUEHANNA STEAM ELECTRIC STATION
Unit 2 Cycle 18
CORE OPERATING LIMITS REPORT**

Table of Contents

1.0	<u>INTRODUCTION</u>	4
2.0	<u>DEFINITIONS</u>	5
3.0	<u>SHUTDOWN MARGIN</u>	6
4.0	<u>AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)</u>	7
5.0	<u>MINIMUM CRITICAL POWER RATIO (MCPR)</u>	9
6.0	<u>LINEAR HEAT GENERATION RATE (LHGR)</u>	24
7.0	<u>ROD BLOCK MONITOR (RBM) SETPOINTS AND OPERABILITY REQUIREMENTS</u>	32
8.0	<u>RECIRCULATION LOOPS - SINGLE LOOP OPERATION</u>	34
9.0	<u>POWER / FLOW MAP</u>	49
10.0	<u>OPRM SETPOINTS</u>	51
11.0	<u>REFERENCES</u>	52

1.0 INTRODUCTION

This CORE OPERATING LIMITS REPORT for Susquehanna Unit 2 Cycle 18 is prepared in accordance with the requirements of Susquehanna Unit 2, Technical Specification 5.6.5. As required by Technical Specifications 5.6.5, core shutdown margin, the core operating limits, RBM setpoints, and OPRM setpoints presented herein were developed using NRC-approved methods and are established such that all applicable limits of the plant safety analysis are met.

2.0 DEFINITIONS

Terms used in this COLR but not defined in Section 1.0 of the Technical Specifications or Section 1.1 of the Technical Requirements Manual are provided below.

- 2.1 The AVERAGE PLANAR EXPOSURE at a specified height shall be equal to the total energy produced per unit length at the specified height divided by the total initial weight of uranium per unit length at that height.
- 2.2 The PELLET EXPOSURE shall be equal to the total energy produced per unit length of fuel rod at the specified height divided by the total initial weight of uranium per unit length of that rod at that height.
- 2.3 FDLRX is the ratio of the maximum LHGR calculated by the core monitoring system for each fuel bundle divided by the LHGR limit for the applicable fuel bundle type.
- 2.4 LHGRFAC_i is a multiplier applied to the LHGR limit when operating at less than 108 Mlbm/hr core flow. The LHGRFAC_i multiplier protects against both fuel centerline melting and cladding strain during anticipated system transients initiated from core flows less than 108 Mlbm/hr.
- 2.5 LHGRFAC_p is a multiplier applied to the LHGR limit when operating at less than RATED THERMAL POWER. The LHGRFAC_p multiplier protects against both fuel centerline melting and cladding strain during anticipated system transients initiated from partial power conditions.
- 2.6 MFLCPR is the ratio of the applicable MCPR operating limit for the applicable fuel bundle type divided by the MCPR calculated by the core monitoring system for each fuel bundle.
- 2.7 MAPRAT is the ratio of the maximum APLHGR calculated by the core monitoring system for each fuel bundle divided by the APLGHR limit for the applicable fuel bundle type.
- 2.8 OPRM is the Oscillation Power Range Monitor. The Oscillation Power Range Monitor (OPRM) will reliably detect and suppress anticipated stability related power oscillations while providing a high degree of confidence that the MCPR safety limit is not violated.
- 2.9 N_p is the OPRM setpoint for the number of consecutive confirmations of oscillation half-cycles that will be considered evidence of a stability related power oscillation.
- 2.10 S_p is the OPRM trip setpoint for the peak to average OPRM signal.
- 2.11 F_p is the core flow, in Mlbm / hr, below which the OPRM RPS trip is activated.

3.0 SHUTDOWN MARGIN

3.1 Technical Specification Reference

Technical Specification 3.1.1

3.2 Description

The SHUTDOWN MARGIN shall be equal to or greater than:

- a) 0.38% $\Delta k/k$ with the highest worth rod analytically determined

OR

- b) 0.28% $\Delta k/k$ with the highest worth rod determined by test

Since core reactivity will vary during the cycle as a function of fuel depletion and poison burnup, Beginning of Cycle (BOC) SHUTDOWN MARGIN (SDM) tests must also account for changes in core reactivity during the cycle. Therefore, the SDM measured at BOC must be equal to or greater than the applicable requirement from either 3.2.a or 3.2.b plus an adder, "R". The adder, "R", is the difference between the calculated value of maximum core reactivity (that is, minimum SDM) during the operating cycle and the calculated BOC core reactivity. If the value of "R" is zero (that is, BOC is the most reactive point in the cycle) no correction to the BOC measured value is required.

The SHUTDOWN MARGIN limits provided in 3.2a and 3.2b are applicable in MODES 1, 2, 3, 4, and 5. This includes core shuffling.

4.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)

4.1 Technical Specification Reference

Technical Specification 3.2.1

4.2 Description

The APLHGRs for ATRIUMTM-10 fuel shall not exceed the limit shown in Figure 4.2-1.


The APLHGR limits in Figure 4.2-1 are valid for Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable in Two Loop operation. The APLHGR limits for Single Loop operation are provided in Section 8.0.

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-9

EFFECTIVE DATE 04/21/2015



AVERAGE PLANAR LINEAR HEAT GENERATION RATE LIMIT VERSUS
AVERAGE PLANAR EXPOSURE - TWO LOOP OPERATION
ATRIUM™-10 FUEL
FIGURE 4.2-1

5.0 MINIMUM CRITICAL POWER RATIO (MCPR)

5.1 Technical Specification Reference

Technical Specification 3.2.2, 3.3.4.1, 3.7.6, and 3.7.8

5.2 Description

The MCPR limit is specified as a function of core power, core flow, average scram insertion time per Section 5.3 and plant equipment operability status. The MCPR limits for all fuel types (ATRIUM™-10) shall be the greater of the Flow-Dependent or the Power-Dependent MCPR, depending on the applicable equipment operability status.

a) Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

Figure 5.2-1: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-2: Power-Dependent MCPR value determined from BOC to EOC

b) Main Turbine Bypass Inoperable

Figure 5.2-3: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-4: Power-Dependent MCPR value determined from BOC to EOC

c) EOC-RPT Inoperable

Figure 5.2-5: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-6: Power-Dependent MCPR value determined from BOC to EOC

d) Backup Pressure Regulator Inoperable

Figure 5.2-7: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-8: Power Dependent MCPR value determined from BOC to EOC

The MCPR limits in Figures 5.2-1 through 5.2-8 are valid for Two Loop operation.

The MCPR limits for Single Loop operation are provided in Section 8.0.

5.3 Average Scram Time Fraction

If the average measured scram times are greater than the Realistic Scram times listed in Table 5.3-1 then the MCPR operating limits corresponding to the Maximum Allowable Average Scram Insertion Time must be implemented. Determining MCPR operating limits based on interpolation between scram insertion times is not permitted. The evaluation of scram insertion time data, as it relates to the attached table should be performed per Reactor Engineering procedures.


Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-13

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-1

PPL Rev. 11


PL-NF-15-002
Rev. 0
Page 12 of 53

SSSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-14

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-2

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 13 of 53


Main Turbine Bypass Inoperable

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-16

EFFECTIVE DATE 04/21/2015




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS INOPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-3

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 15 of 53

SSSES UNIT 2 CYCLE 18



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS INOPERABLE
TWO LOOP OPERATION (BOC to EOC)
FIGURE 5.2-4


EOC-RPT Inoperable

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-19

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
EOC-RPT INOPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-5

PPL Rev. 11


PL-NF-15-002
Rev. 0
Page 18 of 53

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-20

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
EOC-RPT INOPERABLE
TWO LOOP OPERATION (BOC to EOC)
FIGURE 5.2-6

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 19 of 53


Backup Pressure Regulator Inoperable

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-22

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
 BACKUP PRESSURE REGULATOR INOPERABLE
 TWO LOOP OPERATION (BOC TO EOC)
 FIGURE 5.2-7

PPL Rev. 11


PL-NF-15-002
 Rev. 0
 Page 21 of 53

SSSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-23

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
BACKUP PRESSURE REGULATOR INOPERABLE
TWO LOOP OPERATION (BOC to EOC)
FIGURE 5.2-8

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 22 of 53

Table 5.3-1**Average Scram Time Fraction Table For Use With Scram Time Dependent
MCPR Operating Limits**

Control Rod Position	Average Scram Time to Position (seconds)		
45	0.470		0.520
39	0.630		0.860
25	1.500		1.910
5	2.700		3.440
Average Scram Insertion Time	Realistic		Maximum Allowable

6.0 LINEAR HEAT GENERATION RATE (LHGR)

6.1 Technical Specification Reference

Technical Specification 3.2.3 and 3.7.6

6.2 Description

The maximum LHGR for ATRIUM™-10 fuel shall not exceed the LHGR limit determined from Figure 6.2-1. The LHGR limit in Figure 6.2-1 is valid for Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable.

To protect against both fuel centerline melting and cladding strain during anticipated system transients initiated from reduced power and flow conditions, power and flow dependent LHGR limit multipliers are provided. The following figures are applicable to EOC-RPT Operable and Inoperable and Backup Pressure Regulator Operable and Inoperable:

a) Main Turbine Bypass Operable

Figure 6.2-2: Flow-Dependent LHGR Limit Multiplier

Figure 6.2-3: Power-Dependent LHGR Limit Multiplier

b) Main Turbine Bypass Inoperable


Figure 6.2-4: Flow-Dependent LHGR Limit Multiplier

Figure 6.2-5: Power-Dependent LHGR Limit Multiplier

The LHGR limit and LHGR limit multipliers in Figures 6.2-1 through 6.2-5 are valid for both Two Loop and Single Loop operation.

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2 TRM/3.2-26 EFFECTIVE DATE 04/21/2015



LINEAR HEAT GENERATION RATE LIMIT VERSUS PELLET EXPOSURE
 ATRIUM™-10 FUEL
 FIGURE 6.2-1


Main Turbine Bypass Operable

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2


TRM/3.2-28

EFFECTIVE DATE 04/21/2015



FLOW DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS OPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-2

SSES UNIT 2 CYCLE 18



POWER DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS OPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-3


Main Turbine Bypass Inoperable

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-31

EFFECTIVE DATE 04/21/2015




FLOW DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS INOPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-4

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-32

EFFECTIVE DATE 04/21/2015



POWER DEPENDENT LHGR LIMIT MULTIPLIER
 MAIN TURBINE BYPASS INOPERABLE
 ATRIUM™-10 FUEL
 FIGURE 6.2-5

PPL Rev. 11

PL-NF-15-002
 Rev. 0
 Page 31 of 53

7.0 ROD BLOCK MONITOR (RBM) SETPOINTS AND OPERABILITY REQUIREMENTS

7.1 Technical Specification Reference

Technical Specification 3.3.2.1

7.2 Description

The RBM Allowable Value and Trip Setpoints for;

- a) Low Power Range Setpoint,
- b) Intermediate Power Range Setpoint,
- c) High Power Range Setpoint,
- d) Low Power Range - Upscale,
- e) Intermediate Power Range - Upscale, and
- f) High Power Range - Upscale

shall be established as specified in Table 7.2-1. The RBM setpoints are valid for Two Loop and Single Loop Operation, Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable.

The RBM system design objective is to block erroneous control rod withdrawal initiated by the operator before fuel design limits are violated. If the full withdrawal of any control rod would not violate a fuel design limit, then the RBM system is not required to be operable. Table 7.2-2 provides RBM system operability requirements to ensure that fuel design limits are not violated.

Table 7.2-1
RBM Setpoints

Function	Allowable Value ⁽¹⁾	Nominal Trip Setpoint
Low Power Range Setpoint	28.0	24.9
Intermediate Power Range Setpoint	63.0	61.0
High Power Range Setpoint	83.0	81.0
Low Power Range - Upscale	123.4	123.0
Intermediate Power Range - Upscale	117.4	117.0
High Power Range - Upscale	107.6	107.2

- ⁽¹⁾ Power setpoint function (Low, Intermediate, and High Power Range Setpoints) determined in percent of rated thermal power. Upscale trip setpoint function (Low, Intermediate, and High Power Range - Upscale) determined in percent of reference level.

Table 7.2-2
RBM System Operability Requirements

Thermal Power (% of Rated)	MCPR ^(2,3)
≥ 28 and < 90	< 1.76
≥ 90 and < 95	< 1.47
≥ 95	< 1.68

- ⁽²⁾ Applicable to Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable.

- ⁽³⁾ Applicable to both Two Loop and Single Loop Operation.

8.0 RECIRCULATION LOOPS - SINGLE LOOP OPERATION

8.1 Technical Specification Reference

Technical Specification 3.2.1, 3.2.2, 3.2.3, 3.3.4.1, 3.4.1, 3.7.6, and 3.7.8

8.2 Description

APLHGR

The APLHGR limit for ATRIUMTM-10 fuel shall be equal to the APLHGR Limit from Figure 8.2-1.

The APLHGR limits in Figure 8.2-1 are valid for Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable in Single Loop operation.

Minimum Critical Power Ratio Limit

The MCPR limit is specified as a function of core power, core flow, and plant equipment operability status. The MCPR limits for all fuel types (ATRIUMTM-10) shall be the greater of the Flow-Dependent or the Power-Dependent MCPR, depending on the applicable equipment operability status.

a) Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

Figure 8.2-2: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-3: Power-Dependent MCPR value determined from BOC to EOC

b) Main Turbine Bypass Inoperable

Figure 8.2-4: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-5: Power-Dependent MCPR value determined from BOC to EOC

c) EOC-RPT Inoperable

Figure 8.2-6: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-7: Power-Dependent MCPR value determined from BOC to EOC

d) Backup Pressure Regulator Inoperable

Figure 8.2-8: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-9: Power-Dependent MCPR value determined from BOC to EOC

The MCPR limits in Figures 8.2-2 through 8.2-9 are valid only for Single Loop operation.

Linear Heat Generation Rate Limit

The LHGR limits for Single Loop Operation are defined in Section 6.0.

RBM Setpoints and Operability Requirements


The RBM setpoints and operability requirements for Single Loop Operation are defined in Section 7.0.

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-37

EFFECTIVE DATE 04/21/2015



AVERAGE PLANAR LINEAR HEAT GENERATION RATE LIMIT VERSUS
AVERAGE PLANAR EXPOSURE - SINGLE LOOP OPERATION
ATRIUM™-10 FUEL
FIGURE 8.2-1


Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

SSSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-39

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-2

PPL Rev. 11


PL-NF-15-002
Rev. 0
Page 38 of 53

SSSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-40

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-3

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 39 of 53


Main Turbine Bypass Inoperable

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-42

EFFECTIVE DATE 04/21/2015




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-4

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-43

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-5


EOC-RPT Inoperable

SSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-45

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
EOC-RPT INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-6

PPL Rev. 11


PL-NF-15-002
Rev. 0
Page 44 of 53

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-46

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
EOC-RPT INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-7

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 45 of 53


Backup Pressure Regulator Inoperable

SSSES UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-48

EFFECTIVE DATE 04/21/2015




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
BACKUP PRESSURE REGULATOR INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-8

SSS UNIT 2 CYCLE 18

SUSQUEHANNA UNIT 2

TRM/3.2-49

EFFECTIVE DATE 04/21/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
BACKUP PRESSURE REGULATOR INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-9

PPL Rev. 11

PL-NF-15-002
Rev. 0
Page 48 of 53

9.0 POWER / FLOW MAP

9.1 Technical Specification Reference

Technical Specification 3.3.1.1

9.2 Description

Monitor reactor conditions to maintain THERMAL POWER / core flow outside of Stability Regions I and II of the Power / Flow map, Figure 9.1.

If the OPRM Instrumentation is OPERABLE per TS 3.3.1.1, Region I of the Power / Flow map is considered an immediate exit region.

If the OPRM Instrumentation is inoperable per TS 3.3.1.1, Region I of the Power / Flow map is considered an immediate scram region.

Region II of the Power / Flow map is considered an immediate exit region regardless of the operability of the OPRM Instrumentation.




Figure 9.1
SSES Unit 2 Cycle 18 Power / Flow Map

10.0 OPRM SETPOINTS

10.1 Technical Specification Reference

Technical Specification 3.3.1.1

10.2 Description

Setpoints for the OPRM Instrumentation are established that will reliably detect and suppress anticipated stability related power oscillations while providing a high degree of confidence that the MCPR Safety limit is not violated. The setpoints are described in Section 2.0 and are listed below:

$$S_P = 1.12$$

$$N_P = 16$$

$$F_P = 60 \text{ Mlbm / hr}$$

11.0 REFERENCES

- 11.1 The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
1. XN-NF-81-58(P)(A), Revision 2 and Supplements 1 and 2, "RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model," Exxon Nuclear Company, March 1984.
 2. EMF-2361(P)(A), Revision 0, "EXEM BWR-2000 ECCS Evaluation Model," Framatome ANP, May 2001.
 3. EMF-2292(P)(A), Revision 0, "ATRIUM™-10: Appendix K Spray Heat Transfer Coefficients," Siemens Power Corporation, September 2000.
 4. XN-NF-84-105(P)(A), Volume 1 and Volume 1 Supplements 1 and 2, "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis," Exxon Nuclear Company, February 1987.
 5. XN-NF-80-19(P)(A), Volume 1 and Supplements 1 and 2, "Exxon Nuclear Methodology for Boiling Water Reactors: Neutronic Methods for Design and Analysis," Exxon Nuclear Company, March 1983.
 6. XN-NF-80-19(P)(A), Volumes 2, 2A, 2B, and 2C "Exxon Nuclear Methodology for Boiling Water Reactors: EXEM BWR ECCS Evaluation Model," Exxon Nuclear Company, September 1982.
 7. XN-NF-80-19(P)(A), Volume 3 Revision 2 "Exxon Nuclear Methodology for Boiling Water Reactors Thermex: Thermal Limits Methodology Summary Description," Exxon Nuclear Company, January 1987.
 8. XN-NF-80-19(P)(A), Volume 4, Revision 1, "Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology to BWR Reloads," Exxon Nuclear Company, June 1986.
 9. XN-NF-85-67(P)(A), Revision 1, "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," Exxon Nuclear Company, Inc., September 1986.
 10. ANF-524(P)(A), Revision 2 and Supplements 1 and 2, "Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors," November 1990.
 11. NE-092-001A, Revision 1, "Licensing Topical Report for Power Uprate With Increased Core Flow," Pennsylvania Power & Light Company, December 1992 and NRC SER (November 30, 1993).

12. ANF-89-98(P)(A) Revision 1 and Supplement 1, "Generic Mechanical Design Criteria for BWR Fuel Designs," Advanced Nuclear Fuels Corporation, May 1995.
13. EMF-2209(P)(A), Revision 3, "SPCB Critical Power Correlation," AREVA NP, September 2009.
14. EMF-85-74(P)(A), Revision 0, Supplement 1(P)(A) and Supplement 2(P)(A), "RODEX2A (BWR) Fuel Rod Thermal-Mechanical Evaluation Model," Siemens Power Corporation, February 1998.
15. EMF-2158(P)(A), Revision 0, "Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/Microburn-B2," Siemens Power Corporation, October 1999.
16. EMF-CC-074(P)(A), Volume 4, Revision 0, "BWR Stability Analysis - Assessment of STAIF with Input from MICROBURN-B2," Siemens Power Corporation, August 2000.
17. NEDO-32465-A, "BWROG Reactor Core Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications," August 1996.
18. ANF-913(P)(A), Volume 1 Revision 1 and Volume 1 Supplements 2, 3, and 4, "COTRANSA2: A Computer Program for Boiling Water Reactor Transient Analyses," Advanced Nuclear Fuels Corporation, August 1990.
19. ANF-1358(P)(A), Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors," Framatome ANP, September 2005.