



Exelon Generation Company, LLC www.exeloncorp.com
Braidwood Station
35100 South Route 53, Suite 84
Braceville, IL 60407-9619

10 CFR 50.73

June 1, 2015
BW150050

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Braidwood Station, Unit 1
Facility Operating License No. NPF-72
NRC Docket No. STN 50-456

Subject: Licensee Event Report 2015-002-00 – Indication in Control Rod Drive Mechanism Nozzle Weld due to Embedded Flaws Opening Up from Thermal and Pressure Stresses during Operation

The enclosed Licensee Event Report (LER) is being submitted in accordance with 10 CFR 50.73, "Licensee Event Report System."

There are no regulatory commitments contained in this letter. Should you have any questions concerning this submittal, please contact Mr. Phillip J. Raush, Regulatory Assurance Manager, at (815) 417-2800.

Respectfully,

A handwritten signature in black ink, appearing to read "Mark Kanavos", with a long horizontal flourish extending to the right.

Mark Kanavos
Site Vice President
Braidwood Station

Enclosure: LER 2015-002-00

cc: NRR Project Manager – Braidwood Station
Illinois Emergency Management Agency – Division of Nuclear Safety
US NRC Regional Administrator, Region III
US NRC Senior Resident Inspector (Braidwood Station)
Illinois Emergency Management Agency - Braidwood Representative