



1600 West Main Street  
Willimantic, CT 06226-1128  
tel 860.465.8898  
www.generalcable.com

**Roy Haller**  
Lead Engineer-Nuclear Products

May 28, 2015

Steven Graham  
Lead Engineer  
Duke Energy - Nuclear Generation Department  
EC07C - Nuclear Engineering Division, Corporate Programs  
PO Box 1006, Charlotte, NC 28201-1006

Dear Steve:

Do you concur with the following statements that represent a summary of the discussions between Duke and General Cable concerning NRC Notice of Nonconformance 99900227/2015-201-02?

Duke Energy Carolinas (Duke) was in contact with and provided input into General Cable's response to Notice of Nonconformance 99900227/2015-201-02 and is aware of the responsibility for accepting the cables and their use in Duke nuclear plants.

Since internal Duke design criteria directs the removal of PVC jackets from the cables' interlocked armor for use inside Containment at appropriate plants, and recognizing that such jacket removal is NOT correlated to IEEE 383-1974 Class 1E qualification, Duke Energy suggested that the PVC removal statement be deleted from future General Cable Certificates of Compliance.

Sincerely,

Roy Haller

Roy, I concur. Sincerely,

*Steven N. Graham 5/28/2015*

Steven N. Graham, Lead Engineer  
Duke Energy - Nuclear Generation  
Email [Steven.Graham@duke-energy.com](mailto:Steven.Graham@duke-energy.com) or [s.graham@ieee.org](mailto:s.graham@ieee.org)

