

NRR-PMDAPEm Resource

From: Alan I Hassoun [hassouna@dteenergy.com]
Sent: Tuesday, June 09, 2015 11:18 AM
To: Rankin, Jennivine
Subject: Re: FERMI 2 - Submittal of Inservice Testing Program Relief Request PRR-012 for Quarterly Test of Core Spray Pumps (MF5816)

Jennie, we do not have any questions or concerns regarding this issue.
Thank you.

*Alan I. (Sam) Hassoun, P. E.
Supervisor - Nuclear Licensing
DTE Energy - Fermi 2 Nuclear Power Plant
Office: 734 586-4287*

*** PROPRIETARY, CONFIDENTIAL OR PRIVILEGED COMMUNICATION ***

This communication may contain proprietary, privileged or confidential information protected by law. It is solely for the use of the intended recipient named above. Any review, dissemination, distribution, forwarding, or copying of this communication by someone other than the intended recipient, or the individual responsible for delivering this communication to the intended recipient, is prohibited. If you have received this communication in error, please immediately notify the sender via email, then destroy the original message.

-----"Rankin, Jennivine" wrote: -----

To: "Alan I Hassoun (hassouna@dteenergy.com)"
From: "Rankin, Jennivine"
Date: 06/09/2015 10:40AM
Subject: FERMI 2 - Submittal of Inservice Testing Program Relief Request PRR-012 for Quarterly Test of Core Spray Pumps (MF5816)

Mr. Hassoun,

Pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 50.55a(z), alternatives to the requirements may be used when authorized by the U.S. Nuclear Regulatory Commission (NRC) if the licensee demonstrates that (i) the proposed alternative would provide an acceptable level of quality and safety or (ii) compliance with the specified requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety.

Pursuant to 10 CFR 50.55a(f)(5)(iii), if the licensee has determined that conformance with certain Code requirements is impractical for the facility, the licensee must notify NRC and submit information to support the determination. Pursuant to 10 CFR 50.55a(f)(6)(i) the NRC will evaluate the licensee's determination that the code requirements are impractical. The NRC may grant relief or may impose such alternative requirements.

In the Subject request dated March 5, 2015, DTE Electric Company is seeking NRC authorization in accordance with 10 CFR 50.55a(z)(1), based on the proposed alternative would provide an acceptable level of quality and safety.

Upon review of the Subject request, the NRC staff is informing you that it will be reviewing the Subject relief request under 10 CFR 50.55a(f)(5)(iii), and not the section proposed in the request.

Please let me know if you have any specific questions or concerns regarding this matter.

Thanks,

Jennie

Jennie Rankin, Project Manager

Plant Licensing Branch III-1

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

Hearing Identifier: NRR_PMDA
Email Number: 2143

Mail Envelope Properties (OF12186827.40E6BA6F-ON85257E5F.00540748-85257E5F.0054074C)

Subject: Re: FERMI 2 - Submittal of Inservice Testing Program Relief Request PRR-012
for Quarterly Test of Core Spray Pumps (MF5816)
Sent Date: 6/9/2015 11:17:48 AM
Received Date: 6/9/2015 11:17:52 AM
From: Alan I Hassoun

Created By: hassouna@dteenergy.com

Recipients:
"Rankin, Jennivine" <Jennivine.Rankin@nrc.gov>
Tracking Status: None

Post Office: dteenergy.com

Files	Size	Date & Time
MESSAGE	2898	6/9/2015 11:17:52 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: