



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

July 6, 2015

LICENSEE: DTE Electric Company

FACILITY: Fermi 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON APRIL 29 AND MAY 4, 2015, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND DTE ELECTRIC COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE FERMI 2 LICENSE RENEWAL APPLICATION (TAC NO. MF4222)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of DTE Electric Company (DTE or the applicant) held two telephone conference calls on April 29 and May 4, 2015, to discuss and clarify the applicant's response to request for additional information (RAI) B.1.45-2, concerning the Fermi 2 license renewal application. The telephone conference calls was useful in clarifying the applicant's response to the staff's RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Daneira Meléndez-Colón, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosures:

1. List of Participants
2. Summary of Telephone Conference Calls

cc: Listserv

July 6, 2015

LICENSEE: DTE Electric Company

FACILITY: Fermi 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON APRIL 29 AND MAY 4, 2015, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND DTE ELECTRIC COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE FERMI 2 LICENSE RENEWAL APPLICATION (TAC NO. MF4222)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of DTE Electric Company (DTE or the applicant) held two telephone conference calls on April 29 and May 4, 2015, to discuss and clarify the applicant's response to request for additional information (RAI) B.1.45-2, concerning the Fermi 2 license renewal application. The telephone conference calls was useful in clarifying the applicant's response to the staff's RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Daneira Meléndez-Colón, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosures:

1. List of Participants
2. Summary of Telephone Conference Calls

cc: Listserv

DISTRIBUTION: See next page

ADAMS Accession No.: **ML15175A039**

*Concurred via e-mail

OFFICE	LA:RPB1:DLR*	PM:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	YEdmonds	DMeléndez-Colón	YDíaz-Sanabria	DMeléndez-Colón
DATE	6/30/15	7/2/15	7/6/15	7/6/15

OFFICIAL RECORD COPY

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON APRIL 29 AND
MAY 4, 2015, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION
AND DTE ELECTRIC COMPANY, CONCERNING REQUESTS FOR
ADDITIONAL INFORMATION PERTAINING TO THE FERMI 2 LICENSE
RENEWAL APPLICATION (TAC NO. MF4222)

DISTRIBUTION:

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRasb Resource

RidsNrrDlrRsrg Resource

RidsNrrPMFermi2 Resource

D. Melendez-Colon

E. Keegan

B. Wittick

B. Harris, OGC

D. Roth, OGC

M. Kunowski, RIII

B. Kemker, RIII

V. Mitlyng, RIII

P. Chandrathil, RIII

TELEPHONE CONFERENCE CALLS
FERMI 2
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS
APRIL 29 AND MAY 4, 2015

PARTICIPANTS

Daneira Meléndez-Colón
William Holston
Giovanni Facco
Allen Hiser
Lynne Goodman
Kevin Lynn
John Tibai
Rondi Sloan
Alan Cox
Andy Taylor
Wayne Bichlmeir
Dave Wooten

AFFILIATIONS

U. S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NRC
DTE Electric Company (DTE)
DTE
DTE
DTE
Entergy
Entergy
Entergy
Entergy

SUMMARY OF TELEPHONE CONFERENCE CALLS
FERMI 2
LICENSE RENEWAL APPLICATION
APRIL 29 AND MAY 4, 2015

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of DTE Electric Company (DTE or the applicant) held two telephone conference calls on April 29 and May 4, 2015, to discuss and clarify the response to request for additional information (RAI) B.1.45-2 concerning the Fermi 2 license renewal application (LRA).

RAI B.1.45-2

Background:

In the letter dated April 27, 2015, the applicant provided its response to RAI B.1.45-2. The staff requested clarification on the applicant's response.

Discussion:

The staff indicated that the response to RAI B.1.45-2 requires clarification. Specifically, the staff asked for clarification on the applicant's response to Part a of RAI B.1.45-2 regarding the performance of adhesion testing when peeling, delamination, or blistering is found.

In addition, the staff requested clarification regarding a change in the scope of the Coatings Integrity Program included in the letter dated April 27, 2015. Specifically, the staff asked for clarification on how loss of piping base material for the mechanical draft cooling tower (MDCT) spray header assemblies will be addressed (i.e., how failure of the pressure boundary due to localized loss of galvanized coating will be addressed).

The applicant provided clarification and stated that it will revise its response to RAI B.1.45-2 and that it will provide additional clarification regarding how loss of piping base material for the MDCT spray header assemblies will be addressed.

ENCLOSURE 2