

JUN 17 2015



HCH-2015-020

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED  
ARTICLE NUMBER: 7013 1710 0000 6324 5127

Department of Environmental Protection  
Office of Permit Management  
Division of Water Quality  
PO Box 420  
Trenton, N.J. 08625-0420

**NEW JERSEY POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT  
HOPE CREEK GENERATING STATION  
NJPDES PERMIT NJ0025411**

Dear Sir:

Attached is the Discharge Monitoring Report for the Hope Creek Generating Station for the month of May 2015, also attached are the semi annual Consolidated Waste Characterization Reports for DSN 461C and DSN 462B.

This report is required by and prepared specifically for the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analyses required to be performed by the above agencies. The choice of the measurement devices and analytical methods are controlled by the EPA and the NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or that any reading or analytical result represents the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions concerning this report, please feel free to contact Travis Zigo at (856) 339-2493.

Sincerely,

A handwritten signature in dark ink that reads "Paul J. Davison".

Paul J. Davison  
Site Vice President – Hope Creek

IE25  
NRK

JUN 17 2015

HCH-2015-020  
NJPDES DMR

2

Attachments

C     Executive Director, DRBC  
       USNRC - Docket number 50-354



JUN 17 2015

## EXPLANATION OF CONDITIONS

### May 2015

The following explanations are included to clarify possible deviation from permit conditions.

General - The columns labeled "No. Ex" on the enclosed DMR tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

Deviations from required sampling, analysis monitoring and reporting methods and periodicities are indicated on the respective transmittal sheet with explanations below.

Results reported on the Discharge Monitoring Report forms are consistent with permit limits, data supplied from contract laboratories, the December 2007 revision of the NJDEP Monitoring Report Form Reference Manual and specific guidance from DEP personnel.

For DSN 462B CWCR, the initial sample was obtained on 4/8/15 and a second sample was obtained on 5/8/15 for an analyte not analyzed for in the initial sample. All samples were obtained within the required sampling time frame.

JUN 17 2015

HCH-2015-020  
NJPDES DMR

4

# EXPLANATION OF EXCEEDANCES

May 2015

The following exceedances are included in the attached report and explained below.

DSN No.

EXPLANATION


**No Exceedances**



COUNTY OF SALEM  
STATE OF NEW JERSEY


I, Paul J. Davison, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the Site Vice President-Hope Creek for PSEG Nuclear, and as such am authorized to sign Hope Creek's Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.



Paul J. Davison  
Site Vice President – Hope Creek

Sworn and subscribed before me  
this 17 day of June, 2015.



**JENNIFER M. TURNER**  
ID # 2332667  
NOTARY PUBLIC OF NEW JERSEY  
My Commission Expires 8/3/2015



New Jersey Department of Environmental Protection  
Division of Water Quality  
**Surface Water Discharge Monitoring Report Submittal Form**

PI 46815

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
<b>NJ0025411</b>	<table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td style="width: 25%;">Month</td><td style="width: 25%;">Day</td><td style="width: 25%;">Year</td></tr><tr><td style="text-align: center;">5</td><td style="text-align: center;">1</td><td style="text-align: center;">2015</td></tr></table> To <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td style="width: 25%;">Month</td><td style="width: 25%;">Day</td><td style="width: 25%;">Year</td></tr><tr><td style="text-align: center;">5</td><td style="text-align: center;">31</td><td style="text-align: center;">2015</td></tr></table>	Month	Day	Year	5	1	2015	Month	Day	Year	5	31	2015	<b>461A – DSN 461A – DSW</b>
Month	Day	Year												
5	1	2015												
Month	Day	Year												
5	31	2015												

**PERMITTEE:**

PSE&G NUCLEAR LLC  
PO BOX 236 – ALLOWAY CREEK NECK RD  
HANCOCKS BRIDGE, NJ 08038

**LOCATION OF ACTIVITY:**

HOPE CREEK GENERATING STATION  
ARTIFICIAL ISLAND  
FOOT OF BUTTONWOOD RD  
LOWER ALLOWAYS CREEK, NJ 08038

**REPORT RECIPIENT:**


PSE&G  
TRAVIS ZIGO  
PO BOX 236 / H15  
HANCOCKS BRIDGE, NJ 08038

**REGION / COUNTY: Southern / Salem County**

**CHECK IF APPLICABLE:**    ☐ No Discharge this Monitoring Period    ☐ Monitoring Report Comments Attached

**WHO MUST SIGN**    The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Paul J. Davison, Site Vice President-Hope Creek	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	6/17/15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE
	856-339-1555
	AREA CODE/PHONE NUMBER

*\*For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER



# Surface Water Discharge Monitoring Report

PI 46815

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

461A DSN 461A - DSW

5/1/2015 TO 5/31/2015

HOPE CREEK GENERATING STATION

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	52.399	61.229	MGD	*****	*****	*****	*****	Ø	Continuous	Meter
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
Flow, In Conduit or Thru Treatment Plant 50050 7 Intake From Stream	SAMPLE MEASUREMENT	56.385	73.795	MGD	*****	*****	*****	*****	Ø	Continuous	Meter
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.5	*****	8.6	SU	Ø	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Mysis Bahia TAN3E 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	Code = N	*****	*****	%EFFL	Ø	Code = N	Code = N
	PERMIT REQUIREMENT	*****	*****		REPORT 01RPMN	*****	*****				
	QL	*****	*****		*****	*****	*****				
IC25 Statre 7day Chr Mysis Bahia TBP3E 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	Code = N	*****	*****	%EFFL	Ø	Code = N	Code = N
	PERMIT REQUIREMENT	*****	*****		REPORT 01RPMN	*****	*****				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	Ø	3/Week	Grab
	PERMIT REQUIREMENT	*****	*****		*****	0.2 01MOAV	0.5 01DAMX				
	RQL	*****	*****		*****	0.1	0.1				

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



# Surface Water Discharge Monitoring Report

PI 46815

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

461A DSN 461A - DSW

5/1/2015 TO 5/31/2015

HOPE CREEK GENERATING STATION

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	25.4	32.6	DEG.C	Ø	Continuous	Meter
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	36.2 01DAMX			Continuous	METER
	QL	*****	*****	*****	*****	*****	*****				
Temperature, oC 00010 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	*****	22.1	26.5	DEG.C	Ø	Continuous	Meter
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX			Continuous	METER
	QL	*****	*****	*****	*****	*****	*****				
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.92	1.92	MG/L	Ø	1/month	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX			1/Month	GRAB
	QL	*****	*****	*****	*****	*****	*****				
Carbon, Tot Organic (TOC) 00680 2 Effluent Net Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.47	0.47	MG/L	Ø	1/month	Calctd
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX			1/Month	CALCTD
	QL	*****	*****	*****	*****	*****	*****				
Carbon, Tot Organic (TOC) 00680 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.57	1.57	MG/L	Ø	1/month	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX			1/Month	GRAB
	QL	*****	*****	*****	*****	*****	*****				
Sulfate, Total (as SO4) 00945 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	UG/L	Ø	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX			1/6 Months	COMP24
	QL	*****	*****	*****	*****	*****	*****				

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



# Surface Water Discharge Monitoring Report

PI 46815

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

461A DSN 461A - DSW

5/1/2015 TO 5/31/2015

HOPE CREEK GENERATING STATION

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Boron, Total (as B) 01022 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	UG/L	Ø	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			1/6 Months	COMPOS
	QL	*****	*****		*****	*****	*****				
Heat (winter) (per Hr.) 81387 1 Effluent Gross Value	SAMPLE MEASUREMENT	103	281	MBTU/HR	*****	*****	*****	*****	Ø	1/Day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	662 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
Copper, Total Recoverable 01119 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	UG/L	Ø	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			1/6 Months	COMPOS
	RQL	*****	*****		*****	2	2				
Lab Certification #  99999 99 Lab	SAMPLE MEASUREMENT	17451	PA166		03036						
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



New Jersey Department of Environmental Protection  
Division of Water Quality  
**Surface Water Discharge Monitoring Report Submittal Form**

PI 46815

NJPDES PERMIT	MONITORING PERIOD				MONITORED LOCATION:			
<b>NJ0025411</b>	Month	Day	Year	To	Month	Day	Year	<b>461C - DSN 461C - DSW internal</b>
	5	1	2015		5	31	2015	

**PERMITTEE:**

PSE&G NUCLEAR LLC  
PO BOX 236 – ALLOWAY CREEK NECK RD  
HANCOCKS BRIDGE, NJ 08038

**LOCATION OF ACTIVITY:**

HOPE CREEK GENERATING STATION  
ARTIFICIAL ISLAND  
FOOT OF BUTTONWOOD RD  
LOWER ALLOWAYS CREEK, NJ 08038

**REPORT RECIPIENT:**

PSE&G  
TRAVIS ZIGO  
PO BOX 236 / H15  
HANCOCKS BRIDGE, NJ 08038

**REGION / COUNTY: Southern / Salem County**

**CHECK IF APPLICABLE:**    ☐ No Discharge this Monitoring Period    ☐ Monitoring Report Comments Attached

**WHO MUST SIGN**    The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

<u>Paul J. Davison, Site Vice President- Hope Creek</u>	N/A
<b>NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR</b>	<b>GRADE AND REGISTRY NUMBER (IF APPLICABLE)</b>
<u>Paul J. Davison</u>	<u>6/17/15</u>
<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR</b>	<b>DATE</b>
	<u>856-339-1555</u>
	<b>AREA CODE/PHONE NUMBER</b>

*\*For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
<b>NAME AND TITLE</b>	<b>SIGNATURE</b>	<b>DATE</b>	<b>AREA CODE/PHONE NUMBER</b>



# Surface Water Discharge Monitoring Report

PI 46815

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

461C DSN 461C - DSW intern

5/1/2015 TO 5/31/2015

HOPE CREEK GENERATING STATION

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	0.024	0.060	MGD	*****	*****	*****	*****	Ø	Continuous	Meter
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			Continuous	METER
	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	4	4	MG/L	Ø	1/month	Compos
	PERMIT REQUIREMENT	*****	*****		*****	30 01MOAV	100 01DAMX			1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				
Petrol Hydrocarbons, Total Recoverable 45501 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	<2	<2	MG/L	Ø	1/month	Grab
	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX			2/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	3	3	MG/L	Ø	1/month	Compos
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX			1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17451	PA166		03036						
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



New Jersey Department of Environmental Protection  
Division of Water Quality  
**Surface Water Discharge Monitoring Report Submittal Form**

PI 46815

NJPDES PERMIT	MONITORING PERIOD				MONITORED LOCATION:		
<b>NJ0025411</b>	Month	Day	Year	To	Month	Day	Year
	5	1	2015		5	31	2015
<b>462B - DSN 462B - DSW Internal</b>							

**PERMITTEE:**

PSE&G NUCLEAR LLC  
PO BOX 236 – ALLOWAY CREEK NECK RD  
HANCOCKS BRIDGE, NJ 08038

**LOCATION OF ACTIVITY:**

HOPE CREEK GENERATING STATION  
ARTIFICIAL ISLAND  
FOOT OF BUTTONWOOD RD  
LOWER ALLOWAYS CREEK, NJ 08038

**REPORT RECIPIENT:**


PSE&G  
TRAVIS ZIGO  
PO BOX 236 / H15  
HANCOCKS BRIDGE, NJ 08038

**REGION / COUNTY: Southern / Salem County**

**CHECK IF APPLICABLE:**    ☐ No Discharge this Monitoring Period    ☐ Monitoring Report Comments Attached

**WHO MUST SIGN**    The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Paul J. Davison, Site Vice President- Hope Creek	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	6/17/15      856-339-1555
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE      AREA CODE/PHONE NUMBER

*\*For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER



# Surface Water Discharge Monitoring Report

PI 46815

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

462B DSN 462B - DSW Intern

5/1/2015 TO 5/31/2015

HOPE CREEK GENERATING STATION

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	0.021	0.032	MGD	*****	*****	*****	*****	Ø	Continuous	Meter
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			Continuous	METER
	QL	*****	*****		*****	*****	*****				
BOD, 5-Day (20 oC)  00310 G Raw Sew/influent	SAMPLE MEASUREMENT	*****	*****	*****	*****	329	329	MG/L	Ø	1/month	Compos
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				
BOD, 5-Day (20 oC)  00310 1 Effluent Gross Value	SAMPLE MEASUREMENT	1	1	KG/DAY	*****	14	14	MG/L	Ø	1/month	Compos
	PERMIT REQUIREMENT	8 01MOAV	REPORT 01WKAV		*****	30 01MOAV	45 01WKAV			1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				
BOD, 5-Day (20 oC)  00310 K Percent Removal	SAMPLE MEASUREMENT	*****	*****	*****	95.7	*****	*****	PERCENT	Ø	1/month	Calctd
	PERMIT REQUIREMENT	*****	*****		87.5 01MOAVMN	*****	*****			1/Month	CALCTD
	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended 00530 G Raw Sew/influent	SAMPLE MEASUREMENT	*****	*****	*****	*****	610	610	MG/L	Ø	1/month	Compos
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	19	19	MG/L	Ø	1/month	Compos
	PERMIT REQUIREMENT	*****	*****		*****	30 01MOAV	45 01WKAV			1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



# Surface Water Discharge Monitoring Report

PI 46815

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

462B DSN 462B - DSW Intern

5/1/2015 TO 5/31/2015

HOPE CREEK GENERATING STATION

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Solids, Total Suspended	SAMPLE MEASUREMENT	*****	*****		97	97	*****		0	1/month	Calctd
00530 K Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 01MOAVMN	REPORT 01MOAV	*****	PERCENT		1/Month	CALCTD
	QL	*****	*****		*****	*****	*****				
Oil and Grease	SAMPLE MEASUREMENT	*****	*****		*****	12	12		0	1/month	Grab
00556 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	10 01MOAV	15 01DAMX	MG/L		1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Nitrogen, Ammonia Total (as N)	SAMPLE MEASUREMENT	*****	*****		*****	12	12		0	1/month	Compos
00610 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	35 01MOAV	REPORT 01DAMX	MG/L		1/Month	COMPOS
	QL	*****	*****		*****	*****	*****				
Enterococci	SAMPLE MEASUREMENT	*****	*****		*****	<10	<10		0	1/month	Grab
61211 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOGE	REPORT 01WKGE	#/100ML		1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Coliform, Fecal General	SAMPLE MEASUREMENT	*****	*****		*****	<10	<10		0	1/month	Grab
74055 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	200 01MOGE	400 01WKGE	#/100ML		1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17451	PA166		06005						
99999 99 Lab	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



New Jersey Department of Environmental Protection  
Division of Water Quality

PI 46815

Consolidated Waste Characterization Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD							MONITORED LOCATION:											
NJ0025411	<table border="1"> <tr> <th>Month</th> <th>Day</th> <th>Year</th> </tr> <tr> <td>1</td> <td>1</td> <td>2015</td> </tr> </table>	Month	Day	Year	1	1	2015	To	<table border="1"> <tr> <th>Month</th> <th>Day</th> <th>Year</th> </tr> <tr> <td>6</td> <td>30</td> <td>2015</td> </tr> </table>	Month	Day	Year	6	30	2015				461C - DSN 461C - DSW i
Month	Day	Year																	
1	1	2015																	
Month	Day	Year																	
6	30	2015																	

**PERMITTEE:**

PSE&G NUCLEAR LLC  
PO BOX 236 - ALLOWAY CREEK NE  
HANCOCKS BRIDGE, NJ 08038

**LOCATION OF ACTIVITY:**

HOPE CREEK GENERATING  
STATION  
ARTIFICIAL ISLAND  
FOOT OF BUTTONWOOD RD  
LOWER ALLOWAYS CREEK, NJ  
08038

**REPORT RECIPIENT:**

PSE&G  
TRAVIS ZIGO  
PO BOX 236 / H15  
HANCOCKS BRIDGE, NJ 08038


REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

**WHO MUST SIGN** The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Paul J. Davison, Site Vice President - Hope Creek  
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, OR  
AUTHORIZED AGENT

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR  
AUTHORIZED AGENT

N/A  
GRADE AND REGISTRY NUMBER (IF APPLICABLE)

6/17/15  
DATE(MONTH/DAY  
/YEAR)

856-339-1555  
AREA CODE/TELEPHONE NUMBER

*\*For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A  
NAME AND TITLE  
N/A  
DATE

N/A  
SIGNATURE  
N/A  
AREA CODE/PHONE NUMBER



# Consolidated Waste Characterization Report

PI 46815

PERMIT NUMBER: MONITORED LOCATION: MONITORING PERIOD: FACILITY NAME:

NJ0025411

461C DSN 461C - DSW intern 1/1/2015 TO 6/30/2015

HOPE CREEK GENERATING STATION

SAMPLE DATE OF REPORT: 5/5/15

PARAMETER	QL	REPORTED VALUE	UNITS	REMARK CODE	SAMPLE TYPE
Nitrogen, Ammonia Total (as N) 00610 Effluent Gross Value		1730	UG/L		GRAB
Zinc, Total Recoverable 01094 Effluent Gross Value	RQL = 10	30.1	UG/L		GRAB
Cadmium, Total Recoverable 01113 Effluent Gross Value	RQL = 4	0.276	UG/L		GRAB
Copper, Total Recoverable 01119 Effluent Gross Value	RQL = 2	20.6	UG/L		GRAB
Dichlorobromomethane 32101 Effluent Gross Value	RQL = 6	<0.120	UG/L		GRAB
Chloroform 32106 Effluent Gross Value	RQL = 5	<0.250	UG/L		GRAB
Lab Certification # 99999 Lab		PA166			NOT AP
Lab Certification # 99999 Lab					NOT AP
Lab Certification # 99999 Lab					NOT AP
Lab Certification # 99999 Lab					NOT AP
Lab Certification # 99999 Lab					NOT AP

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.



New Jersey Department of Environmental Protection  
Division of Water Quality

PI 46815

Consolidated Waste Characterization Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD							MONITORED LOCATION:
NJ0025411	Month	Day	Year	To	Month	Day	Year	462B - DSN 462B - DSW I
	1	1	2015		6	30	2015	

**PERMITTEE:**

PSE&G NUCLEAR LLC  
PO BOX 236 - ALLOWAY CREEK NE  
HANCOCKS BRIDGE, NJ 08038

**LOCATION OF ACTIVITY:**

HOPE CREEK GENERATING  
STATION  
ARTIFICIAL ISLAND  
FOOT OF BUTTONWOOD RD  
LOWER ALLOWAYS CREEK, NJ  
08038

**REPORT RECIPIENT:**

PSE&G  
TRAVIS ZIGO  
PO BOX 236 / H15  
HANCOCKS BRIDGE, NJ 08038


REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☒ Monitoring Report Comments Attached

**WHO MUST SIGN** The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Paul J. Davison, Site Vice President - Hope Creek  
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, OR  
AUTHORIZED AGENT

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR  
AUTHORIZED AGENT

N/A  
GRADE AND REGISTRY NUMBER (IF APPLICABLE)

6/17/15  
DATE (MONTH/DAY  
/YEAR)

856-339-1555  
AREA CODE/TELEPHONE NUMBER

*\*For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A  
NAME AND TITLE  
N/A  
DATE

N/A  
SIGNATURE  
N/A  
AREA CODE/PHONE NUMBER



# Consolidated Waste Characterization Report

PI 46815

PERMIT NUMBER: MONITORED LOCATION: MONITORING PERIOD: FACILITY NAME:

NJ0025411 462B DSN 462B - DSW Intern 1/1/2015 TO 6/30/2015 HOPE CREEK GENERATING STATION

SAMPLE DATE OF REPORT: 4/8/15 \*

PARAMETER	QL	REPORTED VALUE	UNITS	REMARK CODE	SAMPLE TYPE
Cyanide, Total (as CN) 00720 Effluent Gross Value *	RQL = 40	< 3.70	UG/L		GRAB
Nickel, Total Recoverable 01074 Effluent Gross Value	RQL = 10	3.10	UG/L		GRAB
Zinc, Total Recoverable 01094 Effluent Gross Value	RQL = 10	98.4	UG/L		GRAB
Cadmium, Total Recoverable 01113 Effluent Gross Value	RQL = 4	< 0.180	UG/L		GRAB
Chromium, Total Recoverable 01118 Effluent Gross Value	RQL = 10	< 0.210	UG/L		GRAB
Copper, Total Recoverable 01119 Effluent Gross Value	RQL = 2	20.8	UG/L		GRAB
Lab Certification # 99999 Lab		PA166			NOT AP
Lab Certification # 99999 Lab					NOT AP
Lab Certification # 99999 Lab					NOT AP
Lab Certification # 99999 Lab					NOT AP
Lab Certification # 99999 Lab					NOT AP

Comments: If there are any questions regarding the monitoring report form, please contact Heather Genievich of the Bureau of Surface Water Permitting at (609) 292-4860.

\* See Explanation of Conditions