

**Terry, Tomeka**

**From:** Sgarro, Rocco R <Rocco.Sgarro@TalenEnergy.com>  
**Sent:** Monday, June 08, 2015 10:58 AM  
**To:** Terry, Tomeka  
**Subject:** DEIS comments

Tomeka,

(2)

4/21/2015  
80 FR 22231

RECEIVED

2015 JUN 30 AM 11:49

RULES AND DIRECTIVES  
BRANCH  
USNRC

The following is a list of minor comments on the Bell Bend DEIS for your information and use:

- Table 2-16 footnote (a) typo: it lists "E" rather than "FE" for Federally Endangered.
- Page 3-12, Lines 9 & 10: this discussion should refer to the four trains of ESW, not the "four PWR cooling loops".
- Page 3-12, Line 24: The ESWEMS pumphouse is located at the west end of the pond.
- Page 8-5, lines 10 and 30, and Page 8-6, Line 20 – All refer to a Section "0" that does not exist.
- Page 7-35, Lines 38 & 39 – The reference to auxiliary boilers is incorrect; they are electrical and are not a combustion source. The diesel driven fire pumps should be added to this discussion.
- Page 5-48, Line 19, and Page 5-49, Line 2: the Noise discussion should reference two "natural" draft cooling towers for clarity
- Page 2-5, Lines 3 & 4: Talen "Electric" should be Talen Energy.
- Page 2-82, Line 22 and Page 4-36, Line 34: The second Normandeau reference should be eliminated. It refers to the 2013 mist net study which we corrected to eliminate an error in reporting the Northern long eared bat.
- Page 2-83, Line 14: The Northern long eared bat finding only applies to the 2008 survey.

In addition, the DEIS cites two errors in the Bell Bend ER:

- Page 4-108, Lines 15&16: note mentions failure to revise the maximum dose in Section 4.5.5.1 in ER Rev 4
- Page 5-83, Table 5-11, footnote (b); Page G-5, Lines 20-22; Page G-9, Table G-6, footnote (a): each citation notes that wrong values were used in the ER and corrected values from the applicant's calculation were used in the DEIS

For these two items, I will be forwarding you a letter docketing the revisions we made to the ER based on our corrective actions.

Please advise if you have any questions.

Rocky

**Please note updated contact information below:**



**Rocco Sgarro** • Vice President – Nuclear Project Development  
Bell Bend • (610) 774-7552 • [Rocco.Sgarro@talenenergy.com](mailto:Rocco.Sgarro@talenenergy.com)  
Talen Energy • 835 Hamilton St., Suite 150 • Allentown, PA 18101

**SUNSI Review Complete**

**Template = ADM – 013**

**E-RIDS= ADM-03**

**Add= T. Terry (4272)**

**P. Vokoun (P5v1)**