

From: [Newhouse, Jerry E](#)
To: [Wertz, Geoffrey](#)
Cc: [Sean M. McDeavitt](#)
Subject: [External_Sender] Updated Proposed TEES TS
Date: Tuesday, June 30, 2015 3:31:13 PM

Good Afternoon,

Following our telephone conversation this afternoon, I would like to submit three minor revisions to our proposed TS.

- 1) In TS 3.5.1, "Radiation Monitoring," Table 3 Note, revise to read, "...if a portable or fixed gamma-sensitive..."
- 2) In TS 5.5, "Radiation Monitoring System," Specification, revise to read, "...from the stack particulate or stack gas (xenon) facility air monitor..."
- 3) In TS 6.8.2, "Records to be Retained for at Least One Certification Cycle," revise the heading to read, "Records to be Retained for at Least One License Cycle," and the body to read, "Records of retraining and requalification of licensed operations personnel shall be maintained at all times the individual is employed or until the license is renewed."

I declare under penalty of perjury that the foregoing is true and correct to the best of my knowledge.

Jerry Newhouse
Assistant Director
Nuclear Science Center
Texas A&M Engineering Experiment Station
Office: (979) 845-7551
Cell: (979) 997-6134